

CONTROL BLOCK: ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)01 PASES1 00-000000-000 41111 5
7 8 9 14 15 25 26 30 37 CAT 38

CONT

01 REPORT SOURCE L 05000387 040583 042983 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During the performance of a test to calibrate the safety relief valves (SRV's)

03 acoustic monitoring system, one of the monitors did not indicate that its respect-

04 ive SRV was open. There were no adverse consequences in that the valves open or

05 closed status could be verified from tailpipe temperature indication.

06

07

08

09 SYSTEM CODE I F 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16

7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 83 21 22 23 24 25 26 27 28 29 30 31 32

18 ACTION TAKEN A 19 FUTURE ACTION Z 20 EFFECT ON PLANT Z 21 SHUTDOWN METHOD Z 22 HOURS 00000 23 ATTACHMENT SUBMITTED N 24 NPRO-4 FORM SUB. N 25 PRIME COMP. SUPPLIER A 26 COMPONENT MANUFACTURER X9999

33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The faulty indication was caused by a broken pin on the accelerometer connector.

11 The connector was replaced in the field and the channel checked and verified to

12 operate properly.

13

14

15 FACILITY STATUS B 28 % POWER 000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY C 31 DISCOVERY DESCRIPTION Test Failure 32

7 8 9 10 11 12 13 14 15 16 17 18 19 20

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39

7 8 9 10 11 12 13 14 15 16 17 18 19 20

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41

7 8 9 10 11 12 13 14 15 16 17 18 19 20

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

7 8 9 10 11 12 13 14 15 16 17 18 19 20

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

7 8 9 10 11 12 13 14 15 16 17 18 19 20

8305060598 830429
PDR ADOCK 05000387
S PDR

NRC USE ONLY

NAME OF PREPARER L.A. Kuczynski

PHONE (717) 542-2181 X3759