

CONTROL BLOCK:

--	--	--	--	--	--

 ①

0	1	A	L	J	M	F	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT	58

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	4	8	7	0	4	1	2	8	3	8	0	5	0	2	8	3	9
60	61								68	69						74	75							80

DOCKET NUMBER

EVENT DATE

REPORT DATE

At 0525 on 4/12/83, during the performance of FNP-1-STP-80.1 (Diesel Generator 1B Operability Test), Diesel Generator 1B was declared inoperable due to a start failure. Prior to the event, "A" train containment spray was voluntarily inoperable for surveillance test performance. Consequently, at 0525 on 4/12/83, "B" train containment spray was declared inoperable due to the loss of emergency power (i.e. 1B Diesel Generator failure). Tech. Spec. sections 3.8.1.1 and 3.6.2.1, in part, require diesel generator 1B and "B" train containment spray to be operable (see attached)

09		SYSTEM CODE EE		CAUSE CODE E		CAUSE SUBCODE B		COMPONENT CODE ENGINE				COMP. SUBCODE Z		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
LER/RO REPORT NUMBER		EVENT YEAR 83		SEQUENTIAL REPORT NO. 016		OCCURRENCE CODE 03		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN AX		FUTURE ACTION Z	
17		21		23		24		27		28		30		32	
ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
33		35		36		37		41		42		43		44	
18		19		20		21		22		23		24		25	
26		27		28		29		30		31		32		33	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0	This event was attributed to the mechanical binding of the fuel filter constant vent
1 1	check valve. The valve was replaced and following the satisfactory performance of
1 2	FNP-1-STP-80.1, Diesel Generator 1B was declared operable at 0158 on 4/13/83. The "A"
1 3	train containment spray suction valve was opened at 0545 on 4/12/83 clearing the LCO
1 4	on containment spray. The fuel oil check valves will be functionally (see attached)

8 9
FACILITY STATUS (28) 1 5 E 1000 29 30 OTHER STATUS 44
7 8 9 10 11 12 13
ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) 44
7 8 9 10 11 12 13
1 6 Z 33 Z 34 NA 44
45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
METHOD OF DISCOVERY (31) B 60
DISCOVERY DESCRIPTION (32) Surveillance Test 80
LOCATION OF RELEASE (36) NA 60

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	H	0	0	0	41 NA

7		8		9		10		11		12	
1		2		3		4		5		6	
1				9				43			
Z				42				NA			

7 8 9 10
PUBLCITY
ISSUED DESCRIPTION (45) NA
2 0 N (44) NA
7 8 9 10
8305100010 830502
PDR ADDCK 05000348
S PDR
NRC USE ONLY
68 69 80

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156

Licensee Event Report
LER No. 83-016/03L-0
Page 2 of 2

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (CONTINUED)

respectively. Tech. Spec. action statement requirements were met. Health/Safety of the public was not affected.

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (CONTINUED)

checked during quarterly inspections of Diesel Generators 1B, 2B, and 1-2A.