

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER DALLAS, TEXAS 75201-3050

Log # TXX-3664  
File # 906.2

May 6, 1983

Mr. Harold R. Denton  
Director of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NO. 50-445  
TRANSMITTAL OF INTEGRATED LEAK RATE TEST REPORT

Dear Mr. Denton:

In accordance with 10 CFR Part 50 Appendix J, Texas Utilities Generating Company, as lead Applicant and as agent for the Owners and Applicants (Dallas Power & Light Company, Texas Electric Service Company, Texas Power & Light Company, Texas Municipal Power Agency and Brazos Electric Power Cooperative, Inc.), herewith submits the report on the Unit One Preoperational Containment Integrated Leak Rate Test (ILRT). This report is incomplete pending the resolution of one (1) open item.

As explained in the report, two (2) electrical penetrations leaked excessively during the ILRT and are undergoing further testing to determine the mechanism that caused their leakage. The results of that testing and any required repair will be the subject of a supplementary report no later than July 1, 1983.

Enclosed is the following prescribed document and the number of each:

Integrated Leak Rate Test Report - 40 copies

Respectfully submitted,

*H. C. Schmidt*  
H. C. Schmidt

HCS:tls  
Enclosure

3001