



Telegram

IE29

TO: U S NUCLEAR REGULATORY COMMISSION
799 ROOSEVELT AVENUE
GLEN ELLYN, ILLINOIS
ATTN: PALISADES PLANT SECTION CHIEF

FROM: R M KRICH, PALISADES

CC: R B DEWITT, P-26-117B, JACKSON
D J VANDEWALLE, P-24-614B, JACKSON

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER T.S. 6.9.2.A(2). ON APRIL 29, 1983, AT 2040, A SAMPLE FROM T-82D (D SAFETY INJECTION TANK) SHOWED BORON CONCENTRATION TO BE 1706 PPM WHICH IS BELOW THE T.S. LIMIT OF 1720 PPM BORON. T-82D BORON CONCENTRATION COULD NOT BE RESTORED WITHIN THE ONE HOUR LIMIT OF T.S. 3.3.2.A. AT 2201, APRIL 29, 1983, SIT T-82D WAS RESTORED TO OPERABILITY WITH A BORON CONCENTRATION OF 1734 PPM.

AT 2311, ON APRIL 29, WITH T-82D INOPERABLE DUE TO ROUTINE SAMPLING WHILE ATTEMPTING TO FURTHER INCREASE THE BORON CONCENTRATION TO ABOVE THE PLANT ADMINISTRATIVE LIMIT, AN ADDITIONAL SAFETY INJECTION TANK, T-82B, BECAME INOPERABLE DUE TO LOW LEVEL. THIS OCCURRENCE OF TWO INOPERABLE SAFETY INJECTION TANKS AT THE SAME TIME LASTED APPROXIMATELY 9 MINUTES. PREPARATIONS FOR POWER REDUCTION WERE

1201-SF (R5-69)

8305100306 830502
PDR ADDCK 05000255
PDR



Telegram

1-012682A122 05/02/83
ICS IPMMVIV MUN
01521 05-02 0200P EDT MVIW
ICS IPMMVIZ
1-009345C122 05/02/83
TLX CONSPower JKN

173 CONSUMERS POWER JACKSON MI 13:29 EDT 05-02
FMS
US NUCLEAR REGULATORY COMMISSION
PALISADES PLANT SEC CHIEF
799 ROOSEVELT AVENUE *lead,*
GLEN ELLYN IL 60137

MSG # PAL620

RCV: 82IM/3.00921 LINE: 3B
CPCO CO MI AVE

CPCO CO MI AVE
PALISADES
?? AMS ??

VDEST: PALISADES
MSGID: NRC MESSAGE
DEST: MSG CENTER MICH AVE

19509

312/ 932-2500

DATE OLD 5-2-83 4:00P
DLY ATTS



Telegram

BEGUN AND CONTINUED IN BOTH INSTANCES UNTIL T-82D CONCENTRATION AND T-82B LEVEL WERE RESTORED TO OPERABILITY PER T.S. 3.3.2. INITIAL REPORT WAS MADE VIA THE NRC HOT LINE ON APRIL 29. NOTIFICATION TO THE NRC SENIOR RESIDENT INSPECTOR WAS MADE ON MAY 2, 1983.
&

TIME: 13:22 05/02/83 EDT
CONNECT TIME : 68 SECONDS

1350 EST

1407 EST

MAY 5 1983