

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 4 1 1 8 3 8 0 5 0 5 8 3 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 At 1035 on 4/11/83, the instrumentation channel associated with Refueling Water

0 3 Storage Tank Water Level Indicator LI-4075A was declared inoperable due to a low

0 4 indication. Tech. Spec. 3.3.3.8, in part, requires the LI-4075A instrumentation

0 5 channel to be operable. Tech. Spec. 3.3.3.8 action statement requirements were met.

0 6 Health/Safety of the public was not affected. A similar occurrence was reported

0 7 in Unit 2 LER 83-006/03L-0.

0 8

0 9

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

I D 11 X 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16

17 LER/RO REPORT NUMBER 8 3

EVENT YEAR 8 3

SEQUENTIAL REPORT NO. 0 2 1

OCCURRENCE CODE 0 3

REPORT TYPE L

REVISION NO. 0

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

E 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 Z 25 Z 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 No apparent cause for this event could be determined. The instrumentation loop was

1 1 checked but no problems were noted. Following the satisfactory performance of

1 2 FNP-2-STP-205.1A (Refueling Water Storage Tank Level Loop Calibration Q2F16LT0501),

1 3 the LI-4075A instrumentation loop was declared operable at 1305 on 4/12/83.

1 4

1 5

1 6

1 7

1 8

1 9

2 0

FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32

E 28 1 0 0 29 NA A 31 Operational Event

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

Z 33 Z 34 NA

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39

0 0 0 37 Z 38 NA

PERSONNEL INJURIES NUMBER DESCRIPTION 41

0 0 0 40 NA

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43

Z 42 NA

PUBLICITY ISSUED DESCRIPTION 45

Z 44 NA

8305110260 830505 PDR ADOCK 05000364 S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III PHONE (205) 899-5156