



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 4, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-028/0 - Fire
Rated Penetrations Opened
to Implement Design Change
Packages
AECM-83/0266

Beginning on March 29, 1983, the fire rated penetrations, as listed on the attached page, were opened to implement design change packages. Hourly fire watches were established within 1 hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7.

The events have no affect on the health and safety of the public and does not constitute a threat to plant safety. The work tasks are expected to be complete by July 1, 1983. This is reported as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

J. P. McGaughy, Jr.
FOR J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: (See Next Page)

8305110291 830504
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0266

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Beginning on March 29, 1983, the following fire rated penetrations were opened to implement design change packages:

<u>PENETRATIONS</u>	<u>INCIDENT REPORT #</u>
CE-15E	83-03-126
CE-211D-02	83-03-128
CE-240D-12	83-03-128
CE-1E	83-04-03
CE-3E	83-04-03
CE-4E	83-04-03
CE-7E	83-04-03
CE-360F	83-04-11
CE-359F	83-04-11
CE-358F	83-04-11
Between Auxiliary Building elevation 139 Area 8 and Control Building elevation 148	83-04-10
AE-63E	83-4-18
<u>CABLE TRAY COVER</u>	
1AE136C	83-04-16
<u>FIRE DAMS</u>	
L084/LA40 in U-733	83-04-04
L089	83-04-09
LA8	83-04-09
L094	83-04-09
LA25	83-04-09
LA23	83-04-09
L081/LA24	83-04-13
L082/LA24	83-04-13
L085/LA24	83-04-13
L077/LA24	83-04-13
L080/LA24	83-04-13
L077/LA13	83-04-13
L079/LA13	83-04-13
L086/LA24	83-04-13
L090/LA24	83-04-13
L091/LA24	83-04-13
L092/LA13	83-04-13
L059/LA48	83-04-14
L061/LA32	83-04-14
L064/LA41	83-04-14
L065/LA32	83-04-14