



Nuclear Division  
P. O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 393-6000

April 25, 1983

1982 Annual Environmental Report  
Radiological - Volume #2


United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Ronald C. Haynes, Regional Administrator  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Reference: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334

Gentlemen:

Enclosed are two (2) copies of the 1982 Annual Environmental Report Radiological - Volume #2, for the Beaver Valley Power Station. Eighteen (18) copies have been provided to the Document Control Desk. The number of copies provided your office is in accordance with the distribution noted in Regulatory Guide 10.1.

Very truly yours,

  
J. J. Carey  
Vice President, Nuclear

Enclosure

8305110424 830425  
PDR ADOCK 05000334  
R PDR

IE25

1982 ANNUAL ENVIRONMENTAL REPORT  
RADIOLOGICAL - VOLUME #2

DUQUESNE LIGHT COMPANY  
BEAVER VALLEY POWER STATION  
AND  
SHIPPINGPORT ATOMIC POWER STATION

8305060269~

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

ABSTRACT

This report describes the Radiological Environmental Monitoring Program conducted during 1982 in the vicinity of the Beaver Valley Power Station and the Shippingport Atomic Power Station. The Radiological Environmental Program consists of on-site sampling of water and gaseous effluents and off-site monitoring of water, air, river sediments, soils, food pathway samples, and radiation levels in the vicinity of the site. This report discusses the results of this monitoring during 1982.

The environmental program outlined in the Beaver Valley Power Station Technical Specifications was followed throughout 1982. There were no radioactive liquid effluents released from the Shippingport Atomic Power Station since radioactive liquids are processed and re-cycled within the plant systems.

The results of this environmental monitoring program show that Shippingport Atomic Power Station and Beaver Valley Power Station operations have not adversely affected the surrounding environment.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

TABLE OF CONTENTS

	<u>Page</u>
Abstract-----	i
I. <u>INTRODUCTION</u> -----	1
A. Scope and Objectives of the Program	1
B. Description of the Shippingport and Beaver Valley Site	2
II. <u>RESULTS &amp; CONCLUSIONS</u> -----	6
III. <u>ENVIRONMENTAL MONITORING CONSIDERATIONS</u> -----	8
A. Environmental Quality Control Programs	8
B. Evaluation of the Quality Control (QC) Program Data	24
C. Standard Requirements and Limitations for Radiological and Other Effluents	24
D. Significant Changes and Reporting Levels	25
IV. <u>MONITORING EFFLUENTS</u> -----	27
A. Monitoring of Liquid Effluents	27
1. Effluent Treatment, Sampling, and Analytical Procedures	33
2. Results	34
B. Monitoring of Airborne Effluents	35
1. Description of Airborne Effluent Sources	35
2. Airborne Effluent Treatment and Sampling	40
3. Analytical Procedures for Sampling Airborne Effluents	44
4. Results	47
C. Solid Waste Disposal	49



DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

TABLE OF CONTENTS (Continued)

V. <u>ENVIRONMENTAL MONITORING PROGRAM</u>	<u>Page</u>
A. Environmental Radioactivity Monitoring Program	51
1. Program Description	51
2. Summary of Results	69
3. Quality Control Program	69
B. Air Monitoring	75
1. Characterization of Air and Meteorology	75
2. Air Sampling Program and Analytical Techniques	75
3. Results and Conclusions	78
C. Monitoring of Sediments and Soils	81
1. Characterization of Stream Sediments and Soils	81
2. Sampling Program and Analytical Techniques	81
3. Results and Conclusions	83
D. Monitoring of Feedcrops and Foodcrops	85
1. Characterization of Vegetation and Foodcrops	85
2. Sampling Program and Analytical Techniques	85
3. Results and Conclusions	87
E. Monitoring of Local Cow's Milk	88
1. Description - Milch Animal Locations	88
2. Sampling Program and Analytical Techniques	88
3. Results and Conclusions	92

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

TABLE OF CONTENTS (continued)

V. <u>ENVIRONMENTAL MONITORING PROGRAM</u> (continued)	<u>Page</u>
F. Environmental Radiation Monitoring	93
1. Description of Regional Background Radiation Levels and Sources	93
2. Locations & Analytical Procedures	93
3. Results and Conclusions	98
G. Monitoring of Fish	100
1. Description	100
2. Sampling Program and Analytical Techniques	100
3. Results and Conclusions	100
H. Monitoring of Surface, Drinking, and Well Waters	102
1. Description of Water Sources	102
2. Sampling Program and Analytical Techniques	102
3. Results and Conclusions	106
I. Estimates of Radiation Dose to Man	109
1. Pathways to Man - Beaver Valley Power Station	109
a. Calculational Models - Beaver Valley Power Station	109
2. Results of Calculated Radiation Dose to Man - Beaver Valley Power Station Liquid Releases	110
3. Airborne Pathway	113
4. Conclusions - Beaver Valley Power Station	113
5. Dose Pathways to Man - Shippingport Atomic Power Station	115
a. Calculational Model - Shippingport Atomic Power Station	115
6. Results and Conclusions - Shippingport Atomic Power Station	116

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

LIST OF FIGURES

<u>Figure No.</u>		<u>Page</u>
1 0	View of the Shippingport and Beaver Valley Site	3
1.1	Geographical Map - 40 Mile Radius	4
4.1	Liquid Discharge Points to Ohio River	28
4.2	Water Flow Schematic - Shippingport Atomic Power Station	29
4.3	Water Flow Schematic - Beaver Valley Power Station	30
4.4	Liquid Radwaste Systems - Shippingport Atomic Power Station	31
4.5	Liquid Radwaste Systems - Beaver Valley Power Station	32
4.6	Gaseous Waste Processing - Shippingport Atomic Power Station	37
4.7	Gaseous Waste Processing - Beaver Valley Power Station	39
4.8	Gaseous Release Points - Shippingport Atomic Power Station and Beaver Valley Power Station	41
4.9	Solid Waste Disposal Diagram	50
5.B.1	Environmental Monitoring Locations - Air Sampling Stations	77
5.B.2	Concentrations of Gross Beta in Air Particulates	79
5.C.1	Environmental Monitoring Locations - Sediments	82
5.D.1	Environmental Monitoring Locations - Feedcrop and Foodcrop	86
5.E.1	Dairy Farm Locations (August - September 1982 Survey)	90
5.E.2	Environmental Monitoring Locations - Milk	91
5.F.1	Environmental Monitoring Locations - Radiation Monitoring	94
5.F.2	Environmental Monitoring Locations - Radiation Monitoring	95
5.F.3	Environmental Monitoring Locations - Radiation Monitoring	96
5.F.4	Environmental Monitoring Locations - Radiation Monitoring	97
5.G.1	Environmental Monitoring Locations - Fish	101
5.H.1	Surface Water and Wells - Locations	105

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

LIST OF TABLES

<u>Table Number</u>		<u>Page</u>
III.1	Quality Control Data - TLD Comparisons	9
III.2	Quality Control Data - Water Split Samples	10
III.3	Quality Control Data - Split Samples - Miscellaneous	12
III.4	Quality Control Data - Spiked Samples	16
III.5	Quality Control Data - Spiked Samples	17
III.6	Quality Control Data - Air Particulates and I-131	18
III.7	Quality Control Data - Milk and Water	22
III.8	Anomalous Measurements During 1982	26
IV.A.1	Effluent Treatment, Sampling and Analytical Procedures Shippingport Atomic Power Station	33
IV.A.2	Effluent Treatment, Sampling and Analytical Procedures Beaver Valley Power Station	33
IV.A.3	Results - Liquid Effluents - Shippingport Atomic Power Station	34
IV.A.4	Results - Liquid Effluents - Beaver Valley Power Station	34
V.A.1	Environmental Monitoring Program Summary	52
V.A.2	Environmental Monitoring Program Results (1982)	57
V.A.3	Pre-Operational Monitoring Program Results (1974-1975)	70
V.A.4	Typical LLDs for Gamma Spectrometry - DLC Contractor	74
V.I.1	Radiation Dose to Man - Beaver Valley Power Station - Liquid Releases	111
V.I.2	Radiation Dose to Man - Beaver Valley Power Station - Airborne Releases	114

## SECTION I

## DUQUESNE LIGHT COMPANY 1982 Annual Radiological Environmental Report

### I. INTRODUCTION

The 1982 Annual Radiological Environmental Report for the Beaver Valley Power Station and the Shippingport Atomic Power Station summarizes the radiological environmental program conducted by the Duquesne Light Company in 1982.

The Duquesne Light Company operates the Shippingport Atomic Power Station for the United States Department of Energy and the Beaver Valley Power Station pressurized water reactor - Unit No. 1 as part of the Central Area Power Coordination group. Beaver Valley No. 2 Unit was under construction in 1982 and is scheduled to start-up in 1986.

The Shippingport Atomic Power Station operated throughout 1982, until the final shutdown date of October 1st 1982, with the gross electrical generation during the year of 302,730 megawatthours. The plant has been in operation utilizing a light water breeder reactor (LWBR) core since September 21, 1977.

The Shippingport Atomic Power Station was the first large-scale central station nuclear reactor in the United States. Since initial power generation in December 1957, operation of the pressurized water reactor at the Shippingport plant has supplied power to the Duquesne Light Company system in addition to providing technology which has served as a basis for the development of pressurized water reactors in the nuclear industry.

The highest average daily output generated at the Beaver Valley Power Station during the year was 827 megawatts net in November, 1982. The total gross electrical generation during the year was 2,862,200. megawatt-hours.

#### A. Scope and Objectives of the Program

The environmental program consists of effluent and environmental monitoring for radioactivity. Liquid and gaseous effluents from the Beaver Valley Power Station and gaseous effluents from the Shippingport Atomic Power Station were collected, processed, sampled, and analyzed to ensure conformance with the applicable regulations and permits prior to their release to the environment. Environmental sampling and analyses included air, water, milk, soil, vegetation, river sediments, fish, and ambient radiation levels in areas surrounding both plants.

I. INTRODUCTIONB. Description of the Shippingport and Beaver Valley Site

The Shippingport Atomic Power Station and the Beaver Valley Power Station are located on the south bank of the Ohio River in the Borough of Shippingport, Beaver County, Pennsylvania, on a 486.8 acre tract of land which is owned by the Duquesne Light Company. Figure 1.0 is an artist's view of both stations. The site is approximately one mile from Midland, Pennsylvania; 5 miles from East Liverpool, Ohio; and 25 miles from Pittsburgh, Pennsylvania. Figure 1.1 shows the site location in relation to the principal population centers. Population density in the immediate vicinity of the site is relatively low. There are no residents within a 1/2 mile radius of either plant. The population within a 5 mile radius of the plant is approximately 18,000 and the only area within that radius of concentrated population is the Borough of Midland, Pennsylvania, with a population of approximately 4,300.

The site lies in a valley along the Ohio River. It extends from the river (elevation 665 feet above sea level) to a ridge along the border south of the Shippingport and Beaver Valley Power Stations at an elevation of 1,160 feet. Plant ground level at both stations is approximately 735 feet above sea level.


The two (2) stations are situated on the Ohio River at river mile 34.8, at a location on the New Cumberland Pool that is 3.3 river miles downstream from Montgomery Lock and Dam, and 19.4 miles upstream from New Cumberland Lock and Dam. The Pennsylvania-Ohio-West Virginia border is located 5.2 river miles downstream from the site. The river flow is regulated by a series of dams and reservoirs on the Beaver, Allegheny, Monongahela and Ohio Rivers and their tributaries. Flow ranges from a minimum of 5000 cubic feet per second (CFS) to a maximum of 100,000 CFS. The mean annual flow is approximately 25,000 CFS.

Water temperature of the Ohio River varies from 32°F to 84°F, the minimum temperatures occur in January and/or February and maximum temperatures in July and August. Water quality in the Ohio River at the site location is affected primarily by the water quality of the Allegheny, Monongahela, and Beaver rivers.

The climate of the area may be classified as humid continental. Annual precipitation is approximately 33 inches, typical yearly temperatures vary from approximately -3°F to 95°F with an annual average temperature of 52.8°F. The predominant wind direction is typically from the southwest in summer and from the northwest in winter.




FIGURE 1.0



VIEW OF THE BEAVER VALLEY POWER STATION AND THE SHIPPINGPORT ATOMIC POWER STATION

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report





## SECTION I

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental ReportI. INTRODUCTIONB. Description of the Shippingport and Beaver Valley Site  
(continued)

The design ratings and basic features of the Beaver Valley Power Station and the Shippingport Atomic Power Station are tabulated below:

	<u>Beaver Valley</u>	<u>Shippingport</u>
Thermal & Elec. Rating - 2660 MW 852 MW MW-Each Reactor		236.6 MW 72 MW
Type of Reactor	PWR	PWR*
Number of Reactor Coolant Loops	3	4
Number of Steam Generators and Type	3 - Vertical	4 - Horizontal
Steam Used by Main Turbine	Saturated	Saturated

Both stations utilize two (2) separate systems (primary and secondary) for transferring heat from the source (the reactor) to the receiving component (turbine-generator). Because the two systems are isolated from each other, primary and secondary waters do not mix; therefore, radioactivity in the primary system water is normally isolated from the secondary system. Reactor coolant in the primary system is pumped through the reactor core and steam generators by means of reactor coolant pumps. Heat is given up from the primary system to the secondary system in the steam generators, where steam is formed and delivered to the main unit turbine, which drives the electrical generator. The steam is condensed after passing through the turbine, and returned to the steam generators to begin another steam/water cycle.

NOTE: MW - megawatts thermal  
MW - megawatts electrical

---

\*Light Water Breeder Core

II. RESULTS AND CONCLUSIONS

Plant operations at both the Beaver Valley Power Station and the Shippingport Atomic Power Station had no adverse effects on the environment as a result of activities at either of the stations during 1982. Comparisons of pre-operational data with operational data indicates the ranges of values are in good agreement for both periods of time.

The Beaver Valley Power Station operated throughout 1982, and the Shippingport Atomic Power Station operated throughout 1982 until the final shutdown date of October 1, 1982. During the year, the radioactive releases from both stations were below the limits of 10 CFR Part 50, Appendix I and applicable permits for each station. The releases at Beaver Valley Power Station did not exceed the limiting conditions identified in the Beaver Valley Power Station Operating License Technical Specifications.

The environmental program for 1982 was the same as in 1981 except for several changes in dairy locations which were revised as required by the Beaver Valley Technical Specifications.

The results of the 1982 Radiological Environmental Monitoring Program are consistent with those of previous years. The only radioactivity above normal ambient levels in the environs other than world-wide fallout from Nuclear weapons tests is noted in Table III.8. This radioactivity was only detected near the Beaver Valley Power Station discharge and resulted in negligible exposure to members of the public. A summary of the 1982 operational environmental data (ranges and means) for each sampling media is found in Table V.A.2. A summary of preoperational (1974 - 1975) environmental data is found in Table V.A.3.

The Beaver Valley Power Station Technical Specifications require sampling of four (4) dairies which have the highest calculated milk pathway potential. These four dairies are determined from calculations based on the meteorological data and the latest milch animal survey. However, these dairies are frequently small, consisting of as few as one cow or goat. The availability of milk from single cow dairies and revisions due to updated calculations and surveys result in sampling of several additional dairies during the year in different sampling periods.

II. RESULTS AND CONCLUSIONS (continued)

In order to provide continuity in the sampling/analyses program, the Environmental Monitoring Program includes three larger dairies and in 1982 a fourth large dairy was added to the program. This dairy is 10.3 miles south-southwest from the Beaver Valley Power Station and is considered to be a control location. Samples from each of these dairies are obtained each month in addition to the four dairies required by the Environmental Technical Specifications. During some sampling periods, one or all of the additional dairies could be among the four required dairies. Thus, there will be at least five and possibly as many as eight dairies sampled in any sampling period. The collection periods associated with each of the locations are provided in the detailed summary of the milk monitoring program of this report (Section V-E).

Examination of effluents from the Shippingport Atomic Power Station and the Beaver Valley Power Station and environmental media demonstrated compliance with regulations and Station Technical Specifications. There were two (2) surface water tritium values during the year which exceeded the reporting levels established in the BVPS technical specifications which were based on preoperational levels. These values were well below the limits of 10CFR20 for discharge from an operating plant. Shippingport Atomic Power Station did not release any liquid radioactive effluents during 1982.

III. ENVIRONMENTAL MONITORING CONSIDERATIONSA. Environmental Quality Control Programs

The Quality Control (QC) Program used for the Beaver Valley - Shippingport Environmental Radioactivity Monitoring Program consisted of seven (7) elements. It should be noted that the comparisons made were at very low levels of radioactivity and consequently, the activities at these levels are difficult to measure. However, acceptable correlation was achieved in most instances as outlined in the discussions and tables which follow.

1. Radiation Monitoring (Duquesne Light Company (DLC) Contractor Laboratory - DLC QC Laboratory - Independent Laboratory)

An independent program of external radiation monitoring was conducted by the QC Laboratory using lithium fluoride TLDs sharing the same location as the DLC Contractor Laboratory TLDs and Independent Laboratory TLDs. Summary data of the QC Laboratory program is provided in Table III.1.

Duplicate contractor TLD, QC TLD, Annual TLD, and Independent Lab TLD and continuous integrating monitoring by a Pressurized Ion Chamber (PIC) show generally good agreement and demonstrate acceptable performance by the DLC Contractor Laboratory. The arithmetic mean of each laboratory agrees within  $\pm 10\%$  of the arithmetic mean of the three laboratories. This is well within the precision of a typical TLD system.

2. Split Sample Program (DLC Contractor Laboratory - DLC QC Laboratory)

Samples of surface (river) water and drinking water were routinely split and analyzed by the DLC Contractor Laboratory and the DLC QC Laboratory. In addition, samples of other media, such as milk, soil, sediment and feedcrop were also split with the DLC QC Laboratory (a laboratory of the Department of Energy).

A summary of results of split water samples is provided in Table III.2. A summary of milk, sediment and feed/food crop split samples is provided in Table III.3. Some variation is expected due to small variations in duplicate samples, variations in analytical procedures, and in calibration, source type, etc.

Because of the overall uniformity of comparable results, it is concluded that the two laboratories are consistent and in agreement.

TABLE III.1  
QUALITY CONTROL RESULTS  
TLD MONITORING  
mR/Day

1st QUARTER						2nd QUARTER				
Location No.	DLC Contractor (CaSO <sub>4</sub> :Dy)	DLC QC Lab (LiF)	Independent Lab #3 (CaSO <sub>4</sub> :Tm)	PDER (2)	DLC PIC (3)	DLC Contractor (CaSO <sub>4</sub> :Dy)	DLC QC Lab (LiF)	Independent Lab #3 (CaSO <sub>4</sub> :Tm)	PDER (2)	DLC PIC (3)
10	0.16	0.21	0.18	0.27	0.23 <sup>(1)</sup>	0.15	0.18	0.21	0.26	0.23 <sup>(1)</sup>
13	0.17	0.22	0.18	0.27		0.17	0.20	0.20	0.26	
14	0.17	0.23	0.19			0.16	0.17	0.20		
15	0.13	0.15	0.13	0.21		0.13	0.15	0.16	0.19	
27	0.17	0.21	0.19			0.16	0.16	0.18		
28	0.18	0.23	0.20			0.17	0.21	0.20		
29	0.21	0.26	0.20			0.19	0.22	0.20		
32	0.19	0.24	0.21	0.23	0.29	0.18	0.20	0.23	0.22	0.27
45	0.19	0.23	0.20	0.27	0.23 <sup>(1)</sup>	0.18	0.21	0.21	0.28	0.24 <sup>(1)</sup>
46	0.16	0.19	0.17	0.22	0.21 <sup>(1)</sup>	0.15	0.17	0.19	0.25	0.18 <sup>(1)</sup>
47	0.19	0.22	0.19			0.18	0.20	0.23		
48	0.18	0.20	0.19			0.17	0.19	0.18		
51	0.20	0.22	0.20	0.27		0.17	0.19	0.20	0.25	

3rd QUARTER					4th QUARTER					
Location No.	DLC Contractor (CaSO <sub>4</sub> :Dy)	DLC QC Lab (LiF)	Independent Lab #3 (CaSO <sub>4</sub> :Tm)	PDER (2)	DLC PIC (3)	DLC Contractor (CaSO <sub>4</sub> :Dy)	DLC QC Lab (LiF)	Independent Lab #3 (CaSO <sub>4</sub> :Tm)	PDER (2)	DLC PIC (3)
10	0.17	0.18	0.23	0.23	0.23 <sup>(1)</sup>	0.17	0.20	0.19	0.24	0.23 <sup>(1)</sup>
13	0.16	0.17	0.20	0.22		0.17	0.21	0.20	0.26	
14	0.17	0.18	0.22			0.17	0.21	0.20		
15	0.14	0.13	0.18	0.20		0.14	0.16	0.17	0.20	
27	0.17	0.17	0.21			0.17	0.19	0.22		
28	0.18	0.19	0.23			0.18	0.22	0.23		
29	0.20	0.22	0.24			0.20	0.26	0.24		
32	0.18	0.19	0.19	0.19	0.27	0.19	0.23	0.23	0.22	0.26
45	0.19	0.21	0.23	0.25	0.23 <sup>(1)</sup>	0.19	0.22	0.23	0.26	0.24 <sup>(1)</sup>
46	0.15	0.15	0.20	0.22	0.19 <sup>(1)</sup>	0.16	0.17	0.18	0.24	0.20 <sup>(1)</sup>
47	0.18	0.19	0.21			0.19	0.23	0.21		
48	0.16	0.17	0.21			0.16	0.20	0.19		
51	0.17	0.18	0.22	0.26		0.18	0.19	0.21	0.28	

(1) PIC Reading at Location 10 taken in DLC Substation in Shippingport Boro, Location 45 taken at Kennedy's Corners, Location 46 taken at Industry Tire Shop.

(2) NRC results from Pennsylvania Department of Environmental Resources.

(3) In this consolidated environmental program the pressurized ion chamber (PIC) continuous monitor readings tend to be slightly higher than the TLD readings due to the differences in the inherent physics of each system. No compensatory measures have been taken to make both systems agree exactly because both systems were installed to monitor relative radiation levels rather than absolute levels. Each system provides a reasonably accurate measure of the absolute radiation levels.

TABLE III.2  
QUALITY CONTROL RESULTS  
SPLIT SAMPLE ANALYSIS RESULTSComparison of Contractor and DLC-QC Labs

<u>Media</u>	<u>Analysis</u>	<u>Sampling Period</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC - QC Lab (1)</u>	<u>Units</u>
Surface Water	Gross Alpha	January	$\leq 1.9$	$2.4 \pm 2.1$	pCi/l
		April	$\leq 0.72$	$\leq 1.1$	pCi/l
		July	$\leq 0.97$	$\leq 0.6$	pCi/l
		October	$\leq 0.89$	$\leq 0.92$	pCi/l
Surface Water	Gross Beta	January	$6.5 \pm 1.3$	$6.3 \pm 2.2$	pCi/l
		April	$4.0 \pm 1.2$	$3.6 \pm 1.9$	pCi/l
		July	$6.1 \pm 1.3$	$3.7 \pm 1.5$	pCi/l
		October	$4.2 \pm 1.4$	$5.6 \pm 2.2$	pCi/l
Surface Water	Co-60	January	$\leq 3.0$	$\leq 4.5$	pCi/l
		April	$\leq 3.0$	$\leq 3.9$	pCi/l
		July	$\leq 2.0$	$\leq 4.0$	pCi/l
		October	$\leq 2.0$	$\leq 3.8$	pCi/l
Surface Water	Cs-134	January	$\leq 3.0$	$\leq 5.0$	pCi/l
		April	$\leq 3.0$	$\leq 4.6$	pCi/l
		July	$\leq 2.0$	$\leq 4.8$	pCi/l
		October	$\leq 2.0$	$\leq 4.7$	pCi/l
Surface Water	Cs-137	January	$\leq 3.0$	$\leq 5.0$	pCi/l
		April	$\leq 3.0$	$\leq 4.3$	pCi/l
		July	$\leq 2.0$	$\leq 5.0$	pCi/l
		October	$\leq 2.0$	$\leq 5.0$	pCi/l
Surface Water	Tritium	1st Quarter Composite	$790 \pm 70$	$560 \pm 210$	pCi/l
		3rd Quarter Composite	$140 \pm 100$	$\leq 196$	pCi/l
Surface Water	Sr-89	2nd Quarter Composite	$\leq 1.6$	$\leq 0.36$	pCi/l
		4th Quarter Composite	$\leq 1.9$	$\leq 0.6$	pCi/l
Surface Water	Sr-90	2nd Quarter Composite	$\leq 0.17$	$0.36 \pm 0.28$	pCi/l
		4th Quarter Composite	$\leq 0.38$	$\leq 0.4$	pCi/l
Surface Water	Co-60 (high sensitivity analysis)	2nd Quarter Composite	$\leq 0.6$	$\leq 3.9$	pCi/l
		4th Quarter Composite	$\leq 0.9$	$\leq 3.6$	pCi/l

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

TABLE III.2 (continued)  
QUALITY CONTROL RESULTS  
SPLIT SAMPLE ANALYSIS RESULTSComparison of Contractor and DLC-QC Labs

<u>Media</u>	<u>Analysis</u>	<u>Sampling Period</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC-QC Lab (1)</u>	<u>Units</u>
Drinking Water	Cs-137	February	$\leq 2.0$	$\leq 4.5$	pCi/l
		May	$\leq 2.0$	$\leq 4.7$	pCi/l
		August	$\leq 3.0$	$\leq 5.1$	pCi/l
		November	$\leq 2.0$	$\leq 4.9$	pCi/l
Drinking Water	Cs-134	February	$\leq 3.0$	$\leq 4.3$	pCi/l
		May	$\leq 2.0$	$\leq 4.5$	pCi/l
		August	$\leq 3.0$	$\leq 4.9$	pCi/l
		November	$\leq 2.0$	$\leq 5.0$	pCi/l
Drinking Water	Co-60	February	$\leq 2.0$	$\leq 3.6$	pCi/l
		May	$\leq 2.0$	$\leq 3.9$	pCi/l
		August	$\leq 3.0$	$\leq 4.2$	pCi/l
		November	$\leq 2.0$	$\leq 4.6$	pCi/l
Drinking Water	Gross Alpha	March	$\leq 0.60$	$\leq 1.3$	pCi/l
		June	$\leq 0.52$	$\leq 1.6$	pCi/l
		August	$\leq 0.36$	$\leq 1.5$	pCi/l
		November	$\leq 0.42$	$\leq 1.4$	pCi/l
Drinking Water	Gross Beta	March	$4.5 \pm 1.1$	$5.6 \pm 1.9$	pCi/l
		June	$3.0 \pm 1.1$	$4.2 \pm 1.8$	pCi/l
		August	$4.6 \pm 1.1$	$4.9 \pm 2.1$	pCi/l
		November	$3.5 \pm 1.3$	$3.4 \pm 1.6$	pCi/l
Drinking Water	Tritium	2nd Quarter	$\leq 70$	$290 \pm 220$	pCi/l
		4th Quarter	$\leq 70$	$\leq 190$	pCi/l

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

TABLE III.3  
QUALITY CONTROL RESULTS  
SPLIT SAMPLE ANALYSIS RESULTSComparison of Contractor and DLC-QC Labs

<u>Media</u>	<u>Analysis</u>	<u>Sampling Period</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC-QC Lab (1)</u>	<u>Units</u>
Milk (Location 25)	I-131	3-16-82	$\leq 0.11$	$\leq 1.2$	pCi/l
	Sr-89	3-16-82	$\leq 2.0$	$\leq 0.93$	pCi/l
	Sr-90	3-16-82	$1.2 \pm 0.5$	$3.1 \pm 0.8$	pCi/l
	Cs-134	3-16-82	$\leq 2.0$	$\leq 4.7$	pCi/l
	Cs-137	3-16-82	$\leq 2.0$	$5.1 \pm 4.4$	pCi/l
	Co-60	3-16-82	$\leq 2.0$	$\leq 3.9$	pCi/l
	K-40	3-16-82	$1230 \pm 120$	- -	pCi/l
Milk (Location 25)	I-131	6-16-82	$\leq 0.14$	$\leq 0.22$	pCi/l
	K-40	6-16-82	$1030 \pm 120$	- -	pCi/l
	Cs-134	6-16-82	$\leq 3.0$	$\leq 4.6$	pCi/l
	Cs-137	6-16-82	$\leq 3.0$	$\leq 4.7$	pCi/l
	Co-60	6-16-82	$\leq 3.0$	$\leq 4.0$	pCi/l
Feed (Location 25)	Be-7	6-14-82	$2.1 \pm 0.46$	- -	pCi/gm Dry
	K-40	6-14-82	$19.6 \pm 2$	- -	pCi/gm Dry
	Cs-134	6-14-82	$\leq 0.02$	$\leq 0.1$	pCi/gm Dry
	Cs-137	6-14-82	$\leq 0.03$	$\leq 0.1$	pCi/gm Dry
	Co-60	6-14-82	$\leq 0.02$	$\leq 0.1$	pCi/gm Dry
Food (Cabbage) (Location 10)	I-131	9-1-82	$\leq 0.007$	$\leq 0.06$	pCi/gm Dry
	K-40	9-1-82	$1.13 \pm 0.14$	- -	pCi/gm Dry
	Co-60	9-1-82	$\leq 0.006$	$\leq 0.04$	pCi/gm Dry
	Cs-134	9-1-82	$\leq 0.007$	$\leq 0.04$	pCi/gm Dry
	Cs-137	9-1-82	$\leq 0.007$	$\leq 0.04$	pCi/gm Dry
Food (Lettuce) (Location 10)	I-131	9-1-82	$\leq 0.004$	$\leq 0.06$	pCi/gm Wet
	Be-7	9-1-82	$0.30 \pm 0.21$	- -	pCi/gm Wet
	K-40	9-1-82	$2.69 \pm 0.54$	- -	pCi/gm Wet
	Co-60	9-1-82	$\leq 0.01$	$\leq 0.07$	pCi/gm Wet
	Cs-134	9-1-82	$\leq 0.01$	$\leq 0.07$	pCi/gm Wet
	Cs-137	9-1-82	$\leq 0.01$	$\leq 0.06$	pCi/gm Wet
Feed (Location 25)	Sr-90	9-20-82	$0.06 \pm 0.01$	$0.19 \pm 0.12$	pCi/gm Dry

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

- - Analyses not performed nor required.



TABLE III.3  
QUALITY CONTROL RESULTS  
SPLIT SAMPLE ANALYSIS RESULTSComparison of Contractor and DLC-QC Labs

<u>Media</u>	<u>Analysis</u>	<u>Sampling Period</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC-QC Lab (1)</u>	<u>Units</u>
Milk (Location 25)	Sr-89	9-20-82	$\leq 1.2$	*	pCi/l
	Sr-90	9-20-82	$3.2 \pm 0.7$	*	pCi/l
	Co-60	9-20-82	$\leq 3.0$	$\leq 4.2$	pCi/l
	Cs-134	9-20-82	$\leq 3.0$	$\leq 4.6$	pCi/l
	Cs-137	9-20-82	$\leq 3.0$	$\leq 4.7$	pCi/l
	I-131	9-20-82	$\leq 0.11$	$\leq 0.6$	pCi/l
	K-40	9-20-82	$1040 \pm 120$	- -	pCi/l
Sediment (Location 3)	Gr-A	10-21-82	$11 \pm 8$	$15 \pm 6$	pCi/gm Dry
	Gr-B	10-21-82	$51 \pm 3$	$29 \pm 7$	pCi/gm Dry
	U-235	10-21-82	$\leq 0.01$	$\leq 0.08$	pCi/gm Dry
	U-234	10-21-82	$0.31 \pm 0.16$	$0.7 \pm 0.2$	pCi/gm Dry
	U-238	10-21-82	$0.18 \pm 0.01$	$0.31 \pm 0.13$	pCi/gm Dry
	Sr-89	10-21-82	$\leq 0.2$	$\leq 0.4$	pCi/gm Dry
	Sr-90	10-21-82	$\leq 0.05$	$\leq 0.08$	pCi/gm Dry
	K-40	10-21-82	$13 \pm 1.3$	- -	pCi/gm Dry
	Co-60	10-21-82	$0.08 \pm 0.03$	$0.20 \pm 0.10$	pCi/gm Dry
	Cs-134	10-21-82	$\leq 0.02$	$\leq 0.07$	pCi/gm Dry
	Cs-137	10-21-82	$0.35 \pm 0.05$	$0.16 \pm 0.12$	pCi/gm Dry
	Ra-226	10-21-82	$2.17 \pm 0.73$	- -	pCi/gm Dry
	Th-228	10-21-82	$1.43 \pm 0.14$	- -	pCi/gm Dry
Milk (Location 25)	I-131	12-21-82	$\leq 0.16$	$\leq 7$	pCi/l
	K-40	12-21-82	$888 \pm 124$	- -	pCi/l
	Cs-134	12-21-82	$\leq 3.0$	$\leq 5.0$	pCi/l
	Cs-137	12-21-82	$\leq 3.0$	$\leq 5.2$	pCi/l
	Co-60	12-21-82	$\leq 3.0$	$\leq 4.4$	pCi/l

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

- - Analysis not performed nor required.

\* Not analyzed due to late arrival of sample.

A. Environmental Quality Control Programs (continued)3. DLC QC Laboratory Program

Spiked samples prepared by DLC QC Laboratory were routinely submitted to the Contractor Laboratory for analysis. Tables III.4 (water) and III.5 (milk) provide data from this portion of the QC Program. The overall results demonstrate that the contractor performed acceptably in the program.

4. Comparisons of Similar Samples (DLC Contractor Laboratory - DLC QC Laboratory)

Duplicate air particulate and charcoal filters (radioiodine) samples were collected at Location #30 and compared during the year on a weekly basis. Comparison of particulate and charcoal samples alternated from week to week. Duplicate monthly air particulate filters, composited from the weekly air particulate filters, were analyzed 6 months out of the year for gamma activity. Duplicate quarterly air particulate filters, composited from the weekly air particulate filters, were analyzed for Sr-89 and Sr-90 activity for the second and third quarters of the year. Table III.6 provides data for this portion of the QC program. The results show generally good agreement between the laboratories and demonstrate that the contractor performed acceptably in the program.

5. Contractor Internal QC Program

The Contractor Laboratory maintained its own QC Program which included participation in the Environmental Protection Agency - Environmental Monitoring Safety Laboratory (EPA - EMSL) Interlaboratory Cross Check Program. This cross check program indicated that the Contractor results were in agreement with EPS EMSL. DLC also audited the Contractor Laboratory and determined that internal QC practices were in effect and that procedures and laboratory analytical techniques conformed to approved DLC procedures.

A. Environmental Quality Control Programs (continued)6. Special QC Program (DLC Contractor Laboratory -  
Independent Laboratory - DLC QC Laboratory)

Milk and water samples were prepared quarterly by an Independent Laboratory. This included low level spiking of specified nuclides. The prepared samples were split three ways and analyzed by the DLC-QC Laboratory and Independent Laboratory as well as the Contractor Laboratory. A summary of results of this portion of the QC program is provided in Table III.7. The results show generally good agreement between the laboratories and demonstrate that the contractor performed acceptably in the program.

TABLE III.4  
QUALITY CONTROL RESULTS  
SPIKE SAMPLE ANALYSIS RESULTS

<u>Sample Date</u>	<u>Ident. No.</u>	<u>Sample Type and Analysis</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC - QC Lab (1)</u>	<u>Units</u>
3-30-82	53-46	Water: Sr-89	17 ± 4	18 ± 4	pCi/l
		Sr-90	12 ± 1	11 ± 2	pCi/l
5-7-82	53-47	Water: I-131	7.8 ± 0.6	9.3 ± 0.8	pCi/l
		Mn-54	45.6 ± 5.0	41 ± 16	pCi/l
		Co-60	40.6 ± 5.1	47 ± 16	pCi/l
		Cs-137	28.2 ± 4.7	31 ± 16	pCi/l
		Co-57	23.7 ± 3.3	28 ± 10	pCi/l
6-10-82	53-48	Water: Gross Alpha	1.6 ± 0.6*	12 ± 2	pCi/l
		Gross Beta	9.4 ± 1.1	14 ± 2	pCi/l
9-22-82	53-49	Water: Sr-89	22 ± 3	18 ± 2	pCi/l
		Sr-90	12 ± 1	12 ± 2	pCi/l
		Cr-51	100 ± 50	113 ± 24	pCi/l
		Ru-106	92.1 ± 9.2	110 ± 18	pCi/l
		Cs-137	29.8 ± 3	26 ± 8	pCi/l
10-30-82	53-50	Water: I-131	lost	3.6 ± 3.5	pCi/l
		Fe-59	26.1 ± 10	18 ± 12	pCi/l
		Co-60	26.6 ± 5.8	30 ± 7	pCi/l
		Ru-106	187 ± 49	250 ± 65	pCi/l
		Ce-144	56.3 ± 24.6	60 ± 52	pCi/l
		H-3	560 ± 90	720 ± 330	pCi/l
1-17-83	53-51	Water: Gross Alpha	7.7 ± 3.4*	21 ± 8	pCi/l
		Gross Beta	15 ± 2.0	20 ± 4	pCi/l
1-17-83	53-48a	Water: I-131	3.8 ± 0.4	4.1 ± 0.2	pCi/l
	b	Water: I-131	8.2 ± 0.5	8.6 ± 1.1	pCi/l
	c	Water: I-131	14 ± 1	16 ± 2	pCi/l

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

\* Poor agreement between the Contractor Lab and the Q.C. Lab. The reason is still under investigation at the time of this report. The Contractor Lab and the EPA intercomparison Gross Alpha results were within acceptable agreement.

TABLE III.5  
QUALITY CONTROL RESULTS  
SPIKE SAMPLE ANALYSIS

<u>Sample Date</u>	<u>Ident. No.</u>	<u>Sample Type and Analysis</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC - QC Lab (1)</u>	<u>Units</u>
2-22-82	52-53	Milk: Sr-89	6.5 ± 2.8	7.5 ± 2.7	pCi/l
		Sr-90	15 ± 1.0	14 ± 2.2	pCi/l
		I-131	8.0 ± 0.4	7.0 ± 1.2	pCi/l
		K-40	1030 ± 100	- -	pCi/l
		Cs-137	24.1 ± 5.6	29 ± 8	pCi/l
6-8-82	52-54	Milk: I-131	3.6 ± 0.2	4.1 ± 1.1	pCi/l
		K-40	1170 ± 120	- -	pCi/l
		Co-60	54.8 ± 7.1	50 ± 7	pCi/l
		Cs-137	33.4 ± 6.6	33 ± 8	pCi/l
		Co-57	48.0 ± 5.9	40 ± 7	pCi/l
9-27-82	52-55	Milk: Sr-89	13 ± 1	20 *	pCi/l
		Sr-90	12 ± 1	12.5 *	pCi/l
		I-131	1.9 ± 0.2	3.2 ± 0.7	pCi/l
		K-40	953 ± 95	- -	pCi/l
		Cr-51	181 ± 18	236 ± 20	pCi/l
		Cs-137	25.3 ± 4.0	33 ± 7	pCi/l
10-30-82	52-56	Ce-144	99.8 ± 25	120 ± 45	pCi/l
		Milk: I-131	2.2 ± 0.2	4.1 ± 3.2	pCi/l
		K-40	1310 ± 130	- -	pCi/l
		Cr-51	91.7 ± 36.1	69 ± 44	pCi/l
		Fe-59	13.3 ± 10	21 ± 12	pCi/l
		Co-60	28.1 ± 5.3	25 ± 9	pCi/l
		Cs-137	20.3 ± 5.4	15 ± 8	pCi/l

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

- - Analyses not performed nor required.

\* QC analysis not available, since the QC laboratory inadvertently disposed of the sample prior to analysis. Teledyne result compared acceptably to the known value using EPA acceptance criteria and EPA uncertainty for a single measurement.

TABLE III.6  
QUALITY CONTROL RESULTS  
AIR PARTICULATES AND CHARCOAL FILTER: COMPARABLE SAMPLES

<u>Air Particulates</u> pCi/Cu. Meter (Beta)			<u>Air Iodine</u> pCi/Cu. Meter		
<u>Sample Date</u>	<u>DLC Contractor</u> <u>Lab (1)</u>	<u>DLC - QC</u> <u>Lab (1)</u>	<u>Sample Date</u>	<u>DLC Contractor</u> <u>Lab (1)</u>	<u>DLC - QC</u> <u>Lab (1)</u>
1/4/82 to 1/12/82	0.038 ± 0.003	0.042 ± 0.003	1/12/82 to 1/13/82	≤ 0.01	≤ 0.015
1/18/82 to 1/25/82	0.042 ± 0.004	0.043 ± 0.003	1/25/82 to 2/1/82	≤ 0.01	≤ 0.021
2/1/82 to 2/8/82	0.034 ± 0.004	0.039 ± 0.003	2/8/82 to 2/16/82	≤ 0.008	≤ 0.017
2/16/82 to 2/22/82	0.020 ± 0.003	0.025 ± 0.003	2/22/82 to 3/1/82	≤ 0.009	≤ 0.020
3/1/82 to 3/8/82	0.029 ± 0.004	0.034 ± 0.003	3/8/82 to 3/15/82	≤ 0.01	≤ 0.022
3/15/82 to 3/22/82	0.012 ± 0.003	0.013 ± 0.002	3/22/82 to 3/29/82	≤ 0.009	≤ 0.022
3/29/82 4/5/82	0.026 ± 0.003	0.027 ± 0.002	4/5/82 to 4/12/82	≤ 0.009	≤ 0.020
4/12/82 to 4/19/82	0.023 ± 0.003	0.030 ± 0.003	4/19/82 to 4/26/82	≤ 0.01	≤ 0.022
4/26/82 to 5/3/82	0.026 ± 0.003	0.029 ± 0.002	5/3/82 to 5/10/82	≤ 0.009	≤ 0.010
5/10/82 to 5/17/82	0.028 ± 0.003	0.038 ± 0.003	5/17/82 to 5/24/82	≤ 0.01	≤ 0.015
5/24/82 to 6/1/82	0.020 ± 0.003	0.027 ± 0.002	6/1/82 to 6/7/82	≤ 0.01	≤ 0.028
6/7/82 to 6/14/82	0.020 ± 0.003	0.028 ± 0.002	6/14/82 to 6/21/82	≤ 0.009	≤ 0.028
6/21/82 to 6/28/82	0.027 ± 0.003	0.029 ± 0.002	6/28/82 to 7/6/82	≤ 0.009	≤ 0.016
7/6/82 to 7/12/82	0.025 ± 0.004	0.025 ± 0.003	7/12/82 to 7/19/82	≤ 0.01	≤ 0.010
7/19/82 to 7/26/82	0.026 ± 0.003	0.029 ± 0.002	7/26/82 to 8/2/82	≤ 0.01	≤ 0.020
8/2/82 to 8/9/82	0.034 ± 0.004	0.037 ± 0.003	8/9/82 to 8/16/82	≤ 0.01	≤ 0.019
8/16/82 to 8/23/82	0.021 ± 0.003	0.027 ± 0.002	8/23/82 to 8/30/82	≤ 0.01	≤ 0.019
8/30/82 to 9/7/82	0.027 ± 0.003	0.030 ± 0.002	9/7/82 to 9/13/82	≤ 0.01	≤ 0.040

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

TABLE III.6  
QUALITY CONTROL RESULTS  
AIR PARTICULATES AND CHARCOAL FILTER: COMPARABLE SAMPLES

Air Particulates pCi/Cu. Meter (Beta)			Air Iodine pCi/Cu. Meter		
Sample Date	DLC Contractor Lab (1)	DLC - QC Lab (1)	Sample Date	DLC Contractor Lab (1)	DLC - QC Lab (1)
9/13/82 to 9/20/82	0.018 ± 0.003	0.020 ± 0.002	9/20/82 to 9/27/82	≤ 0.009	≤ 0.018
9/27/82 to 10/4/82	0.025 ± 0.003	0.031 ± 0.003	10/4/82 to 10/11/82	≤ 0.009	≤ 0.019
10/11/82 to 10/18/82	0.025 ± 0.003	0.023 ± 0.002	10/18/82 to 10/25/82	≤ 0.009	≤ 0.014
10/25/82 to 11/1/82	0.040 ± 0.004	0.035 ± 0.003	11/1/82 to 11/8/82	≤ 0.01	≤ 0.018
11/8/82 to 11/15/82	0.034 ± 0.004	0.034 ± 0.003	11/15/82 to 11/22/82	≤ 0.006	≤ 0.018
11/22/82 to 11/29/82	0.021 ± 0.003	0.027 ± 0.002	11/29/82 to 12/6/82	≤ 0.01	≤ 0.023
12/6/82 to 12/13/82	0.027 ± 0.003	0.030 ± 0.003	12/13/82 to 12/20/82	≤ 0.01	≤ 0.023
12/20/82 to 12/27/82	0.020 ± 0.003	0.026 ± 0.002	12/27/82 to 1/3/82	≤ 0.01	≤ 0.017

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

TABLE III.6  
QUALITY CONTROL  
AIR PARTICULATES ( $\mu\text{Ci}/\text{m}^3$ )

<u>Sample Date</u>	<u>Nuclide</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC - QC Lab (1)</u>
January	Be-7	$0.105 \pm 0.016$	$0.081 \pm 0.008$
(12/28/81 to 2/1/82) Bettis	K-40	$0.018 \pm 0.013$	- -
(12/28/81 to 2/1/82) Teledyne	Others	LLD	LLD
March			
(3/1/82 to 3/29/82) Bettis	Be-7	$0.083 \pm 0.016$	$0.080 \pm 0.030$
(3/1/82 to 3/29/82) Teledyne	Others	LLD	LLD
May			
(5/3/82 to 6/1/82) Bettis	Be-7	$0.113 \pm 0.011$	$0.18 \pm 0.03$
(5/3/82 to 6/1/82) Teledyne	Others	LLD	LLD
July			
(6/28/82 to 7/26/82) Bettis	Be-7	$0.137 \pm 0.018$	$0.090 \pm 0.016$
(6/28/82 to 8/2/82) Teledyne	Others	LLD	LLD
September			
(8/30/82 to 9/27/82)	Be-7	$0.076 \pm 0.029$	$0.045 \pm 0.018$
	Others	LLD	LLD
November			
(11/1/82 to 11/29/82)	Be-7	$0.086 \pm 0.019$	$0.057 \pm 0.016$
	Others	LLD	LLD

LLD Lower limit of detector.

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

- - Analyses not performed nor required.



TABLE III.6  
QUALITY CONTROL  
AIR PARTICULATES ( $\text{pCi}/\text{m}^3$ )

<u>Sample Date</u>	<u>Nuclide</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC - QC Lab (1)</u>
January	Be-7	$0.105 \pm 0.016$	$0.081 \pm 0.008$
(12/28/81 to 2/1/82) QC Lab	K-40	$0.018 \pm 0.013$	- -
(12/28/81 to 2/1/82) Contractor Lab	Others	LLD	LLD
March			
(3/1/82 to 3/29/82) QC Lab	Be-7	$0.083 \pm 0.016$	$0.080 \pm 0.030$
(3/1/82 to 3/29/82) Contractor Lab	Others	LLD	LLD
May			
(5/3/82 to 6/1/82) QC Lab	Be-7	$0.113 \pm 0.011$	$0.18 \pm 0.03$
(5/3/82 to 6/1/82) Contractor Lab	Others	LLD	LLD
July			
(6/28/82 to 7/26/82) QC Lab	Be-7	$0.137 \pm 0.018$	$0.090 \pm 0.016$
(6/28/82 to 8/2/82) Contractor Lab	Others	LLD	LLD
September			
(8/30/82 to 9/27/82) QC Lab	Be-7	$0.076 \pm 0.029$	$0.045 \pm 0.018$
(8/30/82 to 9/27/82) Contractor Lab	Others	LLD	LLD
November			
(11/1/82 to 11/29/82) QC Lab	Be-7	$0.086 \pm 0.019$	$0.057 \pm 0.016$
(11/1/82 to 11/29/82) Contractor Lab	Others	LLD	LLD

LLD Lower limit of detector.

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

- - Analyses not performed nor required.

TABLE III.6  
QUALITY CONTROLAIR PARTICULATE AND CHARCOAL FILTER - COMPARABLE SAMPLES  
LOCATION 30 - (pCi/m<sup>3</sup>)

<u>Sample Date</u>	<u>Nuclide</u>	<u>DLC Contractor Lab (1)</u>	<u>DLC - QC Lab (1)</u>
1st Quarter Composite 12/28/81 to 3/29/82	Sr-89	$\leq 0.0012$	$\leq 0.0012$
	Sr-90	$0.0002 \pm 0.0001$	$\leq 0.00019$
3rd Quarter Composite 6/27/82 to 9/27/82	Sr-89	$\leq 0.0014$	$\leq 0.00086$
	Sr-90	$0.0002 \pm 0.0001$	$\leq 0.00015$

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

TABLE III.7  
QUALITY CONTROL DATAQC Sample Comparisons  
(All Analyses in pCi/l)

Sample Date	Ident. No.	Sample Type and Analysis	Independent Lab (1)	DLC Contractor Lab (1)	DLC - QC Lab (1)
2-24-82	53-239	Water: Sr-90	9.9 ± 0.4	9.6 ± 0.7	9.8 ± 1.5
		I-131	2.1 ± 0.4	4.6 ± 0.2	4.9 ± 0.7
		Co-60	16 ± 8	19.4 ± 5.7	15 ± 6
		Cs-134	23 ± 10	19.3 ± 6.3	17 ± 5
		Cs-137	35 ± 9	34.3 ± 6.2	30 ± 6
2-24-82	53-240	Water: H-3	1050 ± 60	1210 ± 100	1020 ± 210
5-19-82	53-241	Water: Sr-89	5.3 ± 1.0	5.0 ± 3.1	4.0 ± 2.2
		Sr-90	19.8 ± 0.5	15 ± 1	16 ± 2
		I-131	16 ± 2	18 ± 1	16 ± 1
		Co-58	28 ± 8	33 ± 6	38 ± 8
		Co-60	19 ± 8	19.1 ± 5.5	20 ± 7
		Cs-137	21 ± 8	18.6 ± 6.3	21 ± 8
5-19-82	53-242	Water: H-3	1230 ± 60	1250 ± 100	1600 ± 230
8-18-82	53-243	Water: Sr-90	25.4 ± 0.6	21 ± 1.0	25 ± 2
		I-131	4.7 ± 1.3	7.7 ± 0.3	11 ± 1
		Fe-59	40 ± 20	30.3 ± 11.5	26 ± 14
		Co-60	29 ± 9	28.6 ± 2.9	33 ± 9
		Cs-134	18 ± 8	15.5 ± 6.4	10 ± 7
		Cs-137	23 ± 7	27.6 ± 6.1	28 ± 8
8-18-82	53-244	Water: H-3	1260 ± 60	1270 ± 100*	1230 ± 230
11-10-82	53-245	Water: Sr-89	10 ± 2	14 ± 5	9.8 ± 2.2
		Sr-90	24 ± 0.5	24 ± 1	15 ± 2
		I-131	17 ± 11	16 ± 1	17.7 ± 0.9
		Co-58	34 ± 8	35.6 ± 5	30 ± 8
		Co-60	25 ± 8	29.8 ± 5.7	31 ± 7
		Cs-137	27 ± 8	38.5 ± 5.8	35 ± 9
11-10-82	53-246	Water: H-3	1260 ± 60	1270 ± 100	1360 ± 280

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

\* Based on reanalysis, the first analysis, although in general agreement with the QC Lab appeared to be biased high.

TABLE III.7  
QUALITY CONTROL DATAQC Sample Comparisons  
(All Analyses in pCi/l)

Sample Date	Ident. No.	Sample Type and Analysis	Independent Lab (1)	DLC Contractor Lab (1)	DLC - QC Lab (1)
2-24-82	52-222	Milk: Sr-89	9.3 ± 1.5	10 ± 4	9.7 ± 2.2
		Sr-90	14.1 ± 0.6	13 ± 1	14 ± 2
		I-131	19.8 ± 0.4	23 ± 1	19 ± 2
		Cs-134	14 ± 5	15.4 ± 4.2	9.1 ± 6.2
		Cs-137	38 ± 5	35.6 ± 5.3	40 ± 5
5-19-82	52-223	Milk: Sr-89	5.0 ± 2	4.0 ± 1.7	≤ 3.0
		Sr-90	19.4 ± 0.5	16 ± 1 *	19 ± 2
		I-131	5.2 ± 1.0	5.8 ± 0.2	3.5 ± 1.7
		Cs-134	19 ± 4	19.6 ± 4.9	18 ± 7
		Cs-137	24 ± 4	29.5 ± 5.2	33 ± 8
8-18-82	52-224	Milk: Sr-89	5.0 ± 2	6.1 ± 2.9	3.8 ± 2.6
		Sr-90	21.0 ± 0.6	15 ± 1.0	20 ± 2
		I-131	3.4 ± 0.4	4.8 ± 0.2	5.9 ± 0.7
		Cs-134	22 ± 4	11.7 ± 6.3	16 ± 9
		Cs-137	25 ± 4	26.3 ± 6.3	32 ± 8
11-10-82	52-225	Milk: Sr-89	12 ± 2	15 ± 2 **	7.1 ± 2.5
		Sr-90	20.8 ± 0.6	16 ± 2	15 ± 2
		I-131	13.5 ± 1	12 ± 1	12.6 ± 1.4
		Cs-134	21 ± 7	18.6 ± 5	15 ± 7
		Cs-137	34 ± 4	44.1 ± 5.7	34 ± 7

(1) Uncertainties are based on counting statistics and are specified at the 95% confidence interval.

\* Based on reanalysis, the first analysis, although in general agreement with the QC Lab appeared to be biased low.

\*\* Although the Contractor Lab and the Q.C. Lab results are not in good agreement, both the Q.C. Lab and the Contractor Lab are in good agreement with the Independent Lab.

7. Nuclear Regulatory Commission (NRC) Program

The Nuclear Regulatory Commission (NRC) also conducted a surveillance program in the vicinity of the site. Samples of air, river water, drinking water, sediment, milk, vegetation, fish and radiation monitoring are included in their program. The Commonwealth of Pennsylvania's radiological laboratory is utilized by the NRC for analyzing these samples. Comparison of results also indicated agreement between the NRC Laboratory and the Duquesne Light Company Contractor Laboratory.

B. Evaluation of the Quality Control (QC) Program Data

The split sample program indicates that the Contractor laboratory is performing satisfactorily. In addition, three (3) independent laboratories are used to supplement the regular program. Comparisons between the independent laboratories and the Contractor laboratory is acceptable, and demonstrates a satisfactory performance by the DLC contractor.

Based on all available QC data and the data from the Contractor's internal EPA Interlaboratory Cross Check Program, the Environmental Monitoring Program for 1982 is acceptable with respect to both accuracy and measurement.

C. Standard Requirements and Limitations for Radiological and Other Effluents

The Shippingport Atomic Power Station and Beaver Valley Power Station are governed by rules and regulations of the Federal Government and the Commonwealth of Pennsylvania. Effluent releases at both stations are controlled to ensure that limits set by Federal or State governments are not exceeded. In addition, self-imposed limits have been established to further limit discharges to the environment.

Shippingport Atomic Power Station is operated in compliance with regulations and permits involving radioactive and other effluents. Limits noted in Department of Energy (DOE) Orders 5484.1 and 5480.1, Ohio River Valley Water Sanitation Commission (ORSANCO) Standards No. 1-70 and 2-70, Pennsylvania Department of Environmental Resources - Industrial Waste Permit #1832, and Environmental Protection Agency (EPA) National Pollutant Discharge Elimination System (NPDES) Permit #PA-0001589, Pennsylvania Department of Environmental Resources Industrial Waste Permit #0472205, and Pennsylvania Department of Environmental Resources Radioactive Gaseous Discharge Permit are observed and followed.

C. Standard Requirements and Limitations for Radiological and Other Effluents (continued)

Beaver Valley Power Station is subject to regulations which include the Code of Federal Regulations 10 CFR, Pennsylvania Department of Environmental Resources (PDER) Industrial Waste Permit #0473211, Sewage Treatment Facilities Permit #0479403, Gaseous Discharge Permit #04-306-001, PA Code - Title 24, Part I, Ohio River Valley Water Sanitation Commission (ORSANCO) Standards No. 1-70 and 2-70, Environmental Protection Agency (EPA), National Pollution Discharge Elimination (NPDES) Permit #0025615, and the Beaver Valley Power Station Technical Specifications.

D. Significant Changes and Reporting Levels

Statistically significant changes in radiological environmental monitoring results are defined as the median value (M) plus two (2) times the 95% confidence interval (N), or ten (10) times the lower limit of detection (LLD) for each sampling media analyzed during the preoperational period 1972 - 1975. Analytical results for sampling media noted in the Beaver Valley Power Station Environmental Technical Specifications, which were greater than the statistically significant values determined in the preoperational program ( $M + 2N$  or  $10 \times LLD$ ), are values which require reporting as an anomalous measurement. This report is forwarded to the Nuclear Regulatory Commission within 10 (ten) days after the completion of a confirming analysis.

There were two (2) analytical results of environmental samples during 1982 which exceeded Beaver Valley Power Station reporting levels and are summarized in Table III.8. The surface water tritium results were attributable to Beaver Valley discharges; however, the releases were well below limits noted in 10 CFR20.

## SECTION III

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental ReportTABLE III.8  
Anomalous Measurements\* During 1982

<u>Sample Date</u>	<u>Environmental Media</u>	<u>Site Location</u>	<u>Reporting Level</u>	<u>Level Found (Analyt. Results)</u>
3rd Quarter 1982	Tritium in Surface Water (1)	2A	1390 pCi/1	1570 pCi/1
4th Quarter 1982	Tritium in Surface Water (1)	2A	1390 pCi/1	2580 pCi/1

NOTE (1): Attributable to BVPS releases. (There were no releases which exceeded effluent limits for tritium as identified in 10 CFR 20).

---

\* Measurements which exceed the reporting levels in the Beaver Valley Power Station Environmental Technical Specifications.

IV. MONITORING EFFLUENTSA. Monitoring of Liquid Effluents

Description of Liquid Effluents at the Shippingport Atomic Power Station and the Beaver Valley Power Station.

Most of the water required for the operation of the Beaver Valley and Shippingport stations is taken from the Ohio River, and returned to the river, used for makeup to various plant systems, consumed by station personnel, or discharged to a septic system. In addition, small amounts of well water and liquid effluents are discharged to the Ohio River using discharge points shown in Figure 4.1. Figures 4.2 through 4.5 are schematic diagrams of liquid flow paths for Shippingport and Beaver Valley respectively. The following four (4) tables summarize radioactive liquid effluents at both the Shippingport and Beaver Valley Power Stations:

Table IV.A.1 - Effluent Treatment, Sampling, and Analytical Procedures - Shippingport


Table IV.A.2 - Effluent Treatment, Sampling, and Analytical Procedures - Beaver Valley

Table IV.A.3 - Results of Liquid Effluent Discharges to the Environment - Shippingport

Table IV.A.4 - Results of Liquid Effluent Discharges to the Environment - Beaver Valley




DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report



DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

SECTION IV


FIGURE 4.2



DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

SECTION IV

FIGURE 4.3







FIGURE 4.4

SHIPPINGPORT ATOMIC POWER STATION - LIQUID RADIOACTIVE WASTE SYSTEMS

FIGURE 4.4

FIGURE 4.4

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report



DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

TABLE IV.A.1

1. Effluent Treatment, Sampling and Analytical Procedures - Shippingport

<u>Effluent Type</u>	<u>Treatment, Sampling and/or Monitoring</u>	<u>Standard and/or Analytical Procedures</u>
(a) Steam System Blowdown	Directed to radwaste system if radioactive. Normally directed to discharge channel where it is diluted by circulating cooling water.	Secondary water is sampled for any radioactive contamination. A 1000 ml sample counted in a multichannel analyzer for 10 minutes for gross activity. The counter can measure a minimum detectable activity (MDA) of $8.4 \times 10^{-8}$ $\mu\text{Ci/ml}$ .
(b) Radioactive Waste Liquids	Collected, segregated and processed as one of two types of liquid wastes:  (a) special waste (b) radioactive waste  Sample taken of batch before processing to remove radioactivity and reuse in plant systems. See Figure 4.4.	A 3000 ml sample is counted for gross activity. The counter can measure a minimum detectable activity (MDA) of $4 \times 10^{-8}$ $\mu\text{Ci/ml}$ .

TABLE IV.A.2

1. Effluent Treatment, Sampling and Analytical Procedures - Beaver Valley

<u>Effluent Type</u>	<u>Treatment, Sampling and/or Monitoring</u>	<u>Standard and/or Analytical Procedures</u>
(a) Steam System Blowdown	Recycled or directed to Radwaste System for discharge.	If discharged, procedures adhere to Technical Specifications.
(b) Radioactive Waste	Concentration of radioactive materials released in waste effluents shall not exceed values specified in 10 CFR 20, Appendix B, Table II for unrestricted areas, and the Environmental Technical Specifications.	Procedures adhere to requirements of Technical Specifications.

TABLE IV.A.3

2. Results: Shippingport

<u>Effluent Type</u>	<u>Results for 1982</u>
(a) Steam System Blowdown	The boilers were periodically blown down. The boilers are sampled prior to each blowdown. There was no radioactive liquid discharged in 1982.
(b) Radioactive Waste Liquids	Since Shippingport first went into operation in 1957, the total activity of liquid waste discharged each year has decreased more or less continuously from a high of 0.53 Ci in 1965 to a low of less than 0.001 Ci in the years 1974, 1975, 1976, and 1977. There was no radioactive liquid discharged in 1978, 1979, 1980, 1981, or 1982.

TABLE IV.A.4

2. Results: Beaver Valley

<u>Effluent Type</u>	<u>Results for 1982</u>
(a) Steam System Blowdown	The Steam System Blowdown was recycled or directed to the Radwaste System where it was monitored and discharged. Radioactivity was detected in the blowdown system during a primary to secondary steam generator tube leak ("C" Steam Generator: 7/22/82 to 8/27/82). This liquid was released in accordance with conditions noted in the Environmental Technical Specifications
(b) Radioactive Waste Liquids	Liquid effluents from the Beaver Valley Power Station were released in accordance with conditions noted in the Environmental Technical Specifications. No limits were exceeded. These values have been reported in the Beaver Valley Power Station Semiannual Effluent Reports for 1982.



IV. MONITORING EFFLUENTSB. Monitoring of Airborne Effluents1. Description of Airborne Effluents/Sources

## a. Shippingport Atomic Power Station

The potential source of airborne radioactivity associated with the Shippingport station is the radioactivity contained in the reactor coolant system. This system contains the activated corrosion and wear products, activated impurities in reactor coolant, and small quantities of fission products originating from naturally-occurring uranium impurity. This material could become airborne from reactor coolant sampling operations and from maintenance and overhaul operations which require opening the system or working on contaminated components removed from the system. Stringent radiological controls which have been developed during 25 years of operations at Shippingport are exercised during these operations to prevent radioactivity from becoming airborne. Cobalt-60 is the nuclide of primary concern because of its long radioactive half-life and its concentration in reactor coolant. This radionuclide, present in the form of minute insoluble particles, could become airborne during maintenance operations on contaminated components removed from this system. However, strict radiological surveillance is maintained throughout the operating plant, including continuous monitoring of airborne radioactivity in the operating spaces to ensure that concentrations are less than the uncontrolled area limits specified in DOE Order 5484.1. In addition, air exhausted from potentially contaminated areas, such as decontamination and maintenance areas, is passed through high-efficiency particulate air filters. These filters are routinely serviced, changed, and tested in-place.




#### SECTION IV

#### DUQUESNE LIGHT COMPANY 1982 Annual Radiological Environmental Report

The principle environmental release point for the Shippingport Atomic Power Station is the containment ventilation exhaust. This point is continuously monitored, and analyses are performed on charcoal cartridges weekly for I-131 and monthly for I-133 and I-135. Additionally, weekly continuous air samples are obtained on fixed filter papers which are analyzed weekly for gross beta, and composited monthly to identify gamma emitting isotopes. Composite of the particulate filters are also analyzed monthly for gross alpha determinations and quarterly for Sr-89 and Sr-90. A monthly gas sample is also obtained and analyzed for tritium.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report



Shippingport Atomic Power Station Gaseous  
Radioactive Waste Processing System

FIGURE 4.6

IV. MONITORING EFFLUENTS

## a. Shippingport Atomic Power Station (continued)

Reactor plant exhausts from the Decontamination Room, Sample Preparation Room, Radiochemistry Laboratory, Gaseous Waste System, and Compacting Station are continuously sampled with fixed filter samplers. These samples are analyzed weekly for gross beta, and composited monthly to identify gamma emitting isotopes.

Processing of noble gases (predominantly short lived Xe-133) is accomplished by collecting and storing the gases in Shippingport RWP vent gas system. After sampling and analysis, the gases are released when the storage tanks are full. Figure 4.6 shows a schematic diagram of the gaseous waste system in the radioactive waste disposal system at Shippingport.

## b. Beaver Valley Power Station (BVPS)

The Beaver Valley Power Station identifies isotopes according to the Environmental Technical Specifications and Regulatory Guide 1.21. Prior to waste gas decay tank batch releases and containment purge releases, an analysis of the principal gamma emitters is performed. The principle gamma emitters include noble gases, iodines, and particulates. Figure 4.7 shows the gaseous radwaste system at Beaver Valley Power Station.

The environmental gaseous release points also require specific nuclide identification. These points include the Process Vent located on top of the Cooling Tower, the Ventilation Vent located on the top of the Auxiliary Building, and Supplementary Leak Collection and Release System (SLCRS) Vent located on top of the Containment. These points are continuously monitored. Principal gamma emitters and tritium are analyzed on a monthly basis. Analysis is also done on charcoal cartridges for I-131, I-133, and I-135 that have continuously sampled the gas stream for a week. Weekly continuous samples are also obtained on filter paper to identify particulate gamma emitting isotopes. Composites of the particulate samples are analyzed monthly for gross alpha determinations and quarterly for Sr-89 and Sr-90.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report




FIGURE 4.7  
BEAVER VALLEY POWER STATION GASEOUS RADIOACTIVE WASTE PROCESSING SYSTEM

IV. MONITORING EFFLUENTS2. Airborne Effluent Treatment and Sampling

## a. Shippingport Atomic Power Station

Gaseous wastes stripped from the reactor coolant at the Shippingport Station are circulated through a hydrogen analyzer and catalytic hydrogen burner system where the hydrogen is removed. The gases are initially stored in a vent gas surge drum, and subsequently compressed and transferred to one of four gas storage drums. The decayed gases are sampled prior to release. In addition, the exhaust from the containment is equipped with high efficiency particulate air filters and monitoring devices to prevent releases of radioactive particulates. Protective devices are utilized in the event of high airborne activity to automatically seal off the primary containment to prevent an inadvertent release of radioactivity. Reactor plant exhausts from the Decontamination Room, Sample Preparation Room, Radiochemistry Laboratory, and Compacting Station are also equipped with high efficiency particulate air filters, and are continuously monitored for radioactive particulates by the use of fixed filter monitors. Exhausts from the Gaseous Waste System are filtered and sampled for radioactivity at the release point also. Continuous air monitors are located within the containers, and other plant areas to constantly monitor the condition of the air. A stack release diagram is shown in Figure 4.8 identifying ventilation and gaseous release points for the Shippingport Atomic Power Station.

## b. Beaver Valley Power Station

Radioactive gases enter the gaseous waste disposal system from the degasifier vent chiller of the boron recovery system, and are directed to the gaseous waste charcoal delay subsystem upstream of the overhead gas compressor where the gas is chilled to condense most of the water vapor. Gases from the degasifier vent chillers contain primarily hydrogen and water vapor. A small amount of nitrogen and traces of the radioisotopes xenon, krypton, cobalt, and iodine are also present in the gaseous effluent.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

## SECTION IV

DISCHARGE POINTS - GASEOUS WASTES

FIGURE 4.8



GASEOUS RELEASE POINTS - BEAVER VALLEY POWER STATIONGASEOUS RELEASE POINTS - SHIPPINGPORT ATOMIC POWER STATION

FIGURE 4.8

IV. MONITORING EFFLUENTS

## b. Beaver Valley Power Station (continued)

The overhead gas compressor directs the radioactive gas stream to a gas surge tank. The system is designed to return most of the gas to the volume control tank in the Chemical and Volume Control System (CVC System). A quantity of gas is periodically discharged from the surge tank to one of the three (3) decay tanks for eventual release to the atmosphere via the process vent on top of the cooling tower. After the decay tanks are sampled and authorization obtained for discharge, the flow of the waste gases from the decay tanks is recorded and rapidly diluted with about 1000 scfm of air in order to limit hydrogen concentration. The gases are then combined with the containment vacuum system exhaust, aerated vents of the vent and drain system, and the main air ejector effluent. The mixture is then filtered through one of the gaseous waste disposal filters, each of which consists of a charcoal bed and a high efficiency filter. The filtered gases are then discharged by one of the gaseous waste disposal blowers to the atmosphere via the process vent on the top of the cooling tower. The radioactivity levels of the stream are monitored continuously. Samples are also taken to determine the rate of activity released to the atmosphere. Should the radioactivity release concentration of the stream go above the allowable setpoint, a signal from the radiation monitor will stop all flow from the decay tanks.

During a shutdown period after the containment has been sampled and the activity levels determined, the containment may be purged through the Supplementary Leak Collection Release System (SLCRS) Vent, or the ventilation vent located on top of the Auxiliary Building.

Areas in the Auxiliary Building subject to radioactive contamination are monitored for radioactivity prior to entering the common ventilation vent. These individual radiation monitors aid in identifying any sources of contaminated air. The ventilation vent is also monitored continuously and sampled periodically. Upon a high radiation alarm, automatic dampers divert the system's exhaust air stream through one of the main filter banks in the supplementary leak collection and release system (SLCRS) and to the SLCRS Vent. Release points are shown in Figure 4.8 for the Beaver Valley Power Station.



IV. MONITORING EFFLUENTS

## b. Beaver Valley Power Station (continued)

Each filter bank consists of roughing filters, charcoal filters, and pleated glass fiber type HEPA filters. The roughing filters remove large particulates to prevent excessive pressure drop buildup on the charcoal and HEPA filters. The charcoal filters are effective for radioactive iodine removal and the HEPA filters remove particulates and charcoal fines.

3. Analytical Procedures for Sampling Airborne Effluents

## a. Shippingport Atomic Power Station

The following tabulates the gaseous sampling and analysis schedule:

Vent Gas Decay Tank Releases

Sample Type	Sampling Frequency	Type Of Activity Analysis	Detectable Concentration
Gas From Decay Tank	Prior to Discharge	Gamma Ray Spectrum of Gas Sample *	$3 \times 10^{-7}$ $\mu\text{Ci/cc}$
Gas from Decay Tank	Prior to Discharge	H-3	$2 \times 10^{-7}$ $\mu\text{Ci/cc}$
Gas from Decay Tank	Prior to Discharge	C-14	$1 \times 10^{-7}$ $\mu\text{Ci/cc}$

\* A gas sample of measured volume is counted in a multi-channel analyzer for 10 minutes for gross activity. The counter has a minimum detectable activity (MDA) of  $3 \times 10^{-7}$   $\mu\text{Ci/cc}$  for the predominant nuclide of Xe-133.

IV. MONITORING EFFLUENTS3. Analytical Procedures for Sampling Airborne Effluents (continued)Air Exhausts

Sample Type	Sampling Frequency	Type Of Activity Analysis	Detectable Limits
1) Air from the Plant Ventilation Exhaust Effluent Stream	Continuous	Gross Gamma	$1.2 \times 10^{-6}$ $\mu\text{Ci/cc}$ (Gas, Channel 8 ORMS)* $5 \times 10^{-10}$ $\mu\text{Ci/cc}$ (Particulate; Channel 12 ORMS)*
2) Particulate Filter in Plant Ventilation Effluent Stream	Continuous	Gross Beta Weekly Sample	$1 \times 10^{-14}$ $\mu\text{Ci/cc}$ (Particulate)
Particulate Filter in Plant Ventilation Effluent Stream	Continuous	Principle Gamma Monthly Composite (Weekly if Gross Beta $\geq 1 \times 10^{-13}$ )	$1 \times 10^{-14}$ $\mu\text{Ci/cc}$ Particulate
Particulate Filter in Plant Ventilation Effluent Stream	Continuous	Gross Alpha Monthly	$2 \times 10^{-15}$ $\mu\text{Ci/cc}$ Particulate
Particulate Filter in Plant Ventilation Effluent Stream	Continuous	Sr-89, Sr-90 Quarterly	$5 \times 10^{-14}$ $\mu\text{Ci/ml}$ (Sr-89) $1 \times 10^{-14}$ $\mu\text{Ci/ml}$ (Sr-90) Particulate
3) Charcoal Cartridge in Plant Ventilation Effluent Stream	Continuous	I-131 Weekly	$1 \times 10^{-13}$ $\mu\text{Ci/ml}$
Charcoal Cartridge in Plant Ventilation Effluent Stream	Monthly	I-133, I-135 Monthly	$1 \times 10^{-13}$ $\mu\text{Ci/ml}$ (I-133) $1 \times 10^{-12}$ $\mu\text{Ci/ml}$ (I-135)
4) Evacuated Bomb Sample In Plant Ventilation Effluent Stream	Monthly	$\text{H}^3$	$2 \times 10^{-7}$ $\mu\text{Ci/ml}$
5) Particulate Filter in Reactor Plant Exhaust from Decontamination Room, Sample Preparation Room, Radiochemistry Laboratory, Gaseous Waste System, and Compacting Station.	Continuous	Gross Beta Weekly	$1 \times 10^{-14}$ $\mu\text{Ci/cc}$ Particulate
Particulate filter in Reactor Plant Exhaust from Decontamination Room, Sample Preparation Room, Radiochemistry Laboratory, and Compacting Station.	Continuous	Principal Gamma Monthly Composite (Weekly if Gross Beta $\geq 1 \times 10^{-13}$ )	$1 \times 10^{-14}$ $\mu\text{Ci/cc}$ Particulate

RMS - Operational Radiation Monitoring System

Although the ORMS Channels have no specific function as far as effluent monitoring and reporting is concerned, these two (2) channels are being listed for information purposes. It is also noted that these channels provide alarm functions in the Main Control Room when levels of  $1.2 \times 10^{-6}$   $\mu\text{Ci/cc}$  are reached on Channel 8, or  $1 \times 10^{-9}$   $\mu\text{Ci/cc}$  on Channel 12. Additionally, they shut the ventilation system butterfly valves when levels of  $1.2 \times 10^{-6}$   $\mu\text{Ci/cc}$  are reached on Channel 8 or  $1 \times 10^{-7}$   $\mu\text{Ci/cc}$  on Channel 12.

IV. MONITORING EFFLUENTS3. Analytical Procedures for Sampling Airborne Effluents (continued)

## b. Beaver Valley Power Station

The following tabulates the gaseous sampling and analysis schedule:

	Gaseous Source	Sampling Frequency	Type Of Activity Analysis	Detectable Concentrations ( $\mu\text{Ci/ml}$ ) <sup>a</sup>
(1)	Waste Gas Decay Tank Releases	Each Tank	Principal Gamma Emitters	$10^{-4b}$
			H-3	$10^{-6}$
(2)	Containment Purge Releases	Each Purge	Principal Gamma Emitters	$10^{-4c}$
			H-3	$10^{-6}$
(3)	Environmental Release Points	Monthly (Gas Samples)	Principal Gamma Emitters	$10^{-4b,c}$
			H-3	$10^{-6}$
		Weekly (Charcoal Sample)	I-131	$10^{-12}$
		Weekly (Charcoal Sample)	I-133, I-135	$10^{-10}$
		Weekly <sup>d</sup> (Particulates)	Principal Gamma Emitters (Ba-La-140, I-131, and others)	$10^{-11}$
		Monthly <sup>d</sup> Composite (Particulates)	Gross $\alpha$	$10^{-11}$
		Quarterly <sup>d</sup> Composite (Particulates)	Sr-90 and Sr-89	$10^{-11}$

<sup>a</sup> The above detectability limits for activity analysis are based on technical feasibility and on the potential significance in the environment of the quantities released. For some nuclides, lower detection limits may be readily achievable, and when nuclides are measured below the stated limits, they should also be reported.

<sup>b</sup> For certain mixtures of gamma emitters, it may not be possible to measure radionuclides at levels near their sensitivity limits when other nuclides are present in the sample at much higher levels. Under these circumstances, it will be more appropriate to calculate the levels of such radionuclides using observed ratios with those radionuclides which are measurable.

<sup>c</sup> Analyses shall also be performed following each refueling, startup, or similar operational occurrence which could alter the mixture of nuclides.

<sup>d</sup> To be representative of the average quantities and concentrations of radioactive materials in particulate form released in gaseous effluents, samples should be collected in proportion to the rate of flow of the effluent stream.

IV. MONITORING EFFLUENTS4. Results

## a. Shippingport Atomic Power Station

Analyses for the particulate airborne radioactivity in the plant effluents indicated that the gross alpha and beta activity concentrations were at or very near the Lower Limit of Detection (LLD). Analytical results of charcoal filter samples showed that there were no instances of radioiodine concentrations above LLD.

Specific gamma analyses of weekly and monthly composite air filter samples were also performed. Results showed naturally occurring radioactivity typical of "background air" and nuclides attributable to worldwide fallout from nuclear weapons testing. During 1982, there were three instances where activity, attributable to plant operations, was measured.

In the first instance, Cobalt-60 activity was measured in the Decontamination Room Waste Receiver Exhaust. The total amount of Co-60 activity released was 0.000000000663 curies at a concentration of  $1.54 \times 10^{-13}$   $\mu\text{Ci/ml}$ . In the second instance, 0.000000000157 curies of Co-60 activity was released from the Decontamination Room Waste Receiver Exhaust at a concentration of  $1.43 \times 10^{-12}$   $\mu\text{Ci/ml}$ . In the third instance, Cobalt-60 activity was measured in the Reactor Plant Main Ventilation Exhaust. The total amount of Co-60 activity released was 0.000000298 curies at a concentration of  $4.76 \times 10^{-15}$   $\mu\text{Ci/ml}$ .

Radiostrontium analyses of quarterly composite air filter samples showed Sr-89 and Sr-90 concentrations in air which were at or near the minimum detectable concentrations of  $5 \times 10^{-14}$   $\mu\text{Ci/ml}$ , and  $1 \times 10^{-14}$   $\mu\text{Ci/ml}$ , respectively. The levels of Sr-89 and Sr-90 observed were extremely low and are typical of "background air" radiostrontium levels. Also tritium and carbon-14 gaseous releases in the effluents were estimated based on analyses of primary coolant and found to be below the predicted levels presented in the LWBR Program Environmental Impact Statement.

There were thirteen (13) releases of gaseous radioactivity from the Shippingport Atomic Power Station during 1982. The total gaseous

#### SECTION IV

#### DUQUESNE LIGHT COMPANY 1982 Annual Radiological Environmental Report

radioactivity released from the Shippingport Atomic Power Station during 1982 was approximately 0.00154 curies of Xe-133. The amount of radioactivity released from the Shippingport Atomic Power Station during 1982 was extremely small and had a negligible effect on the environment as shown in Section V.6.

##### b. Beaver Valley Power Station

Gaseous effluents from the Beaver Valley Power Station were released in accordance with conditions noted in the Environmental Technical Specifications. No limits were exceeded. These values have been reported in the Beaver Valley Power Station Semi-Annual Effluent Reports for 1982.

IV. MONITORING EFFLUENTSC. Solid Waste Disposal at the Shippingport and Beaver Valley Power Stations

During normal operations and periodic maintenance, Shippingport and Beaver Valley Power Station generated small quantities of radioactive solid waste materials such as evaporator concentrates, contaminated rags, paper, plastics, filters, spent ion-exchange resins, and miscellaneous tools and equipment. These were disposed of as solid radioactive waste.

At Shippingport Atomic Power Station and the Beaver Valley Power Station, the compactable wastes were segregated and compressed in a 55-gallon compactor to minimize disposal volumes. The compressed waste, plus other drums of noncompactable waste, were then shipped offsite for disposal at a site owned by the Department of Energy or a commercial radioactive material burial site licensed by the Nuclear Regulatory Commission (NRC) or a state under agreement with the NRC. No radioactive waste material was buried at the Shippingport or Beaver Valley Power Station site.

All containers used for packaging, transport, and disposal of radioactive materials met the requirements of the United States Department of Transportation and the Nuclear Regulatory Commission. Shipments offsite were made in accordance with Department of Transportation regulations. Figure 4.9 depicts solid waste handling at the site.

In 1982, the Shippingport plant disposed of a total of 6312 cubic feet of radioactive solid waste having a total radioactivity of about 0.217 curies. This included twelve (12) shipments of low level wastes.

At Beaver Valley Power Station approximately 10,392 cubic feet of radioactive solid waste was shipped offsite in 1982. The actual burial volume of solid waste is slightly higher due to container size (11,052 cubic feet). The thirty-three (33) shipments contained a total activity of 383.4 curies.

Industrial solid wastes from both plants were collected in portable bins, and removed to an approved offsite burial ground. No burning or burial of wastes was conducted at either the Beaver Valley or Shippingport plant.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

SECTION IV

SOLID WASTE DISPOSAL DIAGRAM

FIGURE 4.9



RADIOACTIVE SOLID WASTE DISPOSALINDUSTRIAL SOLID WASTE DISPOSAL DIAGRAM

FIGURE 4.9



V. ENVIRONMENTAL MONITORINGA. Environmental Radioactivity Monitoring Program1. Program Description

The program consists of monitoring water, air, soil, river bottoms, vegetation and foodcrops, cow's milk, ambient radiation levels in areas surrounding the site, and aquatic life as summarized in Table V.A.1. Further description of each portion of the program (Sampling, Methods of Sample Analysis, Discussion and Results) are included in parts V-B through V-I of this report.

V-B - Air Monitoring

V-C - Sediments and Soils Monitoring

V-D - Vegetation and Foodcrops

V-E - Cow's Milk

V-F - Environmental Radiation Monitoring

V-G - Fish

V-H - Surface, Drinking and Well Waters

V-I - Estimates of Radiation Dose to Man



TABLE V.A.1  
CONSOLIDATED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Type of Sample	DLC Sample Points	Sample Point Description	Sample Frequency	Sample Preparation	Analysis Frequency	(b) Analysis
1. Air Particulate and Radioiodine	13.	Meyer's Farm	Continuous Sampling with sample collect- tion at least	Weekly Composite <sup>(d)</sup>		Gross $\beta$ , <sup>(c)</sup> I-131
	30	Shippingport, PA. (S.S.)		Monthly Composite <sup>(d)</sup>		$\gamma$ -scan
	46.1	Industry, PA (Tire Co.)	weekly.	Quarterly Composite <sup>(d)</sup>		
	32	Midland, PA (S.S.)				
	48(a)	Weirton, WV (a)				
	51	Aliquippa, PA (S.S.)				Sr-89, 90
	47	East Liverpool, OH				
	27	Brunton's Farm				
2. Direct Radiation	28	Sherman's Farm	Continuous (TLD)	Quarterly <sup>(k)</sup>		$\gamma$ -Dose
	29B	Beaver County Hospital		Annually <sup>(K)</sup>		
	30	Shippingport, PA (S.S.)				
	13	Meyer's Farm				
	46	Industry, PA (Church)				
	32	Midland, PA (S.S.)				
	48(a)	Weirton, WV (a)				
	45.1	Raccoon Twp, PA Kennedy's Crnrs.				
DLC#	70	West. Bvr. School	Continuous (TLD)	Quarterly <sup>(k)</sup>		$\gamma$ -Dose
	28	Sherman's Farm		Annually		
	71	Brighton Twp. School				
	72	Logan School				
	29B	Beaver County Hospital				
	73	Potter Twp. School				
	74	Comm. Col-Center Twp.				
	75	Holt Road				
	76	Raccoon Twp. School				
	77	Green Garden Rd (Wayne's)				
	59	Irons				
	78	Raccoon Mun. Bldg.				
	27	Brunton's Farm				
	79	Rt. 18 & Rt. 151				
	15	Georgetown				
	46.1	Industry PA Tire Co.				
	91	Pine Grove Rd and Doyle Rd.				
	94	McCleary Rd, Wilson				
	DLC#	DLC#				
	80	Raccoon Park				
	81	Southside School				
	82	Hanover Municipal Bldg.				
	83	Mill Creek Rd				
	14	Hookstown				
	84	Hancock Co. Children Home				
	85	Rts. 8 & 30 Intersection				
	86	E. Liverpool Cahills House				
	92	Georgetown Rd.				
	87	Calcutta Road				
	88	Midland Heights				
	89	Ohioville				
	90	Fairview School				
	10	Shippingport Boro, PA				
	45	Mt. Pleasant Church				
	60	Haney's Farm				
	93	Sunset Hills, Midland				
	95	McCleary Rd, Hollie Williams				

S.S. - Substation

TABLE V.A.1  
CONSOLIDATED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM  
(Continued)

Type of Sample	DLC Sample Points	Sample Point Description	Sample Frequency	Sample Preparation	Analysis Frequency	(b) Analysis
3. Surface Water	49.1	Arco Polymers (a)	Intermittent	Monthly Composite of		Gross $\beta$
	2.1	Downstream (Midland)Crucible	Composite Samples(j)	Weekly Sample (d)		Gross $\alpha$
	3	Shippingport Atomic Power Station Discharge	Collected Weekly			$\gamma$ -scan
	49(a)	Montgomery Dam (Upstream)	Weekly Grab Samples Only	Quarterly Composite		Co-60, H-3
	2A	Downstream BVPS Outfall				Sr-89, Sr-90
4. Groundwater	5	East Liverpool (raw water)	Daily Grab Sample Only - Collected Weekly (j)			
	13	Meyer's Farm				
	14	Hookstown, PA				
	15	Georgetown, PA				
5. Drinking	11	Shippingport Boro	Quarterly	Quarterly		$\gamma$ -scan, Gross $\beta$
						Gross $\alpha$ , H-3
	4	Midland, PA (Midland Water Treatment Plant)	Intermittent <sup>(e)</sup> Sample Collected Weekly	Weekly Composite of Daily Sample (d)		$\gamma$ -scan, I-131
6. Shoreline Sediment	5	East Liverpool, OH (East Liverpool Water Treatment Plant)		Monthly Composite (d) Quarterly Composite (d)		Gross $\alpha$ , Gross $\beta$ H-3, Co-60, Sr-89, 90
	2A	Downstream BVPS Outfall	Semiannual	Semiannual		$\gamma$ - scan, Gross $\beta$
	3	Vicinity SAPS Discharge				Gross $\alpha$
7. Milk	49	Upstream Side of Montgomery Dam (a)				Uranium Isotopic
	50	Upstream side of New Cumberland Dam				Sr-89, 90
	25	Searight's Dairy	Weekly <sup>(f)</sup>	Weekly sample from Searight's only		I-131
	61*	Allison		Biweekly (grazing)		$\gamma$ - scan
	62*	Lyon		Monthly (indoors)		Sr-89, 90
	66*	Straight				I-131, Cs-137
	69*	Collins	Biweekly (g)			
	96(a)	Windsheimer	When animals are on pasture;			
	97*	Douglass	monthly at other times.			
	98*	Foxall (Hammond)	Monthly	Monthly		$\gamma$ - scan
	99*	Lampich				Sr-89, 90
	27	Brunton's Dairy (h)				I-131, Cs-137
	29A	Nicol's Dairy (h)				

\*Additional dairies required by Environmental Technical Specification 3.2.1.D.2. In addition to Searight's (Site 25), three dairies are selected when milk is available based on highest deposition factors. Sites 27 and 29A are required for the Shippingport program.

TABLE V.A.1  
CONSOLIDATED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM  
(Continued)

Type of Sample	DIC Sample Points	Sample Point Description	Sample Frequency	Sample Preparation	Analysis Frequency	Analysis (b)
8. Fish	2A	Vicinity of BVPS #1 Station Discharge and Shippingport Dis. Sta.	Semiannual	Composite of edible parts by species (i)		γ-scan on edible portions
	49(a)	Upstream Side of Montgomery Dam				
9. Food Crops (Shipp.)	10	(Three locations within	Annual at	Composite of each		γ-scan
(Georg.)	15	5 miles Selected by	harvest if	sample species		I-131 on green
(Indus.)	46	Company)	available			leafy vegetables
	48(a)	Weirton, WV				
10. Feedstuff and Summer Forage	25	Searight's Dairy Farm	Monthly	Monthly		γ-scan
			Quarterly	Quarterly Composite		Sr-90
11. Soil	13	Meyer's Farm	Every 3 years	12 Core Samples		γ-scan
	30	Shippingport, Pa.	(1982, 1985, etc.)	3" Deep (3" Dia.		Sr-90
	46	Industry, Pa.		at each location		Gross β
	32	(North of Site) Midland		(approx. 10'		Gross α
	48(a)	Weirton, W. Va.		radius)		Uranium Isotopic
	51	Aliquippa, Pa.				
	47	E. Liverpool, Oh.				
	27	Brunton's Dairy				
	22	South of BVPS Site				
	29A	Nichol's Dairy				

TABLE V.A.1  
CONSOLIDATED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM  
(Continued)Notes:

- (a) Control sample station: These are locations which are presumed to be outside the influence of plant effluents.
- (b) Typical LLD's for Gamma Spectrometry are shown in Table V.A.4.
- (c) In these cases a gamma isotopic analysis is done if the gross beta activity exceeds the reporting level of  $0.53\text{pCi/m}^3$ .
- (d) Analysis composites are well mixed actual samples prepared of equal portions from each shorter term samples from each location.
- (e) Composite samples are collected at intervals not exceeding 2 hours.
- (f) Weekly milk sample from Searight's Dairy is analyzed for I-131 only.
- (g) Milk samples are collected bi-weekly when animals are in pasture and monthly at other times. [Assume April - October for grazing season (pasture).]
- (h) The milk samples from Brunton's and Nicol's are collected once per month.
- (i) The fish samples will contain whatever species are available. If the available sample size permits, then the sample will be separated according to species and compositing will provide one sample of each species. If the available size is too small to make separation by species practical, then edible parts of all fish in the sample will be mixed to give one sample.
- (j) Composite samples are collected at intervals not exceeding 2 hours at locations 49.1 and 2.1. Weekly grab samples are obtained at location 3, 49 and 2A. A weekly grab sample is also obtained from daily composited grab samples obtained by the water treatment plant operator at location 5.
- (k) Two (2) TLD's are collected quarterly and annually from each monitoring location.

Additional Notes:

- Sample points correspond to site numbers shown on maps.
- All Iodine I-131 analyses are performed within 40 hours of sample collection if possible.
- All Air samples are decayed for 72 hours before analyzing for Gross Beta.

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334

Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean Name Distance and Directions	Quar. Mean	Control Locations	Number of Nonroutine Reported Measurements***
			** Mean (f) **Range		**Mean (f) **Range	**Mean (f) **Range	
Air Particulate and Radioiodine ( $10^{-3}$ pCi/Cu. M.)	Gross (519) Beta	2.5	26(519/519) (10-49)	Aliquippa, PA No. 51 8.5 miles - ESE	27(52/52) (11-42)	27(51/51) (12-49)	0
	Sr-89 (40)	2	LLD	--	--	--	-
	Sr-90 (40)	0.1	0.21(19/40) (0.12-0.36)	Sherman Dairy No. 28	0.30(2/4) (0.30-0.31)	0.20(2/4) (0.16-0.24)	0
	I-131(519)	10	LLD	--	--	--	-
	Gamma (120) Be-7	20	106(120/120) (45-215)	East Liverpool No. 47 6.5 miles - W	114(12/12) (63-200)	112(12/12) (63-187)	0
	K-40	10	39(21/120) (15-131)	Meyer's Farm No. 13 1.6 miles - SW	81(2/12) (31-131)	50(3/12) (25-88)	0
	Cs-137	0.6	1.9(4/120) (1.1-1.9)	Weirton, WV No. 48 20 miles - SW	1.9(1/12) --	Same as High Location	0
	Ra-226	10	29(1/120)	Weirton, WV No. 48 20 miles - SW	29(1/12) --	Same as High Location	0
	Th-228	1	2.9(8/120) (1.6-5.9)	Midland, Pa. No. 32 0.9 mile - NNW	4.3(1/12) --	LLD --	0
	Others	Table V.A.	LLD	--	--	--	-

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

## 1982 Annual Radiological Environmental Report

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean	Control Locations	Number of Nonroutine Reported Measurements***	
			** Mean (f)	Name	**Mean (f)		**Mean (f)
			**Range	Distance and Directions	**Range		**Range
Sediment (pCi/g) (dry weight)	Gross (8)	0.3	16(8/8)	BVPS Discharge No. 02A	21(2/2)	16(2/2)	0
	Alpha		(9.0-21)	River Mile -- 35.0	(20-21)	(11-20)	-
	Gross (8)	1.0	40(8/8)	BVPS Discharge No. 02A	49(2/2)	39(2/2)	0
	Beta		(24-52)	River Mile -- 35.0	(46-52)	(35-43)	-
	Sr-89 (8)	0.2	LLD	--	--	--	-
	Sr-90 (8)	0.04	0.069(6/8)	BVPS Discharge No. 02A	0.082(2/2)	0.057(2/2)	0
			(0.042-0.11)	River Mile -- 35.0	(0.054-0.11)	(0.057-0.057)	-
	Gamma (8)						
	Be-7	0.2	1.8(2/8)	BVPS Discharge No. 02A	2.4(1/2)	LLD	0
			(1.2-2.4)	River Mile -- 35.0	--	--	-
	K-40	0.5	13(8/8)	BVPS Discharge No. 02A	16(2/2)	14(2/2)	0
			(4.0-17)	River Mile -- 35.0	(15-17)	(12-16)	-
	Co-60	0.03	0.58(4/8)	BVPS Discharge No. 02A	1.0(2/2)	LLD	0
			(0.082-1.9)	River Mile -- 35.0	(0.11-1.9)	--	-
	Cs-137	0.02	0.37(8/8)	BVPS Discharge No. 02A	0.63(2/2)	0.37(2/2)	0
			(0.045-0.78)	River Mile -- 35.0	(0.47-0.78)	(0.32-0.42)	-
Ce-144	0.09	0.62(1/8)	Montgomery Dam No. 49	0.62(1/2)	Same as	0	
		--	River Mile -- 31.0	--	High Location	-	
Ra-226	0.1	2.3(8/8)	BVPS Discharge No. 02A	3.5(2/2)	2.3(2/2)	0	
		(1.2-4.0)	River Mile -- 35.0	(3.1-4.0)	(2.0-2.6)	-	
Th-228	0.02	1.5(8/8)	BVPS Discharge No. 02A	2.0(2/2)	1.5(2/2)	0	
		(0.66-2.4)	River Mile -- 35.0	(1.6-2.4)	(1.3-1.7)	-	

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334

Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations		Location with Highest Quar. Mean Name Distance and Directions	Control Locations		Number of Nonroutine Reported Measurements***
			** Mean (f)	**Range		**Mean (f)	**Range	
Sediment (pCi/g) (dry weight) (continued)	Others	Table V.A.	LLD	--	--	--	Montgomery Dam No. 49	-
	U-233 (8) and U-234	0.01	0.44(8/8) (0.13-0.74)		Montgomery Dam No. 49 River Mile -- 31.0	0.49(2/2) (0.44-0.54)	Same as High Location	0
	U-235 (8)	0.01	0.024(6/8) (0.011-0.040)		BVPS Discharge No. 02A River Mile -- 35.0	0.034(2/2) (0.029-0.040)	0.014(2/2) (0.011-0.017)	0
	U-238 (8)	0.01	0.34(8/8) (0.10-0.54)		N. Cumberland D. No. 50 River Mile -- 54.0	0.39(2/2) (0.37-0.40)	0.36(2/2) (0.32-0.40)	0

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)



## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Bucket No. 50-334Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean	Control Locations	Number of Nonroutine Reported Measurements***	
			** Mean (f)	Name	**Mean (f)		**Mean (f)
			**Range	Distance and Directions	**Range		**Range
Weirton WV No. 48							
Soil (pCi/g ) (dry weight)	Gross (10) Alpha	0.3	15(10/10) (8.7-28)	S. of Site BVPS No. 22	28(1/1) --	12(1/1) --	0 -
	Gross (10) Beta	1.0	37(10/10) (30-51)	S. of Site BVPS No. 22	51(1/1) --	32(1/1) --	0 -
	Sr-90 (10)	0.05	0.12(9/10) (0.049-0.21)	East Liverpool No. 47	0.21(1/1) --	0.061(1/1) --	0 -
	Gamma (10)						
	Be-7	0.2	0.26(2/10) (0.21-0.31)	Nicol Dairy No. 29A	0.31(1/1) --	LLD --	0 -
	K-40	0.5	13(10/10) (10-17)	S. of Site BVPS No. 22	17(1/1) --	13(1/1) --	0 -
	Cs-137	0.02	0.68(10/10) (0.28-1.0)	Midland No. 32	1.0(1/1)	0.28(1/1)	0
	Ce-141	0.03	0.13(1/10) --	Aliquippa No. 51	0.13(1/1) --	LLD --	0 -
	Ra-226	0.1	2.2(10/10) (1.4-3.2)	Meyer Farm No. 13	3.2(1/1) --	1.4(1/1) --	0 -

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix 8)

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean Name Distance and Directions	Quar. Mean	Control Locations		Number of Nonroutine Reported Measurements***
			** Mean (f) **Range		**Mean (f) **Range	**Mean (f) **Range	**Range	
Soil (pCi/g ) (dry weight) (continued)	Th-228	0.02	1.2(10/10) (0.82-1.7)	Industry No. 46	1.7(1/1) --	0.98(1/1) --	--	0 -
	Others	Table V.A.	LLO		--	--	--	-
	U-233 (10) and U-234	0.01	0.37(10/10) (0.29-0.51)	Industry No. 46	0.51(1/1) --	0.38(1/1) --	--	0 -
	U-235 (10)	0.01	0.012(10/10) (0.0089-0.016)	Industry No. 46	0.016(1/1) --	0.012(1/1) --	--	0 -
	U-238 (10)	0.01	0.32(10/10) (0.23-0.49)	Nicol Dairy No. 29A	0.49(1/1) --	0.32(1/1) --	--	0 -

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
 (County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean Name Distance and Directions	Quar. Mean **Mean (f) **Range	Control Locations **Mean (f) **Range	Number of Nonroutine Reported Measurements***
			** Mean (f) **Range				
Feed and Forage (pCi/g) (dry weight)	Sr-90 (5)	0.003	0.047(5/5) (0.018-0.075)	Searight Dairy No. 25 2.4 miles - SW	--	One sample location	0
	Gamma (13) Be-7	0.3	1.2(9/13) (0.46-2.5)	--	--	--	0
	K-40	0.5	16(13/13) (8.0-32)	--	--	--	0
	Cs-137	0.03	0.062(1/13) --	--	--	--	0
	Th-228	0.05	0.20(3/13) (0.13-0.26)	--	--	--	0
	Others	Table V.A.	LLD	--	--	--	--

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

-- Searight's Dairy is the only Feed and Forage sample location, therefore, all of the data for this location is listed under All Indicator Locations.

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
 (County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Name Distance and Directions	Quar. Mean	Control Locations	Number of Nonroutine Reported Measurements***
			** Mean (f) **Range		**Mean (f) **Range		
Food and Garden Crops (pCi/g) (wet weight)	I-131 (8)	0.006	LLD	--	--	Weirton, WV No. 48 --	-
	Gamma (8)						
	Be-7	0.3	0.30(1/8) --	Shippingport, PA No. 10	0.30(1/1) --	LLD	0
	K-40	0.5	3.2(8/8) (1.1-6.1)	Weirton, WV No. 48 20 miles - SW	6.1(1/2) --	Same as High Location	0
	Cs-137	0.01	0.044(1/8) --	Industry, PA No. 46 2.0 miles -- NNE	0.044(1/2) --	LLD	0
	Others	TABLE V. A.	--	--	--		-

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
 (County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations		Location with Highest Name Distance and Directions	Quar. Mean	Control Locations		Number of Nonroutine Reported Measurements***
			** Mean (f)	**Range		**Mean (f)	**Mean (f)	**Range	
Milk (pCi/l)	I-131 (152)	0.2	LLD		--	--	Brunton Dairy No. 27		--
	Sr-89 (119)	2	LLD		--	--	--	--	--
	Sr-90 (119)	1	4.7(119/119) (0.67-14)		Collins No. 69	9.9(18/18) (3.0-14)	2.1(12/12) (1.6-4.0)		0
	Gamma (119) K-40	100	1360(119/119) (860-1900)		Douglas No. 97	1650(10/10) (1120-1900)	1260(12/12) (1100-1540)		0
	Cs-137	5	7.1(22/119) (4.2-11)		Straight No. 66	10(1/2) --	LLD		0
	Others	Table V.A.	LLD		--	--	--		--

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
 (County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Lower Limit		All Indicator Locations ** Mean (f) **Range	Location with Highest Quar. Mean Name Distance and Directions	Control Locations		Number of Nonroutine Reported Measurements***
	Total Number of Analysis Performed	of Detection (LLD)			**Mean (f) **Range	**Mean (f) **Range	
						Weirton, WV No. 48	
External Radiation (mR/day)	(176) quarterly)	0.05	0.18(176/176) (0.13-0.21)	Raccoon Mun. Bldg. No. 78	0.20(4/4) (0.20-0.21)	0.17(4/4) (0.16-0.18)	0
	(44 annual)	0.05	0.17(44/44) (0.13-0.20)	Raccoon Mun. Bldg. No. 78	0.20(1/1) --	0.17(1/1) --	0 -
Fish (pCi/g) (wet weight)						Montgomery Dam No. 49	
	Gamma (4) K-40	0.5	2.4(4/4) (1.7-3.3)	BVPS Discharge No. 02A River Mile -- 35.0	2.9(2/2) (2.6-3.3)	1.9(2/2) (1.7-2.2)	0 -
	Cs-137	0.01	0.029(1/4) --	Montgomery Dam No. 49 River Mile -- 31.0	0.029(1/2) --	Same as High Location	0 -
	Others	Table V.A.	LLD	--	--	--	-

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
 (County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean	Control Locations		Number of Nonroutine Reported Measurements***
			** Mean (f)	Name	**Mean (f)	**Mean (f)	
			**Range	Distance and Directions	**Range	**Range	
Montgomery Dam No. 49							
Surface Water (pCi/L)	Gross (72) Alpha	1	1.6(1/72)	BVPS Discharge No. 02A River Mile -- 35.0	1.6(1/12)	LLD	-
	Gross (72) Beta	1	5.1(72/72) (2.3-9.5)	BVPS Discharge No. 02A River Mile -- 35.0	6.7(12/12) (4.7-9.5)	5.2(12/12) (4.1-6.9)	0
	Gamma (72)						
	Ra-226	100	120(1/72) --	Crucible Steel No. 2.1 --	120(1/12) --	LLD --	0 -
	Others	TABLE V.A.	LLD	--	--	--	-
	Sr-89 (24)	1.5	LLD	--	--	--	-
	Sr-90 (24)	0.4	LLD	--	--	--	-
	Co-60 (24)(a)	1	LLD	--	--	--	-
	Tritium (24)	100	420(22/24) (70-2580)	BVPS Discharge No. 02A River Mile -- 35.0	1420(4/4) (220-2580)	150(3/4) (110-210)	2 -

(a) Co-60 analyzed by high sensitivity method.

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations	Location with Highest Quar. Mean Name Distance and Directions	Control Locations	Number of Nonroutine Reported Measurements***
			** Mean (f) **Range		**Mean (f) **Range	
Drinking Water (pCi/l)	I-131 (104)	0.2	0.25(1/104)	Midland Pa. No. 04 River Mile -- 36.3	0.25(1/52) --	0
	Gross (24) Alpha	0.6	LLD	--	-- --	-
	Gross (24) Beta	1	4.7(24/24) (2.9-6.5)	Midland Pa. No. 04 River Mile -- 36.3	5.0(12/12) -- (3.0-6.0) --	0
	Gamma (104)	Table V.A.	LLD	--	-- --	-
	Sr-89 (8)	1.5	LLD	--	-- --	-
	Sr-90 (8)	0.4	LLD	--	-- --	-
	Co-60 (8)(a)	1	LLD	--	-- --	-
	Tritium (8)	100	160 (6/8) (110-270)	East Liverpool No. 5 River Mile -- 41.2	175(4/4) -- (110-270) --	-

(a) Co-60 analyzed by high sensitivity method.

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.6 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)



## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Duquesne Light Company Docket No. 50-334Location of Facility Beaver, Pennsylvania Reporting Period Annual 1982  
(County, State)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection (LLD)	All Indicator Locations		Location with Highest Quar. Mean		Control Locations		Number of Nonroutine Reported Measurements***
			** Mean (f)	** Range	Name	** Mean (f)	** Mean (f)	** Range	
Ground Water (pCi/l)	Gross (16) Alpha	2	LLD	--	--	--	Georgetown Δ15	--	-
	Gross (16) Beta	1	3.0(15/16) (1.2-5.3)		Hookstown Pa. No. 14 3 miles -- WSW	4.4(4/4) (3.6-5.0)	1.8(4/4) (1.4-2.5)		0
	Gamma (16)	Table V.A.	LLD	--	--	--	--	--	-
	Tritium (16)	70	150(11/16) (90-210)		Georgetown, Pa. No. 15 4.6 miles -- WNW	160(4/4) (110-210)	Same as High Location		0

\* Nominal Lower Limit of Detection (LLD)

\*\* Mean and range based upon detectable measurements only. Fraction of detectable measurements at specified locations is indicated in parentheses (f)

\*\*\* Nonroutine reported measurements are defined in Regulatory Guide 4.8 (December 1975) and the Beaver Valley Power Station Technical Specifications (Appendix B)

V. ENVIRONMENTAL MONITORINGA. Environmental Radioactivity Monitoring Program (continued)2. Summary of Results

All results of this monitoring program are summarized in Table V.A.2. This table is prepared in the format specified by NRC Regulatory Guide 4.8 and in accordance with Beaver Valley Power Station Operating License, (Appendix B, Environmental Technical Specifications). Summaries of results of analysis of each media are discussed in Sections V-B through V-H and an assessment of radiation doses are found in Section V-I. Table V.A.3 summarizes Beaver Valley Power Station pre-operational ranges for the various sampling media during the years 1974 and 1975. Comparisons of pre-operational data with operational data indicate the ranges of values are in good agreement for both periods of time.

In a few cases where activity was detected, some of the activity was attributable to previous nuclear weapons tests and the remaining detected activities were near the lower limit of their detection (LLD) and are attributable to the normal statistical fluctuation near the LLD level.

The conclusion from all program data is that the operation of the Shippingport and Beaver Valley Power Station has not resulted in any detectable changes to the environment attributable to either station.

3. Quality Control Program

The Quality Control Program implemented by Duquesne Light Company to assure reliable performance by the DLC contractor and the supporting QC data are presented and discussed in Section III of this report. The lower limits of detection for various analysis for each media monitored by this program by the DLC Contractor Laboratory are provided in Table V.A.4.

TABLE V.A.3 (Page 1 of 4)

## ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Shippensburg Atomic Power Station Docket No. Not ApplicableName of Facility Beaver Valley Power Station Docket No. 50-334Location of Facility Beaver, Pennsylvania Reporting Period CY 1974 - 1975  
(County, State)PRE-OPERATIONAL PROGRAM SUMMARY (COMBINED 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed		Lower Limit of Detection LLD	All Indicator Locations Mean, (f) Range	
Surface Water pCi/l	Gross Alpha	(40)	0.3	0.75	<sup>5</sup> /40 0.6 - 1.1
	Gross Beta	(120)	0.6	4.4	<sup>120</sup> /120 2.5 - 11.4
	Gamma	(1)	10 - 60	< LLD	
	Tritium	(121)	100	300	<sup>120</sup> /121 180 - 800
	Sr-89	(0)	—	—	
	Sr-90	(0)	—	—	
	C-14	(0)	—	—	
Drinking Water pCi/l	I-131	(0)	—	—	
	Gross Alpha	(50)	0.3	0.6	<sup>4</sup> /50 0.4 - 0.8
	Gross Beta	(208)	0.6	3.8	<sup>208</sup> /208 2.3 - 6.4
	Gamma	(0)	—	—	
	Tritium	(211)	100	310	<sup>211</sup> /211 130 - 1000
	C-14	(0)	—	—	
	Sr-89	(0)	—	—	
Ground Water pCi/l	Gross Alpha	(19)	0.3	< LLD	
	Gross Beta	(76)	0.6	2.9	<sup>73</sup> /75(a) 1.3 - 8.0
	Tritium	(81)	100	440	<sup>77</sup> /81 80 - 800
	Gamma	(1)	10 - 60	< LLD	
Air Particulates and Gaseous pCi/m <sup>3</sup>	Gross Alpha	(188)	0.001	0.003	<sup>35</sup> /188 0.002 - 0.004
	Gross Beta	(927)	0.006	0.07	<sup>927</sup> /927 0.02 - 0.32
	Sr-89	(0)	—		
	Sr-90	(0)	—		
	I-131	(816)	0.04	0.08	<sup>2</sup> /816 0.07 - 0.08
	Gamma	(197)	—		
	ZrNb-95		0.005	0.04	<sup>122</sup> /197 0.01 - 0.16
	Ru-106		0.010	0.04	<sup>50</sup> /197 0.02 - 0.09
	Ce-141		0.010	0.02	<sup>3</sup> /197 0.01 - 0.04
	Ce-144		0.010	0.02	<sup>44</sup> /197 0.01 - 0.04
	Others		< LLD		

TABLE V.A.3 (Page 2 of 4)  
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Shippensburg Atomic Power Station Docket No. Not Applicable  
 Name of Facility Beaver Valley Power Station Docket No. 50-12-  
 Location of Facility Beaver, Pennsylvania Reporting Period Q1 1974 - 1975  
 (County, State)

PRE-OPERATIONAL PROGRAM SUMMARY (COMBINED 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection LLD	All Indicator Locations Mean, (±) Range	
Soil pCi/g (dry) (Template Samples)	Gross Alpha (0)	—	—	—
	Gross Beta (64)	1	22	64/64 14 - 32
	Sr-89 (64)	0.25	0.4	1/64 —
	Sr-90 (64)	0.05	0.3	48/64 0.1 - 1.3
	U-234,235,238 (0)	—	—	—
	Gamma (64)			
	K-40	1.5	13	63/64 5 - 24
	Cs-137	0.1	1.5	56/64 0.1 - 6.8
	Ce-144	0.3	1.1	7/64 0.2 - 3
	ZrNb-95	0.05	0.3	13/64 0.1 - 2
	Ru-106 <sup>(b)</sup>	0.3	1.1	3/64 0.5 - 2
	Others			< LLD
Soil pCi/g (dry) (Core Samples)	Gross Alpha (0)	—	—	—
	Gross Beta (8)	1	21	8/8 16 - 28
	Sr-89 (8)	0.25		< LLD
	Sr-90 (8)	0.05	0.2	5/8 0.08 - 0.5
	Gamma (8)			
	K-40	1.5	13	8/8 7 - 20
	Cs-137	0.1	1.2	7/8 0.2 - 2.4
	Co-60	0.1	0.2	1/8 —
	Others			< LLD

TABLE V.A.3 (Page 3 of 4)  
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Shippingport Atomic Power Station Docket No. Not Applicable  
 Name of Facility Beaver Valley Power Station Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Level CI 1974 - 1975  
 (County, State)

## PRE-OPERATIONAL PROGRAM SUMMARY (COMBINED 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed	Lower Limit of Detection LLD	All Indicator Locations Mean, (f) Range		
Sediments pCi/g (dry)	Gross Alpha (0)	—			
	Gross Beta (33)	1	18	33/33	5 - 30
	Sr-90 (0)	—		—	
	U-234, 235, 238 (0)	—		—	
	Gamma (33)		13	33/33	2 - 30
	K-40	1.5	13	33/33	2 - 30
	Cs-137	0.1	0.4	21/33	0.1 - 0.6
	ZrNb-95	0.05	0.8	12/33	0.2 - 3.2
	Ce-144	0.3	0.5	3/33	0.4 - 0.7
	Ru-106 <sup>(b)</sup>	0.3	1.5	3/33	1.3 - 1.8
	Others				< LLD
Foodstuff pCi/g (dry)	Gamma (8)				
	K-40	1	33	8/8	10 - 53
	Cs-137	0.1	0.2	1/8	—
	ZrNb-95	0.05	0.2	1/8	—
	Ru-106 <sup>(b)</sup>	0.3	0.8	1/8	—
	Others				< LLD
Feedstuff pCi/g (dry)	Gross Beta (80)	0.05	19	80/80	8 - 50
	Sr-89 (81)	0.025	0.2	33/81	0.04 - 0.93
	Sr-90 (81)	0.005	0.4	78/81	0.02 - 0.81
	Gamma (81)				
	K-40	1	19	75/81	5 - 46
	Cs-137	0.1	0.5	6/81	0.2 - 1.6
	Ce-144	0.3	1.5	5/81	0.9 - 2.6
	ZrNb-95	0.05	0.8	13/81	0.2 - 1.8
	Ru-106 <sup>(b)</sup>	0.3	1.4	12/81	0.6 - 2.3
	Others				< LLD

TABLE V.A.3 (Page 4 of 4)  
 ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SUMMARY

Name of Facility Shippingport Atomic Power Station Docket No. Not Applicable  
 Name of Facility Beaver Valley Power Station Docket No. 50-334  
 Location of Facility Beaver, Pennsylvania Reporting Level CY 1974 - 1975  
 (County, State)

PRE-OPERATIONAL PROGRAM SUMMARY (COMBINED 1974 - 1975)

Medium or Pathway Sampled (Unit of Measurement)	Analysis and Total Number of Analysis Performed		Lower Limit of Detection LLD	All Indicator Locations Mean, (f) Range		
Milk pCi/l	I-131	(91)	0.25	0.6	<sup>4</sup> /91	0.3 - 0.8
	Sr-89	(134)	5	7	<sup>4</sup> /134	6 - 11
	Sr-90	(134)	1	5.3	<sup>132</sup> /134	1.5 - 12.8
	Gamma	(134)				
	Cs-137		10	13	<sup>19</sup> /134	11 - 16
	Others					< LLD
External Radiation mR/day	γ - Monthly	(599)	0.5 mR *	0.20	<sup>599</sup> /599	0.08 - 0.51
	γ - Quarterly	(195)	0.5 mR *	0.20	<sup>195</sup> /195	0.11 - 0.38
	γ - Annual	(48)	0.5 mR *	0.19	<sup>48</sup> /48	0.11 - 0.30
Fish pCi/g (wet)	Gross Beta	(17)	0.01	1.9	<sup>15</sup> /17	1.0 - 3.2
	Sr-90	(17)	0.005	0.14	<sup>17</sup> /17	0.02 - 0.50
	Gamma	(17)				
	K-40		0.5	2.4	<sup>17</sup> /17	1.0 - 3.7
	Other					< LLD

\* LLD in units of MR - Lower end of useful integrated exposure detectability range for a passive radiation detector (TLD).

- (a) One outlier not included in mean. (Water taken from dried-up spring with high sediment and potassium content. Not considered typical groundwater sample.)
- (b) May include Ru-106, Ru-103, Be-7.

DUQUESNE LIGHT COMPANY  
TABLE V.A. 4  
TYPICAL LLDs \* FOR GAMMA SPECTROMETRY

Nuclide	Milk Water (pCi/liter)	Air Particulates ( $10^{-3}$ pCi/m <sup>3</sup> )	Vegetation (pCi/kg dry)	Sediment & Soil (pCi/g dry)	Fish (pCi/g wet)
Be-7	30	20	50	0.03	0.05
K-40	60	20	**	**	**
Cr-51	40	10	100	0.05	0.1
Mn-54	3	0.5	30	0.02	0.03
Co-58	3	0.6	30	0.02	0.03
Fe-59	6	1	60	0.03	0.06
Co-60	3	0.6	30	0.02	0.03
Zn-65	8	1	70	0.04	0.07
Zr/Nb-95	5	2	50	0.03	0.05
Ru-103	3	2	40	0.03	0.04
Ru-106	30	5	30	0.02	0.03
Ag-110M	5	3	30	0.02	0.03
I-131	4	2	30	0.02	0.03
Te-132	4	2	20	0.01	0.02
I-133	4	2	20	0.01	0.02
Cs-134	4	0.6	30	0.02	0.03
Cs-136	6	0.6	50	0.03	0.05
Cs-137	4	0.6	20	0.02	0.03
Ba/La-140	10	6	40	0.02	0.04
Ce-141	6	2	60	0.03	0.06
Ce-144	30	5	200	0.1	0.2
Ra-226	60	6	600	0.3	0.6
Th-228	10	1	60	0.03	0.06

\* At time of analysis (D&C Contractor Lab).

\*\* Activity detected in all samples.

NOTE Lower Level of Detection is defined in Beaver Valley Power Station Technical Specifications.

V. ENVIRONMENTAL MONITORINGB. Air Monitoring1. Characterization of Air and Meteorology

The air in the vicinity of the site contains pollutants typical for an industrial area. Air flow is generally from the Southwest in summer and from the Northwest in the winter.

2. Air Sampling Program and Analytical Techniquesa. Program

The air is sampled for gaseous radioiodine and radioactive particulates at each of ten (10) off-site air sampling stations. The locations of these stations are listed in Table V.A.1 and shown on a map in Figure 5.B.1.

Samples are collected at each of these stations by continuously drawing about one cubic foot per minute of atmosphere air through a glass fiber filter and through a charcoal cartridge. The former collects airborne particulates; the latter is for radioiodine sampling. Samples are collected for analysis on a weekly basis.

The charcoal is used in the weekly analysis of airborne I-131. The filters are analyzed each week for gross beta, then composited by station for monthly analysis by gamma spectrometry. They are further composited in a quarterly sample from each station for Sr-89/90 analysis. In order to reduce interference from natural radon and thoron radioactivities, all filters are allowed to decay for a few days after collection prior to counting for beta in a low background counting system.

b. Procedures

Gross Beta analysis is performed by placing the filter paper from the weekly air sample in a 2" x 1/4" planchet and counting it in a low background, gas flow proportional counter.




Gamma emitters are determined by stacking all the filter papers from each monitoring station collected during the month and scanning this composite on a lithium drifted germanium (Ge(Li)) gamma spectrometer.

Radioiodine (I-131) analysis is performed by a gamma scan of the charcoal in a weekly charcoal cartridge. The activity is referenced to the mid-collection time.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

FIGURE 5.B.1

ENVIRONMENTAL MONITORING LOCATIONS— AIR SAMPLING LOCATIONS



V. ENVIRONMENTAL MONITORINGb. Procedures (continued)


Strontium-89 and Strontium-90 activities are determined in quarterly composited air particulate filters. Stable strontium carrier is added to the sample and it is leached in nitric acid to bring deposits into solution. The mixture is then filtered. Half of the filtrate is taken for strontium analysis and is reduced in volume by evaporation. Strontium is precipitated as  $\text{Sr}(\text{NO}_3)_2$  using fuming (90%) nitric acid. An iron (ferric hydroxide) scavenge is performed, followed by addition of stable yttrium carrier and a 5 to 7 day period for yttrium ingrowth. Yttrium is then precipitated as hydroxide, is dissolved and re-precipitated as oxalate. The yttrium oxalate is mounted on a nylon planchet and is counted in a low level beta counter to infer strontium-90 activity. Strontium-89 activity is determined by precipitating  $\text{SrCo}_3$  from the sample after yttrium separation. This precipitate is mounted on a nylon planchet and is covered with  $80 \text{ mg/cm}^2$  aluminum absorber for level beta counting.

3. Results and Conclusions

A summary of data is presented in Table V.A.2.

## a. Airborne Radioactive Particulates

A total of five hundred nineteen (519) weekly samples from ten (10) locations was analyzed for gross beta. One sample was not obtained due to theft of air monitoring equipment. Results were comparable to previous years. Figure 5.B.2 illustrates the average concentration of gross beta in air particulates.



V. ENVIRONMENTAL MONITORING

## a. Airborne Radioactive Particulates (continued)

The weekly air particulate samples were composited to one hundred and twenty (120) monthly samples which were analyzed by gamma spectrometry. Naturally occurring Be-7 was present in every sample. Occasional traces above detection levels of other nuclides were present. Some were natural, others were residual from previous nuclear weapons tests. These are listed in the summary Table V.A.2. Examination of effluent data from the Beaver Valley Power Station and the Shippingport Atomic Power Station demonstrated that none of the slightly elevated results are attributable to the operation of either power station.

A total of forty (40) quarterly samples were each analyzed for Sr-89, and Sr-90.

Based on the analytical results, the operation of Beaver Valley Power Station and Shippingport Atomic Power Station did not contribute to any increase in air particulate radioactivity during CY 1982.

## b. Radioiodine

A total of five hundred and nineteen (519) weekly charcoal filter samples were analyzed for I-131. One sample was not obtained due to theft of air monitoring equipment. No detectable concentrations were found at any locations.

Based on analytical results, the operation of Beaver Valley Power Station and Shippingport Atomic Power Station did not contribute to any increase in airborne radioiodine during CY 1982.

V. ENVIRONMENTAL MONITORINGC. Monitoring of Sediments and Soils1. Characterization of Stream Sediments and Soils

The stream sediments consist largely of sand and silt. Soil samples may vary from sand and silt to a heavy clay with variable amounts of organic material.

2. Sampling Program and Analytical Techniques

## a. Program

River bottom sediments were collected quarterly above the Montgomery Dam in the vicinities of the Beaver Valley discharge and Shippingport discharge and above the New Cumberland Dam. A Ponar or Eckman dredge is used to collect the sample. The sampling locations are also listed in Table V.A.1 and are shown in Figure 5.C.1.

Soil samples were collected at each of ten (10) locations during CY 1982. At each location 12 core samples (3" diameter by 2" deep) are gathered at prescribed points on a 10 foot radius circle. Each location is permanently marked with reference pins. Each set of samples is systematically selected by moving along the radius in such a manner as to assure representative undisturbed samples. Sampling locations are listed in Table V.A.1 and are shown in Figure 5.C.1.

Bottom sediments and soils are analyzed for gross alpha and beta activity, strontium, uranium, and the gamma-emitting radionuclides.

## b. Analytical Procedures

Gross beta - sediments and soils are analyzed for gross beta by mounting a 1 gram portion of dried sediment in a 2" planchet. The sample is counted in a low background, gas flow proportional counter. Self absorption corrections are made on the basis of sample weight.

Gross alpha activity of sediment or soil is analyzed in the same manner as gross beta except that the counter is set up to count only alpha.


Gamma analysis of sediment or soil is performed in a 100 ml plastic bottle which is counted by a gamma spectrometer.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

## SEDIMENTS AND SOILS

FIGURE 5.C.1

## ENVIRONMENTAL MONITORING LOCATIONS— SHORELINE SEDIMENTS &amp; SOIL





V. ENVIRONMENTAL MONITORING

## b. Analytical Procedures (continued)

Strontium 89 and 90 are determined by radiochemistry. A weighed sample of sediment or soil is leached with Nitric Acid HNO<sub>3</sub>. A stable carrier is added for determination of recovery. Strontium concentration and purification is ultimately realized by precipitations of strontium nitrate in fuming nitric acid. Additional hydroxide precipitations and barium chromate separations are also used. The purified strontium is converted to a carbonate for weighing and counting. Samples are counted soon after separation (5 - 7 days is allowed for yttrium ingrowth). Activities are calculated on the basis of appropriate Sr-89 decay and Y-90. Separate mounts covered with a 80 mg/cm aluminum absorber are used for counting in a low background beta counter.

Uranium isotopic analysis of sediment and soil samples were performed by alpha spectrometry after leaching and isolation of the uranium by anion exchange chromatography plus mercury cathode electrolysis, then electroplated onto a planchet.

3. Results and Conclusions

## a. Results

The results of sediment and soil analysis are summarized in Table V.A.2.

There were no significant differences between these current levels and those previously detected in both upstream and downstream sediment samples.



V. ENVIRONMENTAL MONITORING3. Results and Conclusions (continued)

## a. Results (continued)

Uranium isotopic analyses were performed by alpha spectroscopy. The results suggest that only naturally occurring U-234 and U-238 were present since the activities were nearly always the same in each sample and the levels are within the expected range of natural uranium activities. In equilibrium, U-234 and U-238 have the same activity.

## b. Conclusion

Other than a very small amount of Co-60 at the outfall of Beaver Valley Power Station, the sediment analyses do not indicate any increased radioactivity attributable to Beaver Valley Power Station. Since Shippingport Atomic Power Station did not release any radioactive liquid waste during 1982, it did not contribute to any changes in river sediment radioactivity. Small amounts of Cs-137 from weapons testing fallout was found in all river sediment samples including those upstream above Montgomery Dam which are unaffected by plant effluents.

Results of soil analysis are comparable to preoperational data.

V. ENVIRONMENTAL MONITORINGD. Monitoring of Feedcrops and Foodcrops1. Characterization of Vegetation and Foodcrops

According to a survey made in 1981, there were approximately 650 farms in Beaver County. The principle source of revenue for the farms was in dairy products which amounted to nearly \$4,659,000.00. Revenues from other farm products were as follows:

Crops	\$2,143,000.00
Horticulture	\$ 551,000.00
Meat	\$1,274,000.00
Poultry	\$ 392,000.00

The percentage of crop land in Beaver County is approximately 17%, pasture land - 6.5%, forest land - 47.8%, and other land uses - 28.7%.

2. Sampling Program and Analytical Techniquesa. Program


Representative samples of cattle feed are collected monthly from the nearest dairy (Searight). See Figure 5.D.1. Each sample is analyzed by gamma spectrometry. The monthly samples are composited into a quarterly sample which is analyzed for Sr-90.

Foodcrops (vegetables) were collected at garden locations during the summer of 1982. Cabbage and lettuce were obtained from Shippingport, Georgetown and Industry, PA, and from Weirton, WV. All samples were analyzed for gamma emitters (including I-131 by gamma spectrometry).

b. Procedures

Gamma emitters, including I-131, are determined by scanning a dried, homogenized sample with the gamma spectrometry system. A Ge(Li) detector is utilized with this system.

Strontium 90 analysis for feedstuff is performed by a procedure similar to that described in V.C.2.



V. ENVIRONMENTAL MONITORING3. Results and Conclusions

A summary of results is provided in Table V.A.2. The predominant isotope detected was naturally occurring K-40 in both food and feed. Other activity is attributable to residuals from previous nuclear weapons tests or naturally occurring radionuclides. All results were consistent with (or lower than) those obtained in the pre-operational program. These data confirm that Shippingport Atomic Power Station and Beaver Valley Power Station did not contribute to radioactivity in foods and feeds in the vicinity of the site.

V. ENVIRONMENTAL MONITORINGE. Monitoring of Local Cow's Milk1. Description - Milch Animal Locations

During the seasons that animals producing milk (milch animals) for human consumption are on pasture, samples of fresh milk are obtained from these animals at locations and frequencies noted in Table V.A.1. This milk is analyzed for its radioiodine content calculated as Iodine-131. The analyses are performed within eight (8) days of sampling.

Detailed field surveys are performed during the grazing season to locate and enumerate milch animals within a five (5) mile radius of the site. Goat herd locations out to fifteen (15) miles are identified. Survey data for the most recent survey conducted in July, 1982 is shown in Figure 5.E.1.

2. Sampling Program and Analytical Techniques

## a. Program

Milk was collected from three (3) reference dairy farms within a 10-mile radius of the site and from one (1) control location outside of the 10-mile radius. Additional dairies, which represent the highest potential milk pathway for radioiodine based on milch animal surveys and meteorological data were selected and sampled. These dairies are subject to change when more recent data (including census) indicate other locations are more appropriate. The location of each is shown in Figure 5.E.2 and described below.

<u>Site</u>	<u>Dairy</u>	<u>Number of Milch Animals</u>	<u>Distance and Direction From Site</u>	<u>Collection Period</u>
25	Searight	41 Cows	2.1 miles-south/sw.	Jan. - Dec.
27	Brunton	105 Cows	7.3 miles-southeast	Jan. - Dec.
29A	Nichol	55 Cows	8.0 miles-northeast	Jan. - Dec.
96	Windsheimer	50 Cows	10.3 miles-south/sw.	Jan. - Dec.
61	Allison	33 Cows	3.2 miles-west/sw.	Jan.-June,Dec.
62	Lyon	20 Cows	3.3 miles-west/sw.	Jan. - Mar.
66	Straight	1 Cow*	3.1 miles-south/se.	Jan. - Feb.
69	Collins	9 Goats, 1 Cow*	3.6 miles-southeast	Feb. - Dec.

## SECTION V - E

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report


<u>Site</u>	<u>Dairy</u>	<u>Number of Milch Animals</u>	<u>Distance and Direction From Site</u>	<u>Collection Period</u>
97	Douglass	2 Goats*	1.9 miles-southwest	April - Aug.
98	Foxall (Hammond)	2 Goats*	2.9 miles-east	July - Nov.
99	Lampich	7 Goats	4.1 miles-east/se.	Aug. - Dec.

\*Milk Usage - Home Only.

DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report

FIGURE 5.E.1

Cow &amp; Goat Survey - Summer, 1982





## FIGURE 5.E.2





V. ENVIRONMENTAL MONITORINGE. Monitoring of Local Cow's Milk (continued)

## a. Program (continued)

The sample from Bearright Dairy was collected and analyzed weekly for radioiodine using a procedure with a high sensitivity. Samples from each of the other selected dairies were collected monthly when cows are indoors, and bi-weekly when cows are grazing. This monthly or bi-weekly sample is analyzed for Sr-89, Sr-90, gamma emitters including Cs-137 (by Spectrometry) and I-131 (high sensitivity analysis).

## b. Procedure

Radioiodine (I-131) analysis in milk was normally performed using chemically prepared samples and analyzed with a beta-gamma coincidence counting system.

Gamma emitters are determined by gamma spectrometry of a one liter Marinelli container of milk.

Strontium analysis of milk is similar to that of other foods (refer to V.C.2) except that milk samples are prepared by addition of Trichloroacetic Acid (TCA) to produce a curd which is removed by filtration and discarded. An oxalate precipitate is ashed for counting.

3. Results and Conclusions

A total of one hundred and fifty-two (152) samples were analyzed for I-131 during 1982. All I-131 activities in milk were below the minimum detectable level (0.3 pCi/l).

A total of one hundred and nineteen (119) samples were analyzed by gamma spectrometry and for strontium. Both the Cs-137 and Sr-90 levels were within the normally expected range. The higher levels from China's nuclear tests which were experienced in other years were absent this year. Such tests were not performed during 1982. Based on analytical results, the operation of Beaver Valley Power Station and Shippingport Atomic Power Station did not contribute to any increase in airborne radioiodine in CY 1982.

V. ENVIRONMENTAL MONITORINGF. Environmental Radiation Monitoring1. Description of Regional Background Radiation Levels and Sources

The terrain in the vicinity of the Shippingport and Beaver Valley Power Station generally consists of rough hills with altitude variations of 300 to 400 feet. Most of the land is wooded.

The principal geologic features of the region are nearly flat-lying sedimentary beds of the Pennsylvania Age. Beds of limestone alternate with sandstone and shale with abundant interbedded coal layers. Pleistocene glacial deposits partially cover the older sedimentary deposits in the northwest. Most of the region is underlain by shale, sandstone, and some coal beds of the Conemaugh Formation. Outcrops of sandstone, shale, and limestone of the Allegheny Formation exist within the Ohio River Valley and along major tributary streams.


Based on surveys reported in previous annual reports, exposure rates ranged from 6 to 12  $\mu$ R/hr. Results for 1982 indicated that background radiation continued in this range.

2. Locations & Analytical Procedures


Ambient external radiation levels at the site were measured using thermoluminescent dosimeters (TLDs). There were three (3) types used in the Duquesne Light Company Radiological Environmental Monitoring Program. They are calcium sulphate dysprosium,  $\text{CaSO}_4$  (Dy) in teflon matrix, lithium fluoride (LiF), and thulium activated calcium sulfate ( $\text{CaSO}_4$ :Tm).

The lithium fluoride TLDs were posted and analyzed by a laboratory of the Department of Energy (DOE) as an independent check of environmental radioactivity levels. The  $\text{CaSO}_4$ :Tm TLDs were used as a back-up and as a QC program. In 1982 there were a total of forty-four (44) off-site environmental TLD locations. The locations of the TLDs are shown in Figures 5.F.1 thru 4. Comparisons of TLD results are presented in Table III.1.


DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report




DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report



DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report



DUQUESNE LIGHT COMPANY  
1982 Annual Radiological Environmental Report





V. ENVIRONMENTAL MONITORING2. Locations & Analytical Procedures (continued)

The lithium fluoride (LiF) TLDs used for environmental purposes are pre-selected and annealed at least 5 working days prior to use. The radiation dose accumulated from the anneal date to the date of posting is accounted for utilizing background readings from five (5) TLD chips which are processed within 24 hours of the posting date. The calibration of the TLD reader is performed within 24 hours of processing the posted environmental TLDs. The environmental TLDs are processed after retrieval and a background correction is made to account for the background radiation accumulated from the date of retrieval to the date of processing.

The calcium sulfate ( $\text{CaSO}_4:\text{Dy}$ ) TLDs were annealed shortly before placing the TLDs in their field locations. The radiation dose accumulated in-transit between the field location and the laboratory was corrected by annealing control dosimeters shortly before the field dosimeters were removed from the field location, then shipping the freshly annealed control dosimeters with the exposed field dosimeters to the laboratory for readout at the same time. All dosimeters were exposed in the field in a special environmental holder. The dosimetry system was calibrated by reading calcium sulfate dosimeters which have been exposed in an accurately known gamma radiation field.

3. Results and Conclusions

Data obtained with the contractor TLD ( $\text{CaSO}_4:\text{Dy}$  in teflon) during 1982 are summarized in Table V.A.2, and the quality control TLD results are listed in Table III.1.

The annual exposure rate of all off-site TLD's averaged 0.18 mR/day in 1982. As in previous years, there was some variation among locations and seasons as would be expected.

In 1982, ionizing radiation dose determinations averaged approximately 66 mR for the year. This is comparable to previous years. There was no evidence of anomalies that could be attributed to the operation of either Beaver Valley Power Station or Shippingport Atomic Power Station. Three sets of TLDs of different types, each provided and analyzed by a separate laboratory, demonstrate good agreement and confirm that changes from natural radiation levels, if any, are negligible.

Lessons learned from the Three Mile Island incident indicated the need for more radiation monitors in all sectors surrounding the plant. Engineering and procurement are in progress for 16 Reuter-Stokes Pressurized Ion Chamber environmental radiation monitors to be used to circle the plant site, one in each of the 16 sectors. Installation of the remote monitors for system operation which was begun in 1981 was completed in 1982 and the monitors were placed in service. Installation of the central processing controller into the Emergency Response Facility is expected to be completed in 1983 which will permit the monitors to be read out at a central location. Engineering is also in progress to upgrade and modify the BVPS meteorological system to meet requirements in U.S. NRC Regulatory Guide 1.23, Rev. 1, and U.S. NUREG-0654, Appendix 2. The Reuter Stokes radiation monitors and the upgraded meteorological system will be tied into a new computer network to help meet some of the requirements set forth in U.S. NRC NUREG-0654 (Criteria for Preparational Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants) and U.S. NRC NUREG-0737 (TMI Action Plan Requirements). The complete meteorological system modifications and new computer network are currently scheduled to be operational by December 1983.



V. ENVIRONMENTAL MONITORINGG. Monitoring of Fish1. Description

Fish collected near the site are generally scrap fish. During 1982, fish collected for the radiological monitoring program included carp, catfish, and crappie bass.

2. Sampling Program and Analytical Techniques

## a. Program

Fish samples are collected semi-annually in the New Cumberland pool of the Ohio River at the Beaver Valley and Shippingport effluent discharge points and upstream of the Montgomery Dam. The edible portion of each different species caught is analyzed by gamma spectrometry. Fish sampling locations are shown in Figure 5.G.1.

## b. Procedure

A sample is prepared in a standard tared 300 ml plastic bottle and scanned for gamma emitting nuclides with gamma spectrometry system which utilizes a Ge(Li) detector.

3. Results and Conclusions

A summary of the results of the fish monitoring data is provided in Table V.A.2. Three (3) fish were caught in April and May. Two (2) more samples were caught in October. Except for naturally occurring K-40, the only gamma emitter which was detected in any samples was a trace of Cs-137 in one sample. Cesium-137 is a long lived fission product and some residual activity persists from previous weapons testing programs. This indicates that the operation of the Shippingport Atomic Power Station and the Beaver Valley Power Station has not resulted in radioactivity in fish in the Ohio River.




FIGURE 5.G.1

V. ENVIRONMENTAL MONITORINGH. Monitoring of Surface, Drinking, and Well Waters1. Description of Water Sources

The Ohio River is the main body of water in the area. It is used by both the Beaver Valley and Shippingport plants for water make-up and receiving plant liquid effluents. In addition, river water is used for cooling purposes at the Shippingport Atomic Power Station and make-up for the cooling tower at the Beaver Valley Power Station.

Ohio River water is a source of water for some towns both upstream and downstream of the Beaver Valley and Shippingport plant sites. It is used by several municipalities and industries downstream of the site. The nearest user of the Ohio River as a potable water source is Midland Borough Municipal Water Authority. The intake of the treatment plant is approximately 1.5 miles downstream and on the opposite side of the river. The next downstream users are East Liverpool, Ohio, and Chester, West Virginia, which are approximately 6 and 7 miles downstream, respectively. The heavy industries in Midland, as well as others downstream use river water for cooling purposes. Some of these plants also have private treatment facilities for plant sanitary water.

Ground water occurs in large volumes in the gravel terraces which lie along the river, and diminishes considerably in the bedrock underlying the site. Normal well yields in the bedrock are less than 10 gallons per minute (gpm) with occasional wells yielding up to 60 gpm.

2. Sampling and Analytical Techniquesa. Surface (Raw River) Water

The sampling program of river water includes six (6) sampling points along the Ohio River. Raw water samples are normally collected at the East Liverpool (Ohio) Water Treatment Plant [River Mile 41.2] daily and composited into a monthly sample. Weekly grab samples are taken from the Ohio River at the following locations: Upstream of Montgomery Dam [River Mile 31.8]; at discharge from Shippingport Atomic Power Station [River Mile 34.8]; and near the discharge from the Beaver Valley Power Station [River Mile 35.0]. Two automatic river water samplers are at the following locations: Upstream of Montgomery Dam [River Mile

29.6]; and at Crucible Steel's river water intake [River Mile 36.2]. The automatic sampler takes a 20 ml to 40 ml sample every 15 minutes and is collected on a weekly basis. The weekly grab samples and automatic water samples are composited into monthly samples from each location. In addition, a quarterly composite sample is prepared for each sample point.

The monthly composites are analyzed for gross alpha, gross beta, and gamma emitters. The quarterly composites are analyzed for tritium (H-3), strontium 89 (Sr-89), strontium 90 (Sr-90), and cobalt 60 (Co-60) (high sensitivity).

Locations of each sample point are shown in Figure 5.H.1.

b. Drinking Water (Public Supplies)

Drinking (treated) water is collected at both Midland (PA) and East Liverpool (OH) Water Treating Plants. An automatic sampler at each location collects 20-50 milliliters every 20 minutes. These intermittent samples are then composited into a weekly sample. The weekly sample from each location is analyzed by gamma spectrometry. The weekly samples are also analyzed for radioiodine (I-131).

Monthly composites of the weekly samples are analyzed for gross alpha, gross beta, and by gamma spectrometry. Quarterly composites are analyzed for H-3, Sr-89, Sr-90 and Co-60 (high sensitivity). Locations of each sample point are shown in Figure 5.H.1.

c. Ground Water

Grab samples were collected each quarter from each of four (4) well locations (see Figure 5.H.1) within four (4) miles of the site. These locations are:


One (1) well at Shippingport, PA

One (1) well at Meyer's Farm (Hookstown, PA)

One (1) well in Hookstown, PA

One (1) well in Georgetown, PA

Each groundwater sample is analyzed for gross alpha, gross beta, tritium, and by gamma spectrometry.



V. ENVIRONMENTAL MONITORING2. Sampling and Analytical Techniques (continued)

## d. Procedure

Gross alpha and gross beta activities are determined first by evaporating one liter of the sample on a hotplate. The residue is mounted and dried on a 2-inch stainless steel planchet. The sample is counted in a low background, gas flow proportional counter. Self-absorption corrections are made on the basis of sample weight.

Gamma analysis is performed on water sample by loading one liter of sample into a one liter marinelli container and counting on a Ge(Li) gamma spectrometry system.

Strontium-89 and 90 are determined on water samples by a procedure similar to that described in V.C.2 except that the leaching step is eliminated.

Cobalt-60 is determined with a sensitivity of 1 pCi/l by evaporating 2 liters of sample on a hotplate and transferring the residue to a 2-inch planchet. The planchet is counted on a Ge(Li) spectrometry system.

Tritium is determined in water samples by converting 2 ml of the sample to hydrogen and counting the activity in a 1 liter low level gas counter which is operated in the proportional range in anti-coincidence mode.

3. Results and Conclusions

A summary of results of all analyses of water samples (surface, drinking, and ground) are provided by sample type and analysis in Table V.A.2. These are discussed below.

## a. Surface Water

A total of seventy-two (72) samples were each analyzed for gross alpha, gross beta, and gamma activity. Twenty-four (24) quarterly composited samples were analyzed for tritium (H-3) and radiostrontium (Sr-89 and Sr-90) as well as a high sensitivity analysis for Co-60.



V. ENVIRONMENTAL MONITORING3. Results and Conclusions (continued)

No Sr-90, Sr-89, or Co-60 were detected in surface water during CY 1982. All alpha and beta activities were within normal range. The only gamma emitter detected was the naturally occurring radionuclide of Ra-226 which was detected in one sample.

The tritium levels in Beaver Valley Power Station outfall were elevated above preoperational levels during the third and fourth quarters, but none of these data suggests detectable increases over preoperational levels downstream of the station. The tritium activity at the Beaver Valley Power Station outfall is consistent with station data of authorized radioactive discharges from Beaver Valley Power Station and were well within limits permitted by NRC license.

No detectable increase in radioactivity in the Ohio River can be attributed to Shippingport Atomic Power Station since it did not discharge radioactive liquids during 1982.

b. Drinking Water

A total of twenty-four (24) samples were analyzed for gross alpha and gross beta. All results were within preoperational data ranges.

A total of eight (8) samples were analyzed for tritium (H-3), radiostrontium (Sr-89 and Sr-90), and cobalt (Co-60). No Sr-89, Sr-90, or Co-60 were detected. The tritium data were within the preoperational range indicative of normal environmental levels.

A total of another one-hundred and four (104) samples were analyzed by gamma spectrometry. No gamma emitting radionuclides were detected by these analyses.



V. ENVIRONMENTAL MONITORING3. Results and Conclusions (continued)

A total of one hundred and four (104) samples were analyzed for radioiodine (I-131) using a highly sensitive technique. A detectable level of I-131 was measured in one (1) weekly sample collected on May 11, 1982, at Midland. The result of 0.25 pCi/liter for this sample is only slightly above the minimum detectable activity of 0.2 pCi/liter. This positive result could not be attributed to station discharges. The result may be attributed to expected variability in the analyses results of very low levels of activity. In addition, surface water analysis for the same period did not indicate the presence of I-131.

## c. Well Water

A total of sixteen (16) samples were each analyzed for gross alpha, gross beta, tritium and by gamma spectrometry. No alpha activity was detected in any of the samples. The gross beta and tritium data are within preoperational ranges.

## d. Summary

The data from water analyses demonstrate that neither Beaver Valley Power Station nor Shippingport Atomic Power Station contributed a significant increase of radioactivity in local river, drinking or well waters. The few positive results which could be attributable to authorized releases from Beaver Valley Power Station are characteristic of the effluent. These results confirm that the station assessments, prior to authorizing radioactive discharges, are adequate and that the environmental monitoring program is sufficiently sensitive.

Further, the maximum detected activity attributable to Beaver Valley Power Station was only a small fraction (1.26%) of the concentration (averaged over a year) permitted by the Federal Regulations for water consumed by the public. The Ohio River further reduced this concentration prior to its potential use by members of the public.

V. ENVIRONMENTAL MONITORINGI. Estimates of Radiation Dose to Man1. Pathways to Man - Beaver Valley Power Stationa. Calculational Models - Beaver Valley Power Station

The radiation doses to man as a result of Beaver Valley operations were calculated for both gaseous and liquid effluent pathways using NRC computer codes XOQDOQ2, GASPAR, and LADTAP. Dose factors listed in Beaver Valley Power Station Environmental Technical Specifications were used to calculate doses to maximum individuals from radioactive noble gases in discharge plumes. Beaver Valley effluent data, based on sample analysis in accordance with the schedule set forth in Appendix B of the BVPS license, were used as the radionuclide activity input.

Each radionuclide contained in the semi-annual effluent report format of Regulatory Guide 1.21 was considered. Certain radionuclides which were not detected in the effluents were not included in dose calculations when the inventory of such nuclides available for discharge was judged to be negligible. As a result, only noble gases, radioiodines, strontium, and tritium were included as source terms based on the lower detectable limits of analysis (all sensitivities for analysis at Beaver Valley were equal to or better than required by the Beaver Valley license).

All gaseous effluent releases, including Auxiliary Building Ventilation, were included in dose assessments. The release activities are based on laboratory analysis. When the activity of noble gas was below detection sensitivity, either the inventory based on its MDL or an appropriate but conservative ratio to either measured activity of Kr-85 or Xe-133 was used. Meteorological data collected by the Beaver Valley Power Station Meteorology System was used as input to XOQDOQ2 which in turn provided input for GASPAR. Except when more recent or specific data was available, all inputs were the same as used in the Beaver Valley Power Station Environmental Statements or in Regulatory Guide 1.109. The airborne pathways evaluated were beta and gamma doses from noble gas plumes inhalation, the "cow-milk child", and other ingestion pathways.

V. ENVIRONMENTAL MONITORINGa. Calculational Models - Beaver Valley Power Station  
(continued)

All potentially radioactive liquid effluents, including steam generator blowdown, are released by batch mode after analysis by gamma spectrometry using a GeLi detector. Each batch is diluted by cooling tower blowdown water prior to discharge into the Ohio River at the Beaver Valley Power Station outfall (River Mile 35.0). The actual data from these analyses are tabulated and used as the radionuclide activity input term in LADTAP. The maximum individual for liquid pathways is located at Midland. Except when more recent or specific data for the period is available, all other input to LADTAP are obtained from the Beaver Valley Power Station Environmental Statement or Regulatory Guide 1.109. Pathways, which were evaluated, are drinking water, fish consumption, shoreline recreation, swimming, and boating.

2. Results of Calculated Radiation Dose to Man - Beaver Valley Power Station Liquid Releasesa. Liquid Pathway - Maximum Individual

The doses which are calculated, based on the model presented above in V.I.1, are summarized and compared to Beaver Valley Power Station license limits below. An additional breakdown of these doses by pathway and organ is provided in Table V.I.1. For these calculations, a hypothetical maximum individual(s) was located at Midland since this is the nearest location which significant exposure of a member of the public could potentially occur.

TABLE V.I.1  
 1982 Radiation Dose to Maximum Individual<sup>a</sup>, mrem/yr.  
 Beaver Valley Power Station - Liquid Releases

<u>PATHWAY</u>	<u>CRITICAL GROUP</u>	<u>USAGE FACTOR</u>	<u>SKIN</u>	<u>ORGAN</u>	<u>THYROID</u>	<u>BONE</u>	<u>WHOLE BODY</u>
Fish Consumption <sup>b</sup>	Adult	21.0 kg	N/A	0.0409 (Liver)	0.00451	0.0239	0.0301
Drinking Water <sup>c</sup>	Infant	510 l	N/A	0.0235 (Liver)	0.0684	0.00252	0.0212
Shoreline Activities	Teen	67 hr.	0.0027	--	--	--	0.0023
TOTAL	MREM CRITICAL INDIVIDUAL		0.0027 (Teen)	0.0542 (Adult) (Liver)	0.0684 (Infant)	0.0312 (Child)	0.0433 (Adult)

DOSE TO INDIVIDUALS DURING 1982 FROM NATURAL RADIATION EXPOSURE

Ambient Gamma Radiation:	69 <sup>d</sup>
Radionuclides in Body :	18 <sup>e</sup>
Global Fallout :	4 <sup>e</sup>
TOTAL mrem :	91

<sup>a</sup> Located at Midland Drinking Water Intake

<sup>b</sup> Child - Usage Factor 6.9 kg/yr.

<sup>c</sup> Adult - Usage Factor 730 l/yr.

<sup>d</sup> Pre-operational average ambient gamma radiation

<sup>e</sup> National Academy of Sciences, "The Effects on Populations of Exposure to Low Levels of Ionizing Radiation:", BEIR Report, 1972.

V. ENVIRONMENTAL MONITORING2. Results of Calculated Radiation Dose to Man - Beaver Valley Power Station Liquid Releases (continued)

Actual Doses (mrem/yr.) - Calculated Using Site Effluents Appendix I \* Analysis Dose - Calculated Using NRC Model Effluents Regulatory Limit Doses - NRC Staff Guidelines RM50-2

	Calculated (1.21 Re- ported Re- leases)	Appendix I Report (Con- servative Non-accident Doses)	RM50-2 (Re. Limit w/o Cost/Benefit Analysis)	Ratio of Calculated Dose vs. Reg. Limit
<u>TOTAL BODY</u>				
Adult	0.0433	2.78	5.0	0.00866
Teen	0.0243	0.712	5.0	0.00486
Child	0.0208	Not Reported	5.0	0.00416
Infant	0.0212	Not Reported	5.0	0.00424
<u>ANY ORGAN</u>				
Adult	0.0542 (Liver)	Not Reported	5.0	0.01084
Teen	0.0486 (Liver)	Not Reported	5.0	0.00972
Child	0.0505 (Liver)	Not Reported	5.0	0.0101
Infant	0.0684 (Thyroid)	Not Reported	5.0	0.01368

Maximum Total Body Dose - Capsule Summary

	mrem
1982 Calculated	0.0433
Appendix I Estimated	2.78
Final Environmental Statement	0.112

Thyroid Dose - (Largest Expected Organ Dose)

1982 Calculated	0.0684
Final Environmental Statement	0.96

\* 10 CFR 50 Appendix I

V. ENVIRONMENTAL MONITORING2. Results of Calculated Radiation Dose to Man - Beaver Valley Power Station Liquid Releases (continued)b. Population Doses

The 1982 calculated dose to the entire population of almost 4 million people within 50 miles of the plant was:

	<u>Man-Millirem</u>	<u>Largest Isotope Contributors</u>		
TOTAL BODY	159.0	H-3	148	mrem
		Co-60	5.14	mrem
		Cs-134	2.69	mrem
THYROID	281.0	H-3	148	mrem
		I-131	130	mrem

3. Airborne Pathway - (Beaver Valley Power Station)

The doses to the public for Beaver Valley Power Station airborne radioactive effluents during 1982 are provided in Table V.I.2. They include the contribution of all pathways. Tritium is the primary radionuclide contribution to these doses. The data demonstrate compliance with 10CFR50, Appendix I design objective limits.

4. Conclusions - (Beaver Valley Power Station)

Based upon the estimated dose to individuals from the natural background radiation exposure in Table V.I.1., the incremental increase in total body dose to the 50-mile population (4 million people), from the operation of Beaver Valley Power Station - Unit No. 1, is less than 0.0001% of the annual background.

The calculated doses to the public from the operation of Beaver Valley Power Station - Unit NO. 1 are below 10CFR50, Appendix I design objectives, and resulted in only a small incremental dose to that which area residents already received as a result of natural background. The doses constituted no meaningful risk to the public.

TABLE V.I.2

Results of Calculated Radiation Dose to Man (1982)  
Beaver Valley Power Station - Airborne Radioactivity

<u>ORGAN</u>	<u>MAXIMUM EXPOSURE INDIVIDUAL, mrem</u>	<u>APPENDIX I* DESIGN OBJECTIVE mrem</u>	<u>PERCENT OF APPENDIX I</u>	<u>50-MILE POPULATION DOSE man rem</u>
TOTAL BODY	0.0625	5	1.25%	0.135
SKIN	0.160	15	1.07%	0.472
LUNG	0.0654	--	--	0.149
THYROID	1.760	--	--	0.430

\* 10CFR50, Appendix I

V. ENVIRONMENTAL MONITORING5. Dose Pathways to Man - Shippingport Atomic Power Station

The radiation doses to man as a result of operations at the Shippingport Atomic Power Station during 1982 were calculated for gaseous effluent pathways. There were no radioactive liquid discharges from the Shippingport Atomic Power Station during 1982.

Effluent monitoring at the Shippingport Station during 1982 has shown that the radioactivity releases were substantially below the Federal radioactivity concentration guides. The environmental monitoring program has demonstrated that the radiation exposure to the general public from the Shippingport Station operations was too low to measure and could only be estimated with the calculational models described below using measured or estimated effluent radioactivity data.

a. Calculational Models - Shippingport Atomic Power Station

The radiation doses to man from Shippingport Atomic Power Station operations were estimated using calculational models recommended by the International Commission on Radiological Protection (ICRP Publ. 2, 1959) and employ the general guidelines of the Nuclear Regulatory Commission (Regulatory Guide 1.109) established to maintain compliance with 10CFR50 Appendix I.

The air dose pathways considered were inhalation, immersion in gaseous and suspended particulate activity, and the ingestion of food and milk produced in the Shippingport vicinity. It was conservatively assumed that food products consumed by the public were produced in the Shippingport area throughout CY 1982. The maximum potentially exposed individual for the air pathways was located at the site boundary. It was conservatively assumed that the maximum individual resides continually at the site boundary.



V. ENVIRONMENTAL MONITORING5. Dose Pathways to Man - Shippingport Atomic Power Station  
(continued)

Modeling parameters and usage factors used in the pathway calculations were consistent with values recommended by the Nuclear Regulatory Commission (NRC Regulatory Guide 1.109). The population distribution within 50 miles of the site was based on census data as provided in the LWBR Program Environmental Impact Statement (ERDA 1541). Furthermore, the air pathway calculation employed site-specific meteorological and wind direction data.

6. Results and Conclusions - Shippingport Atomic Power Station

Evaluation of the radiation dose-to-man calculations for the airborne effluents show that the maximum annual radiation exposure potentially received by an individual residing at the site boundary is less than 0.1 mrem. The maximum dose to an individual is well below the 10CFR50 Appendix I dose limits. Furthermore, the radiation exposure to the entire population of 4 million persons within 50 miles of the Shippingport Station was less than 1 person-rem. This dose is negligible compared to the typical general use of approximately 360,000 person-rem received by all individuals from typical background radiation.

In conclusion, the radiation exposure received from the Shippingport Station during CY 1982 by any member of the general public is a very small fraction of the background radiation and has, therefore, no significant effect on the general public.

DISTRIBUTION LIST

United States Nuclear Regulatory Commission (18 copies)  
Attn: Mr. David Wigginton, Project Manager  
Operating Reactors Branch No. 1  
Division of Licensing  
c/o Document Control Desk  
Washington, DC 20555

Mr. R. C. Haynes, (2 copies)  
Regional Administrator  
United States Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Mr. Nicholas DeBenedictis, Secretary  
Department of Environmental Resources  
Commonwealth of Pennsylvania  
9th Floor, Fulton Building  
Third and Locust Streets  
Harrisburg, PA 17105

Mr. C. K. Gaddis, Manager  
Pittsburgh Naval Reactors Office  
United States Department of Energy  
Post Office Box 109  
West Mifflin, PA 15122-0109

Admiral K. R. McKee  
Deputy Assistant Secretary for Naval Reactors  
United States Department of Energy  
Washington, DC 20585

Mr. D. E. Patterson, Director  
Division of Operational and Environmental Safety  
United States Department of Energy  
Washington, DC 20013

United States Department of Energy  
Headquarters Library  
Washington, DC 20013

United States Department of Energy  
Technical Information Center  
Post Office Box 62  
Oak Ridge, TN 37830

J. M. Arthur, Chairman of the Board  
and Chief Executive Officer  
Duquesne Light Company  
One Oxford Centre  
301 Grant Street  
Pittsburgh, PA 15279

DISTRIBUTION LIST (continued)

J. J. Carey  
Vice President - Nuclear  
Duquesne Light Company  
P.O. Box 4  
Shippingport, PA 15077

E. J. Woolever  
Vice President,  
Nuclear Construction Division  
Duquesne Light Company  
One Oxford Centre  
301 Grant Street  
Pittsburgh, PA 15279

H. A. VanWassen  
Project Manager, Beaver Valley Power Station  
Duquesne Light Company  
One Oxford Centre  
301 Grant Street  
Pittsburgh, PA 15279

J. D. Sieber  
Manager, Nuclear Safety & Licensing Department  
Duquesne Light Company  
P.O. Box 4  
Shippingport, PA 15077

T. D. Jones  
Manager, Nuclear Operations  
Duquesne Light Company  
P.O. Box 4  
Shippingport, PA 15077

S. L. Pernick  
Manager of Environmental Affairs  
Duquesne Light Company  
One Oxford Centre  
301 Grant Street  
Pittsburgh, PA 15279

C. E. Ewing  
Manager, Quality Assurance  
Duquesne Light Company  
Beaver Valley Power Station  
P.O. Box 186  
Shippingport, PA 15077

W. F. Wirth  
Director Radiological Safety Programs  
Duquesne Light Company  
Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 15077