

## LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M T D C C 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 3001 REPORT SOURCE L 6 0 5 0 0 0 0 3 1 5 7 0 4 0 7 8 3 8 0 5 0 4 8 3 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

01 2 WHILE ATTEMPTING TO EXIT UPPER CONTAINMENT (DURING NORMAL OPERATIONS), IT WAS DIS-  
01 3 COVERED THAT THE OUTER DOOR OF THE PERSONNEL AIRLOCK WOULD NOT OPEN. THE INTERLOCK  
01 4 CABLE HAD TO BE DISCONNECTED TO ALLOW PERSONNEL TO EXIT THE CONTAINMENT. THIS CON-  
01 5 DITION WAS NONCONSERVATIVE WITH RESPECT TO T.S.3.6.1.3. ACTION REQUIREMENTS WERE  
01 6 MET. PUBLIC HEALTH AND SAFETY WAS NOT AFFECTED. PREVIOUS OCCURRENCES: 50-315,  
01 7 79-004, 83-031, 81-042, 83-019; DOCKET NO. 50-316, 78-014, 78-066, 79-016, 79-031.

01 8 9 30

01 9 SYSTEM CODE S A 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE P E I N E I T R 14 COMP. SUBCODE A 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

01 17 LER/RO REPORT NUMBER 8 3 21 22 23 24 25 26 27 28 29 30 31 32  
01 18 ACTION TAKEN A 18 FUTURE ACTION F 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER W 3 1 0 0 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

01 1 THE EXISTING INTERLOCK CABLE WAS OUT OF ADJUSTMENT AND COULD NOT BE ADJUSTED TO A  
01 2 SATISFACTORY CONDITION. THE CABLE WAS REPLACED, INTERLOCKS WERE TESTED, AND THE  
01 3 AIRLOCK WAS DECLARED OPERABLE IN 1HR. 16 MINS. A DESIGN CHANGE WILL BE INSTALLED TO  
01 4 INCREASE THE RELIABILITY OF THE INTERLOCK SYSTEM. RFC-DC-12-1874

01 5 9 30

01 6 FACILITY STATUS E 28 % POWER 1 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

01 7 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

01 8 PERSONNEL EXPOSURES NUMBER 0 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

01 9 PERSONNEL INJURIES NUMBER 0 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

01 10 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

01 11 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER PAUL CARTEAUX

PHONE: 616-465-5901

8305120399 830504  
PDR ADOCK 05000315  
S PDR

NRC USE ONLY