



**Wisconsin Electric** POWER COMPANY  
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

May 4, 1983

Mr. J. G. Keppler, Regional Administrator  
Office of Inspection and Enforcement,  
Region III  
U. S. NUCLEAR REGULATORY COMMISSION  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

DOCKET NOS. 50-266 AND 50-301  
FURTHER RESPONSE TO IE BULLETIN 79-14  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

IE Bulletin 79-14 requires licensees to verify that the as-built, safety-related piping systems conform to the as-designed seismic analysis and acceptance criteria. This letter is our twelfth submittal regarding IE Bulletin 79-14 and supplements our previous responses.

The present status of our program and the actions planned for completion of work in response to IE Bulletin 79-14 are as follows:

1. All of the mechanical corrections generated by the analyses have been installed with the exception of two corrections which require welding to the residual heat removal piping during unit outages. The mechanical correction for Unit 2 will be made in June 1983 during the current refueling outage, and the Unit 1 mechanical correction will be installed during Unit 1's refueling outage beginning October 1983.
2. All isometric drawings, with the exception of the two applicable to the mechanical corrections identified in (1) above, have been completed. The two isometrics remaining will be revised and reissued following installation of the last mechanical corrections.

-1-

8305120408 830504  
PDR ADOCK 05000266  
Q PDR

IEH  
MAY 6 1983

Mr. J. G. Keppler


-2-

May 4, 1983

Based on the above, we expect to issue our next report after completion of the remaining action items, around December 1983. This report will summarize our activities on the IE Bulletin 79-14 program and act as our final report.

If you require any additional information at this time, please contact us.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'Sol Burstein', with a stylized, flowing script.

Executive Vice President

Sol Burstein

Copy to NRC Resident Inspector