

THE CINCINNATI GAS & ELECTRIC COMPANY



April 29, 1983
LOZ-83-0022

J. WILLIAMS, JR.
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM M-72, LACK OF QA PROGRAM
FOR FIRE PROTECTION SYSTEM INSTALLATION
W.O. 57300, JOB E-5590, FILE NO. 956C, M-72

This letter constitutes an interim report concerning the subject condition initially reported to the Commission as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

Sargent & Lundy (S&L) has completed a review of the commitments which The Cincinnati Gas & Electric Company (CG&E) made relative to BTP-APCSB 9.5-1 Appendix A, Part C, Quality Assurance Program, and the manner in which these were implemented and documented. The CG&E Nuclear Engineering and Quality Assurance Departments are evaluating the S&L report to determine those actions necessary to meet the quality assurance requirements of the fire protection program.

The documentation concerning installation and testing of the fire protection system is not complete. Therefore, CG&E has requested that S&L develop a sampling program for CG&E implementation to assure that the fire protection system was installed, and will function, as designed. This program is scheduled to be submitted to CG&E for review by May 20, 1983.

Resolution of this problem, including a projected completion date of required corrective actions, will be determined after completing the above tasks. A follow-up report on the status of these actions will be submitted by August 1, 1983.

8305120410 830429
PDR ADOCK 05000358
S PDR

MAY 5 1983

IE27

Mr. J.G. Keppler
Regional Administrator
April 29, 1983
LOZ-83-0022
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By *J. Williams Jr.*
J. WILLIAMS, JR.
SENIOR VICE PRESIDENT

DJS/FJS/cse

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
ATTN: W.F. Christianson
NRC Zimmer Project Inspector
Region III