




ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

May 2, 1983

1CAN058301

Mr. W. C. Seidle, Chief  
Reactor Project Branch #2  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011



Subject: Arkansas Nuclear One - Unit 1  
Docket No. 50-313  
License No. DPR-51  
Licensee Event Report  
No. 83-010/03L-0

IE-29

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 1 Technical Specification 6.12.3.2.b, attached is the subject report concerning the high bearing temperature of steam driven emergency feedwater (EFW) pump P-7A during monthly surveillance testing.

Very truly yours,

John R. Marshall  
Manager, Licensing

JRM:RJS:s1

Attachment

cc: Mr. Richard C. DeYoung  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Norman M. Haller, Director  
Office of Management & Program Analysis  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8305120414 830502  
PDR ADOCK 05000313  
S PDR