



# Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

April 21, 1983

Mr. J.M. Allan  
Acting Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 82-001/01X-1  
ER 100450 FILE 841-23  
PLA- 1633

---

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 82-001/01X-1. This is an Update Report. The previous report was dated August 2, 1982. This report is in regard to an unacceptable linear indication in the A-11M weld on a Reactor Recirculation System riser that was detected by radiography examination.

The previous report was determined to be reportable per Technical Specification 6.9.1.8.C.

  
H.W. Keiser  
Superintendent of Plant-Susquehanna

JTT/pjg

attachment

cc: Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

G.G. Rhoads  
Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8305120422 830421  
PDR ADOCK 05000387  
S PDR

IE22