



Wisconsin Electric POWER COMPANY
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

May 5, 1983

54-266

STATE OF WISCONSIN
Department of Natural Resources
WPDES Permit Section
P.O. Box 7921
Madison, WI 53707

Gentlemen:

WPDES Permit No. WI-0000957-2
POINT BEACH NUCLEAR PLANT

This will notify the Department that the daily maximum pH effluent limitation was exceeded at the Point Beach Nuclear Plant. The pH of the retention pond discharge (sample point 501) was 9.8 s.u. on April 29, 1983.

The Company has commenced an investigation into this incident which will include a review of the sampling and analysis techniques to determine the validity of the results, an inspection of any treatment equipment, and a review of operators' logs to determine any unusual activities which might have caused the incident. When the investigation is completed, a letter will be sent to the Department outlining the results of the investigation and corrective action, if any, which has been or will be taken.

Very truly yours,

Vice President - Nuclear Power

C. W. Fay

cc: Lake Michigan District
NRC Region III
NRC Washington✓

IE25

8305130034 830505
PDR ADOCK 05000266
S PDR



Wisconsin Electric POWER COMPANY

231 WEST MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

WISCONSIN BUSINESS

IS IN A FINE STATE

POSTNET
FIRST CLASS



Mr. H. R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. NUCLEAR REGULATORY COMMISSION
Washington, D. C.

20555