

CP&L

Carolina Power & Light Company

ATLANTA REGION II
ATLANTA, GEORGIA

83 MAY 10 4 9: 34

P. O. Box 101, New Hill, N. C. 27562
May 6, 1983

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 3100)
Atlanta, Georgia 30303

NRC-67

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 KW - UNITS 1 & 2
WELDING ON CLASS 1E 480V MOTOR CONTROL CENTERS,
PURCHASE ORDER NY-435143, ITEM 129

Dear Mr. O'Reilly:

On April 8, 1983, Mr. A. Hardin of the NRC was notified of a potentially reportable item per the provisions of 10CFR50.55(e) and 10CFR, Part 21. The Class 1E Motor Control Centers from the vendor (ITE Gould) contained weld deficiencies.

At the present time, ITE Gould is still evaluating the welding on their motor control centers and do not expect to be complete with this until the first part of July, 1983. For this reason, we would request an extension until July 13, 1983 for submitting a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons
Project General Manager
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Mr. G. Maxwell (NRC-SHNPP)
Mr. R. Prevatte (NRC-SHNPP)
Mr. V. Stello (NRC)

8305130080 830506
PDR ADOCK 05000400
S PDR

OFFICIAL COPY
IE 21