

**CP&L**

REGION II  
ATLANTA, GEORGIA

Carolina Power & Light Company

83 MAY 10 A 9:33

Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport, NC 28461-0429

May 5, 1983

FILE: B09-13510C  
SERIAL: BSEP/83-1421

Mr. James P. O'Reilly, Administrator  
U. S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street N.W.  
Atlanta, GA 30303


BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1  
DOCKET NO. 50-325  
LICENSE NO. DPR-71  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

On April 4, 1983, a Unit No. 1 fire barrier LCO was initiated on penetration seal No. CB-2-301, fire door 221. This door, which is located on the 49-foot elevation of the Unit No. 1 Control Building, provides personnel access to the Unit No. 1 computer room from the Control Room. The LCO was initiated to permit opening the door to allow ambient air circulation between the computer room and the Unit No. 1 Control Room electronic equipment area due to the inoperability of the computer room air-conditioning unit.

On April 11, 1983, the LCO time frame expired. The required repairs to the subject air-conditioning unit were not completed until April 13, 1983, at which time the LCO was cancelled and door 221 was returned to service.

Very truly yours,



C. R. Dietz, General Manager  
Brunswick Steam Electric Plant

RMP/dj/LETDJ4

Enclosure

cc: Mr. R. C. DeYoung  
NRC Document Control Desk

OFFICIAL COPY

IE 22

8305130108 830505  
PDR ADOCK 05000325  
S PDR