



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 6, 1983

83 MAY 10 P2:20

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Fire Barriers
in Control Room Panel
1H13P871 Opened for Design
Change
LER 82-175/99 X-1
AECM-83/0268

This is an update to a previous report submitted on January 18, 1983. The event for which the report was submitted occurred on December 13, 1983, when several fire barriers in Control Room Panel 1H13P871 were opened in order to accommodate a design change in the panel. A Limiting Condition for Operation was entered in accordance with Technical Specification 3.7.7. The event was reported pursuant to Technical Specification 6.9.2.

All corrective action for the event is complete. Attached is LER 82-175/99 X-1, which is a final report.

Yours truly,

[Signature]
FOR J. P. Mc GAUGHY JR

JPM:sap
Attachment

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)

Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

100-27

8305130194 830506
PDR ADDCK 05000416
PDR