

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | O H D B S 1 2 | 0 0 - 0 0 0 0 0 0 - 0 0 3 | 4 1 1 1 1 4 | 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

1 8 | L 6 | 0 5 | 0 0 0 3 4 6 7 | 0 6 0 4 8 1 8 | 0 5 0 5 8 3 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | (NP-33-81-40) At 1410 hours during the performance of ST 5031.14, it was noted that the

0 3 | relay status lamp 302A did not change state when a trip signal was applied. As a result

0 4 | the trip output to AF 599 (auxiliary feedwater discharge to Steam Generator 2) from the

0 5 | Steam and Feedwater Rupture Control System (SFRCS) Channel 2 was inoperable. This

0 6 | placed the unit in the action statement of Technical Specification 3.3.2.2. There was

0 7 | no danger to the health and safety of the public or station personnel. SFRCS Channels

0 8 | 1/3 and Auxiliary Feedwater Train 1 were operable.

0 9 8 | I E 11 | E 12 | A 13 | 1 N S T R U 14 | X 15 | Z 16

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

1 7 8 | 8 1 | 0 3 2 | 0 3 | X | 1

LER RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

1 8 X 19 | Z 20 | Z 21 | 0 0 0 0 | Y 23 | Y 24 | N 25 | C 5 6 0 0 26

ACTION KEN ACTION FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | The cause was determined to be a failed relay driver card in SFRCS Channel 2. Under

1 1 | MWO IC-458-81, the defective relay driver board was replaced. The channel was declared

1 2 | operable on 6/4/81 at 2240 hours. The defective relay driver board will be tested to

1 3 | determine the failed component.

1 5 8 9 | E 28 | 0 7 3 29 | NA 30 | B 31 | During performance of ST 5031.14 32

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 8 9 | Z 33 | Z 34 | NA 35 | NA 36

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 8 9 | 0 0 0 37 | Z 38 | NA 39

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 8 9 | 0 0 0 40 | NA 41

PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 8 9 | Z 42 | NA 43

IS OF OR DAMAGE TO FACILITY PE DESCRIPTION

2 0 8 9 | N 44 | NA 45

ISSUED DESCRIPTION

NRC USE ONLY