

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I P A L 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CON'T

0 1 L 6 0 1 5 0 0 0 2 5 5 7 0 4 1 0 8 3 8 0 5 0 9 8 3 9

REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 During normal power operation, a sample from T-82C ("C" Safety Injection

0 3 Tank) showed the boron concentration to be below the TS limit of 1720 ppm.

0 4 Boron concentration was promptly restored. Condition reportable per

0 5 TS 3.3.1.b and 6.9.2.b(2). No threat to public health or safety resulted.

0 6 _____

0 7 _____

0 8 _____

0 9 _____

SYSTEM CODE S F 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE A C C U M U 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

LER NO. 17 REPORT NUMBER 8 3 EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 0 2 5 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN X 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPSR-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER N 1 5 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 Boron dilution due to minor leakage past loop check valve and SIT check

1 1 valve or fill and drain valve. Primary coolant leak rate is being closely

1 2 monitored. Valves will be inspected during next refueling outage.

1 3 _____

1 4 _____

FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Tank Sample 32

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED DESCRIPTION N 44 NA 45

NRC USE ONLY

8305130230 830509
PDR ADOCK 05000255
S PDR