

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

April 22, 1983

Mr. James M. Allan
Acting Regional Administrator
U. S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, PA 19406

Docket No. 50-318
License No. DPR 69


SUBJECT: Cancellation of LER 83-19/3L (U-2)

Dear Mr. Allan:

This letter is to cancel LER 83-19 describing a malfunction of the CEA Motion Inhibit.

The Metroscope front scanner module does not feed a signal to the Power Dependent Insertion Limit (PDIL) circuits. Thus, the PDIL input and all other inputs to the CEA Motion Inhibit were operable. Consequently, an LER was not warranted. We apologize for any inconvenience.

Very truly yours,


L. B. Russell
Plant Superintendent

LBR:LSH:bsb

cc: Director, Office of Management Information
and Program Control
Messrs: A. E. Lundvall, Jr.
J. A. Tiernan

8305160081 830422
PDR ADOCK 05000318
S PDR

IE22