



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

May 6, 1983

Mr. J.M. Allan
Acting Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-058/03L-0
ER 100450 FILE 841-23
PLA-1654

Docket No. 50-387
License No. NPF-14

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-058/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that two reactor pressure vessel water level switches were found out of tolerance. This LER will be updated.

LER 83-024/03L-0 is of similar nature.


H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/pjg

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8305160124 830506
PDR ADOCK 05000387
S PDR

1E 22