

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

REPORT

REPORT SOURCE L 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 2 | 7 | 0 | 3 | 0 | 8 | 8 | 3 | 8 | 0 | 5 | 0 | 3 | 8 | 3 | 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While in Mode 5, early warning fire detectors in Zone 41 were found inoperable during
0 3 performance of the 6-month fire detection channel functional test. Additionally, on
0 4 April 1, 1983, early warning fire detectors in Zone 6 were found inoperable during
0 5 performance of the same surveillance procedure. For both events, an hourly firewatch
0 6 was posted within one hour in accordance with LCO 3.3.3.7 Action Statement 'a'.
0 7 Health and safety of the public were not affected.

SYSTEM CODE A B		CAUSE CODE X		CAUSE SUBCODE X		COMPONENT CODE I N S T R U				COMP SUBCODE E		VALVE SUBCODE Z	
EVENT YEAR 8 3		SEQUENTIAL REPORT NO. 0 3 6		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0					
ACTION TAKEN X	FUTURE ACTION X	EFFECT ON PLANT Z	SHUTDOWN METHOD Z	HOURS 0 0 0 0	ATTACHMENT SUBMITTED N	NPRD-4 FORM SUB. N	PRIME COMP SUPPLIER A	COMPONENT MANUFACTURER P 4 3 5					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 1 The cause of the fire detector failures is not known at this time. The early warning
1 1 fire detectors are under evaluation to determine the extent of the problem. A plan
1 2 of corrective action is expected to be complete by June 1, 1983. Compensatory measures
1 2 will remain in place until the detectors are returned to operable status.

FACILITY STATUS (1) 5 (G) (28) % POWER (0) (0) (0) (29) OTHER STATUS NA (30) METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32) Surveillance Testing
 ACTIVITY CONTENT RELEASED OF RELEASE (1) 6 (Z) (33) (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE (36)
 PERSONNEL EXPOSURES NUMBER (1) 7 (0) (0) (0) (37) TYPE (Z) (38) DESCRIPTION NA (39)
 PERSONNEL INJURIES NUMBER (1) 8 (0) (0) (0) (40) DESCRIPTION NA (41)
 LOSS OF OR DAMAGE TO FACILITY TYPE (1) 9 (Z) (42) DESCRIPTION NA (43)
 PUBLICITY ISSUED (2) 0 (Z) (44) DESCRIPTION NA (45)

8305160125 830503
 PDR ADDCK 05000362
 S PDR

NRC USE ONLY

8305160125 830503
PDR ADDCK 05000362
S PDR

NRC USE ONLY

714/492-7700