NRC FORM 366 (12 81) 10 CFR 50

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P A S E S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

0 1 REPORT SOURCE | L (6) | 0 5 0 0 0 3 8 7 (7) | 0 4 0 9 8 3 (8) | 0 5 0 6 8 3 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During the performance of scheduled surveillance tests, two RPV water level switches
0 3 were found out of tolerance. One switch is the low-low level ADS permissive and the
0 4 other is the high level trip for the RCIC. There were no adverse consequences in
0 5 that the redundant ADS permissive switch was operable and available and there were
0 6 no instances of high RPV level in the quarter since the RCIC switch was last cali-
0 7 brated.
0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	I C (11)	E (12)	E (13)	I N S T R U (14)	S (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 3	—	0 5 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER (26)
E (18)	C (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	B 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Setpoint drift was the cause of both the switches being out of tolerance. Other
1 1 plants are being contacted to determine if they have similar problems and what
1 2 their proposed solutions are. Engineering evaluation is underway regarding use of
1 3 analog transmitters and electronic switches to replace the present mechanical
1 4 switches

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	B (28)	0 0 0 (29)	NA	(31)	Surveillance Testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

	PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

	PERSONNEL INJURIES NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

	LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION (43)
1 9	Z (42)	NA

	PUBLICITY ISSUED	DESCRIPTION (45)
2 0	N (44)	

8305160151 830506
PDR ADOCK 05000387
S PDR

NRC USE ONLY

NAME OF PREPARER L.A. Kuczynski PHONE (717) 542-2181 X3759