

MAILGRAM SERVICE CENTER
MIDDLETOWN, VA, 22645
05AM

Western
Union Mailgram



1-0187934217 08/05/83 ICS IPMMVIV MVN CGBA
06300 MGM (02651) 08-05 0425P CDT MVIW

SD - 255

NUCLEAR REGULATORY COMMISSION
799 ROOSEVELT
GLEN ELLYN IL 60137

1-007084C217 08/05/83
TLX CONSPower JKN
241 CONSUMERS POWER JACKSON MI 10:59 EDT 08-05
PMS
NUCLEAR REGULATORY COMMISSION

799 ROOSEVELT
GLEN ELLYN IL 60137

MSG # CBW105
MSG # ? AMS
TO:U S NUCLEAR REGULATORY COMMISSION
FROM:R M KRICH

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER
TS 6.9.2.A(2). ON AUGUST 4, 1983, AT 2327, WITH THE T-82D SAFETY
INJECTION (SI) TANK INOPERABLE DUE TO ROUTINE SAMPLING, AN ADDITIONA
L
SI TANK, T-82B, BECAME INOPERABLE DUE TO LOW LEVEL. THIS OCCURRENCE
OF TWO INOPERABLE SI TANKS AT THE SAME TIME LASTED FOR APPROXIMATELY
5 MINUTES AT WHICH TIME T-82B WAS RESTORED TO OPERABILITY PER TS 3.3
.2.

INITIAL REPORT WAS MADE VIA THE NRC HOT LINE AT 2340 ON AUGUST 4,
1983. NOTIFICATION TO THE NRC RESIDENT INSPECTOR WAS MADE ON AUGUST
5.

8

TIME: 10:52 08/05/83 EDT
CONNECT TIME : 50 SECONDS

CPCO GO MI AVE

CPCO GO MI AVE

N
NO CARRIER 8308180223 830805
PDR ADOCK 05000255
S PDR

TIME: 10:54 08/05/83 EDT

AUG 8 1983

TO REPLY BY MAILGRAM MESSAGE, SEE REVERSE SIDE FOR WESTERN UNION'S TOLL - FREE PHONE NUMBERS

1622
10