



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

October 17, 1978

2-108-7

Director of Nuclear Reactor Regulation
ATTN: Mr. J. F. Stoltz, Chief
Light Water Reactors Branch #1
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Arkansas Nuclear One-Unit 2
Docket No. 50-368
License No. NPF-6
Fire Protection
(File: 2-1510, 2-2040)

RECEIVED
OCT 26 PM 4:06
OFFICE OF THE SECRETARY
D.C.

Gentlemen:

Our response to Item 3C, in our letter of April 12, 1978, stated that actuation of the (proposed) water spray system in ANO-2 Fire Zone 2109-U could possibly affect safety related AC panels 2R51, 2R52, 2R53, 2R54 and committed to provide drip shields for these panels but gave no implementation date.

Our letter of June 15, 1978, response to Item 8f, committed to provide spray shields, in zone 2109-U, for MCCs 2B51 and 2B61 by September 1, 1978. We committed to this early date because a sprinkler system is already installed in the portion of Zone 2109-U where these MCCs are located. These spray shields have been installed.

We intended for the addition of spray shields to the four AC panels to be installed commensurate with the addition of the sprinkler system to the remaining portion of Zone 2109-U which was committed to be installed by the 1st refueling outage (by our letter of June 15, 1978, response to Item 4f) since the four panels are located in that area. Addition of the spray shields to the AC panels before installation of the sprinkler system serves no purpose.

Through an administrative error, we failed to make this point clear. However, given this clarification, we request that the implementation date for Item 3.3 of NUREG-0223 Table 3.1 and Item 3.3 of the table entitled "Implementation Dates for Proposed Modifications", page 7 of Amendment No. 1 to NPF-6 be changed to "prior to startup following the first regularly scheduled refueling outage" consistent with Item 3.5 of the two tables listed below.

7810240135 P


Boo2
S/P

2-108-7
Mr. J. F. Stolz, Chief

-2-

October 16, 1978

Very truly yours,

A handwritten signature in cursive script that reads "Daniel H. Williams". The signature is written in dark ink and is positioned above the printed name and title.

Daniel H. Williams
Manager, Licensing

DHW:JTE:jaj