

CP&L

USNRC REGION II
ATLANTA, GEORGIA

Carolina Power & Light Company

83 AUG 15 A 9:43

P. O. Box 101, New Hill, N. C. 27562
August 8, 1983

50-400
401

NRC-106

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 2900)
Atlanta, Georgia 30303

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 KW - UNITS 1 & 2
BACKDRAFT DAMPERS RECEIVED WITH ONE COUNTERBALANCE
ARM IN LIEU OF TWO, ITEM 134


Dear Mr. O'Reilly:

On June 2, 1983, Mr. K. V. Hate' notified the NRC (Mr. A. Hardin) of a potentially reportable item per the provisions of 10CFR50.55(e). Mr. Hardin was informed that thirty-four (34) Unit No. 1 backdraft dampers (Seismic Class I) were received from Ruskin Manufacturing Company with one (1) counterbalance arm assembly in lieu of the required two (2).

On June 29, 1983, we stated in our letter NRC-91 that we were awaiting shake test results from Wyle Laboratories in order to complete our evaluation. At that time we requested an extension until August 8, 1983 to complete our evaluation and submit a report on the reportability of this item. Since our last report, the test results have been received and we are currently awaiting Ebasco Services' review and approval of these results expected by August 29, 1983. Therefore, we are requesting an extension until September 12, 1983 for submitting a report on the reportability of this item.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons
Project General Manager
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. R. C. DeYoung (NRC)

8308180241 830808
PDR ADOCK 05000400
S PDR

OFFICIAL COPY

IE 27
1/0