

IPMBNAB BRID
1-008575C220 08/08/83
ICS IPMMVIO MVN
02141 MT VERNON IL 08-08 1208P CDT MVIL
ICS IPMBDGS
1-004650M220 08/08/83
TLX CONSPower JKN
245 CONSUMERS POWER JACKSON MI 10:49 EDT 08-08

PMS

U S NUCLEAR REGULATORY COMMISSION
PALISADES PLANT SECT CHIEF
799 ROOSEVELT AVENUE
GLEN ELLYN IL 60137

(8/2) 932-2500

MSG # CBW119

R KRICH

VDEST: PALISADES
MSGID: NRC MESSAGE
DEST: MSG CENTER MICH AVE
TO: U S NUCLEAR REGULATORY COMMISSION
FROM: R M KRICH

TO: U S NUCLEAR REGULATORY COMMISSION
799 ROOSEVELT AVENUE
GLEN ELLYN, ILLINOIS
ATTN: PALISADES PLANT SECTION CHIEF

FROM: R M KRICH, PALISADES

CC: VICE-PRESIDENT, NUCLEAR OPERATIONS, P-26-117B
NUCLEAR LICENSING ADMINISTRATOR, P-24-614B

THIS CONFIRMS PROMPT NOTIFICATION OF AN OCCURRENCE REPORTABLE PER T.S. 6.9.2.A(2). ON AUGUST 6, 1983, AT 0345, A SAMPLE FROM T-82D (D SAFETY INJECTION TANK) SHOWED BORON CONCENTRATION TO BE 1712 PPM WHICH IS BELOW THE T.S. LIMIT OF 1720 PPM BORON. T-82D BORON CONCENTRATION COULD NOT BE RESTORED WITHIN THE ONE HOUR LIMIT OF T.S. 3.3.2.A. AT THE TIME OF THIS OCCURRENCE, THE PLANT WAS ALREADY IN A POWER REDUCTION. AT 0449, AUGUST 6, 1983, SIT T-82D WAS RESTORED TO OPERABILITY WITH A BORON CONCENTRATION OF 1753 PPM. INITIAL REPORT WAS MADE VIA THE NRC HOT LINE ON AUGUST 6, 1983. NOTIFICATION TO THE NRC RESIDENT INSPECTOR WAS MADE ON AUGUST 8, 1983.

.P?

TIME: 10:46 08/08/83 EDT
CONNECT TIME : 65 SECONDS

1206 EST

1213 EST

IPMBNAB BRID

8308180386 830808
PDR ADOCK 05000255
S PDR

AUG 12 1983

1522
1/0

western union

western union

western union

western union

western union