

CONTROL BLOCK: | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0



Commonwealth Edison

Dresden Nuclear Power Station

R.R. #1

Morris, Illinois 60450

Telephone 815/942-2920

August 9, 1983

DJS Ltr #83-774

James G. Keppler, Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reportable Occurrence Report #83-54/03L-0, Docket #050-237 is being submitted to your office in accordance with Dresden Nuclear Power Station Technical Specification 6.6.B.2.(c), observed inadequacies in the implementation of administrative or procedural controls which threaten to cause reduction of degree of redundancy provided in reactor protection systems or engineered safety feature systems.

D.J. Scott
Station Superintendent
Dresden Nuclear Power Station

DJS/kjl

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
U.S. NRC, Document Management Branch
File/NRC

IE22
AUG 15 1983



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 2 83 101
STA UNIT YEAR NO.

PART 1 TITLE OF DEVIATION

OCCURRED

Containment Spray Interlocks Surv. Performed Late

7/14/83

1100

DATE

TIME

SYSTEM AFFECTED

1500

PLANT STATUS AT TIME OF EVENT

LPCI

MODE S/D

PWR(MWT) 0

LOAD(MWE) 0

TESTING

☒ YES☐ NO

DESCRIPTION OF EVENT

Containment spray interlocks surveillance DIS 1500-3 (T.S.4.2.1) was performed on 7/13/83, two days past the actual latest date due. Due to a previous computer problem the latest date due was printed as 7/13/83 on the surveillance schedule instead of 7/11/83.

10 CFR50.72 NRC RED PHONE

☐☒

NOTIFICATION MADE

YES

NO

EQUIPMENT FAILURE

N/A

☐ YES☒ NO

WORK REQUEST NO.

RESPONSIBLE SUPERVISOR

D.A. Ringo

DATE 7/18/83

PART 2 OPERATING ENGINEER'S COMMENTS

None

☐ EVENT OF PUBLIC INTEREST☐ TECH. SPEC. VIOLATION☐ NON REPORTABLE OCCURRENCE☐ 14 DAY REPORTABLE/T.S.☒ 30 DAY REPORTABLE/T.S. 6.6.B.2.c☐ ANNUAL/SPECL REPORT REQ'D

A.I.R. #

L.E.R. # 83-54/03L-0

☐ 24-HOUR NRC NOTIFICATION REQ'D

TELEPH N/A

REGION III

DATE

TIME

TELEGM/TELECOPY N/A

REGION III

DATE

TIME

☐ CECO CORPORATE NOTIFICATION MADE

IF ABOVE NOTIFICATION IS PER 10CFR21

☐ 5-DAY WRITTEN REPORT REQ'D PER 10CFR21

Telecopy

XXXXXX

Dennis P. Galle

7/18/83

1616

CECO CORPORATE OFFICER

DATE

TIME

PRELIMINARY REPORT
COMPLETED AND REVIEWED

John M. Almer

OPERATING ENGINEER

7/18/83

DATE

INVESTIGATED REPORT & RESOLUTION
ACCEPTED BY STATION REVIEWRESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTION

86-5176 (FORM 15-52-1) 10-81

8/10/83

Douglas Part
STATION SUPERINTENDENT

8/10/83

8/10/83
DATE