

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

USNRC REGION II
ATLANTA, GEORGIA

1750 Chestnut Street Tower II

83 AUG 17 A8:07

August 12, 1983

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/83098

The enclosed report provides details concerning a glycol containment
isolation valve discovered failed closed and subsequent rise of
ice bed temperature above 27°F. This report is submitted in
accordance with Sequoyah unit 1 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Records Center
Institute of Nuclear Power Operations
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

OFFICIAL COPY

IE 22