

Georgia Power Company
Post Office Box 439
Baxley, Georgia 31513
Telephone 912 367-7781
912 537-9444

USNRC REGION II
ATLANTA, GEORGIA

83 AUG 17 A8:06



Georgia Power

Edwin I. Hatch Nuclear Plant


July 29, 1983
GM-83-721

PLANT E. I. HATCH
Licensee Event Report
Docket No. 50-321

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

ATTENTION: Mr. James P. O'Reilly

Attached is a Supplemental Narrative Summary to Licensee Event Report No. 50-321/1979-021, Rev. 5. This report is required by Hatch Unit 1 Technical Specifications 6.9.1.9.d and Environmental Technical Specifications 3.2 and 5.7.2.


H. C. Nix
General Manager

HCN/djs

xc: R. J. Kelly
G. F. Head
J. T. Beckham, Jr.
P. D. Rice
K. M. Gillespie
S. B. Tipps
R. D. Baker
Control Room
File

8308190383 830729
PDR ADOCK 05000321
S PDR

OFFICIAL COPY

IE 22
110

July 29, 1983

SUPPLEMENTAL NARRATIVE SUMMARY
TO
LER 50-321/1979-021, REV. 5
EDWIN I. HATCH NUCLEAR PLANT - HATCH 1
NONROUTINE RADIOLOGICAL ENVIRONMENTAL OPERATING
ANOMALOUS MEASUREMENT REPORT

This report which supplements the previous submittals on LER 50-321/1979-021 provides updated data on tritium levels in groundwater samples taken from locations where the average value during the second quarter of 1983 exceeded 3.0 E4 pCi/l which is the report level ;for tritium in environmental water samples according to Table 3.2-3 of the ETS. There continues to be no significant impact on the public health and safety due to these readings which exceeded the report level. As reported previously, any releases to unrestricted areas are through the outfalls of the drainage system; such releases continue to be small and result in nonsignificant doses to the public.

Reportable levels were found only at test holes N9B and T18. The tritium levels at these locations have been continuously reportable for over 4 years. The tritium levels found during the second quarter along with a complete listing of past average quarterly levels are presented in Table 1.

Supplement
July 29, 1983

Table 1
High Tritium Levels

pCi/l

<u>Qtr. or Date</u>	<u>N9B</u>	<u>T18</u>
<u>QUARTERLY AVERAGES</u>		
3-78	3.45 E3	
4-78	4.49 E3	
1-79	3.42 E4	
2-79	8.50 E4	6.68 E4
3-79	1.38 E5	7.61 E4
4-79	1.71 E5	6.84 E4
1-80	1.73 E5	8.71 E4
2-80	1.79 E5	6.36 E4
3-80	1.64 E5	7.61 E4
4-80	1.13 E5	5.91 E4
1-81	1.06 E5	8.29 E4
2-81	8.17 E4	7.77 E4
3-81	8.47 E4	1.27 E5
4-81	9.77 E4	1.27 E5
1-82	4.20 E5	1.29 E5
2-82	4.42 E5	1.56 E5
3-82	3.64 E5	9.33 E4
4-82	3.12 E5	1.02 E5
1-83	3.64 E5	dry
2-83	3.58 E5	3.81 E4

During Second Quarter 1983

4/06	4.10 E5	
4/12		dry
4/19	4.11 E5	
4/26	4.07 E5	
5/11		dry
5/17	3.55 E5	
5/31	2.87 E5	
6/07		3.81 E4
6/14	3.16 E5	
6/28	3.23 E5	

Supplement
July 29, 1983