



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

83 AUG 17 9:29
August 11, 1983

NUCLEAR PRODUCTION DEPARTMENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 83-065/0 - Fire
Rated Penetrations Reworked
AECM-83/0462

On July 8, 1983, the fire rated penetrations listed on the attached page were reworked due to incomplete documentation and secondary containment penetrations not being sealed properly (improper sealing resulted in air in-leakage). A Limiting Condition for Operation was entered in accordance with Technical Specification 3.7.7.

The discrepancies and corrective actions are identified on Material Non-Conformance Reports 00416-83 and 00479-83. This is reported as a Special Report pursuant to Technical Specification 6.9.2. This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The work tasks are expected to be completed by September 30, 1983.

Yours truly,

Sam H. Hobbs for

L. F. Dale
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8308190392 830811
PDR ADOCK 05000416
S PDR

OFFICIAL COPY
TE 22
11

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0462

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. C. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

On July 8, 1983, the following fire rated penetrations were reworked:

<u>PENETRATIONS</u>	<u>INCIDENT REPORT NUMBER</u>
AE70A	83-07-17
AE71A	83-07-17
AE35C	83-07-17
AE43C	83-07-17
AE88C	83-07-17
AE185C	83-07-17
AC38E	83-07-17
AE289D	83-07-17
AE405C	83-07-19
AE411C	83-07-19
AE217D	83-07-19
AE220D	83-07-19