

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 12 00 - 000000 - 0003 411114 45
7 8 9 14 15 25 26 30 37 38 39CONT
01 REPORT SOURCE L 0500003157 07111833 08111839
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING NORMAL OPERATION, A LEAK DEVELOPED FROM THE PACKING SEAL WATER SUPPLY LINE
03 OF THE EAST COMPONENT COOLING WATER (CCW) PUMP. THE PUMP WAS REMOVED FROM SERVICE
04 WHICH WAS NON-CONSERVATIVE WITH RESPECT TO T.S. 3.7.3. THE PUMP WAS OUT OF SERVICE
05 FOR 3 HOURS AND 55 MINUTES. THE ACTION REQUIREMENTS WERE MET. PUBLIC HEALTH AND
06 SAFETY WERE NOT AFFECTED. THIS WAS THE FIRST OCCURENCE OF THIS TYPE.
07
0809
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
WB 11 E 12 B 13 VALVEX 14 F 15 D 16
LEAD REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
83 066 03 L 0
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
F 18 Z 19 Z 20 Z 21 00000 N 22 N 24 A 25 L 3000 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

13 THE LEAK RESULTED FROM FAILURE OF A 3/8 INCH ISOLATION VALVE ON THE PACKING SEAL
14 WATER SUPPLY LINE WHICH WAS USED DURING THE PREOP. PHASE WHEN PACKING WAS INSTALLED
15 RATHER THAN THE MECHANICAL SEALS PRESENTLY INSTALLED. THE LINES WERE REMOVED AND
16 PIPE PLUGS WERE INSTALLED. THE LINES HAD BEEN REMOVED PREVIOUSLY FROM THE WEST
17 CCW PUMP.
1819
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
FACILITY STATUS % POWER OTHER STATUS (20) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
E 28 0816 29 NA A 31 OPERATOR OBSERVATION
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 NA NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
000 27 Z 38 NA
PERSONNEL INJURIES NUMBER DESCRIPTION (41)
000 40 NA
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 NA
PUBLICITY STATUS DESCRIPTION (45)
N 44 NA
NRC USE ONLY
208308190422 830811
PDR ADOCK 05000315
S PDR

NAME OF PREPARER DAVID G. WIZNER

PHONE: 616-465-5901