



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 ■ PERRY, OHIO 44081 ■ TELEPHONE (216) 259-3737 ■ ADDRESS-10 CENTER ROAD

Serving The Best Location in the Nation

FERRY NUCLEAR POWER PLANT PROJECT ORGANIZATION
CEI NUCLEAR ENGINEERING DEPARTMENT
AND KAISER ENGINEERS, INC.

August 9, 1983

Mr. Richard Jagger
National Board of Boiler & Pressure Vessel Inspections
1055 Crupper
Columbus, Ohio 43229

Subject: Missing Radiographs of Two (2) B-W Valves.


Dear Mr. Jagger:


This is to notify you that the missing Radiographs for Two (2) Borg-Warner Valves, 12 inch Globe Valve, S/N 57289 and 12 inch Globe Valve, S/N 57290 have been located in the film vault at PNPP. These radiographs were stored in a misidentified package which was located after receipt of a letter from Borg-Warner telling us what packages of radiographs had been sent simultaneously.

The radiographs are good and the valves appear to be acceptable. The radiographs were done with the ends in the as cast condition and do not exhibit the penetrameter anomaly. However, the weld ends do exhibit the wrong size penetrameter.

These valves will be accepted based on the sampling that was re-radiographed on site by Magnaflux Quality Services. These two (2) valves were included in the number of valves we had problems with (217) so they do not add to the number re-radiographed (44).

Sincerely,

for 
Hudson Walls, Jr.
Sr. NDE Administrator


James P. Hingey
NDE Level III

HW/JPH/kac

cc: K. Ward
M. Gildner

P. Milinazzo
D. Tevis

R. Acomb
NDE File

B-W File

8308190424 830809
PDR ADOCK 05000440
A PDR

IE 27
AUG 12 1983
110