



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

NUCLEAR PRODUCTION DEPARTMENT

September 9, 1982

U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, D. C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station  
Units 1 and 2  
Docket Nos. 50-416 and 50-417  
License No. NPF-13  
File 0260/0277/15601  
Additional Information on Revision  
6 to GGNS Emergency Plan  
AECM-82/384

This letter addresses questions posed by Mr. Don Perrotti, Nuclear Regulatory Commission reviewer for the Grand Gulf Nuclear Station Units 1 and 2 Emergency Plan, on Revision 6 to the Plan. The three areas about which he expressed concern were the Emergency Action Levels (Table 4-1), emergency accountability (section 6.5.1.1) and the contents of the followup messages to offsite agencies (Figure 6-1).

Corrections to the Emergency Action Levels have been made as indicated on the attached pages. The followup message form has been revised; a copy is attached to this letter. Section 6.5.1.1 will be revised to read as follows: "... Personnel accountability and identification of missing persons onsite will be conducted in approximately 30 minutes. MP&L and contract personnel working outside the protected area will be promptly notified by a public address system. These individuals will be assembled and accounted for at predetermined locations, and a report provided to the Emergency Director within approximately 30 minutes. Other persons who may be in public access areas near-site..."

These changes will be incorporated into Revision 7 to the Plan by October 31, 1982. Revisions to the Emergency Plan Procedures will begin immediately and are expected to be completed by October 31, 1982. If you have any questions, please contact this office.

Yours truly,

L. F. Dale  
Manager of Nuclear Services

8210070044 820917  
PDR ADOCK 05000416  
F PDR

PBB/LRM/JDR:ac  
Attachments

cc: See next page

Member Middle South Utilities System

X005

## MISSISSIPPI POWER &amp; LIGHT COMPANY

cc: Mr. N. L. Stampley (w/o)  
Mr. R. B. McGhee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/o)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator (w/o)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303