

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

August 4, 1983  
ANPP-27500-RQT/BSK

RECEIVED  
NRC  
AUG 12 AM 11:01

U.S. Nuclear Regulatory Commission  
Region V  
Creekside Oaks Office Park  
1450 Maria Lane - Suite 210  
Walnut Creek, CA 94596-5368

Attention: Mr. D. M. Sternberg, Chief  
Reactor Projects Branch 1

Subject: Interim Report - DER 83-45  
A 50.55(e) Potentially Reportable Deficiency Relating to  
Cable Separations In Unit 1 Control Room Panels  
File: 83-019-026, D.4.33.2

Reference: Telephone Conversation between P. Narbut and R. Tucker on  
July 7, 1983

Dear Sir:

The NRC was notified of a potentially reportable deficiency in the referenced telephone conversation. At that time, it was estimated that a determination of reportability would be made within thirty (30) days.

Due to the extensive investigation and evaluation required, an Interim Report is attached. It is now expected that this information will be finalized by October 18, 1983, at which time a complete report will be submitted.

Very truly yours,

E. E. Van Brunt

E. E. Van Brunt, Jr.  
APS Vice President  
Nuclear Projects Management  
ANPP Project Director

EEVBJr/RQT:sn  
Attachment

cc: See Page 2

50-528

8308220148 830804  
PDR ADDCK 05000528  
S PDR

11

IE-27

U. S. Nuclear Regulatory Commission  
Page 2

cc: Richard DeYoung, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

T. G. Woods, Jr.  
G. C. Andognini  
J. A. Roedel  
D. B. Fasnacht  
A. C. Rogers  
B. S. Kaplan  
W. E. Ide  
J. Vorees  
J. R. Bynum  
P. P. Klute/D. D. Green  
A. C. Gehr  
W. J. Stubblefield  
W. G. Bingham  
R. L. Patterson  
R. W. Welcher  
R. M. Grant  
D. R. Hawkinson  
L. E. Vorderbrueggen  
G. A. Fiorelli  
S. R. Frost  
J. Self

Records Center  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway - Suite 1500  
Atlanta, Georgia 30339

INTERIM REPORT - DER 83-45  
POTENTIAL REPORTABLE DEFICIENCY  
ARIZONA PUBLIC SERVICE COMPANY (APS)  
PVNGS UNIT 1

I. Potential Problem

- 1 NCR's SE-1847, SE-1861, S-327-1-E, SE-2045 and SE-2046 document that field installed Class 1E Cables violate the "Separation Requirement for Field Cabling Within Enclosures", Specification 13-EM-306, Section 11.0.
2. NCR's SE-1847, SE-1861, SE-2045, SE-2046 and S-327-1-E also document continuing separation requirement violations. APS Operation/Maintenance and Start-up Departments procedures do not provide instructions or requirements for work involving cable separation.

II. Approach To and Status of Proposed Resolution

Bechtel engineering is investigating to provide a resolution and corrective action plan.

III. Projected Completion of Corrective Action and Submittal of the Final Report

Evaluation of this condition and submittal of the Final Report is Forecast to be completed by October 18, 1983.