

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

RECEIVED
NRC

1983 AUG 10 PM 1:01

July 29, 1983
ANPP-27465-RQT/BSK

REGION V USE

U. S. Nuclear Regulatory Commission
Region V
Creskide Oaks Office Parks
1450 Maria Lane - Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. D. M. Sternberg, Chief
Reactor Projects Branch 1

Subject: Time Extension for Report - DER 82-68
A 50.55(e) Potentially Reportable Deficiency Relating to
Underground Cables to Startup Transformers May Not Carry
Full-Load Current At Maximum Site Soil Temperature.
File: 83-019-026, D.4.33.2


Reference: (A) Telephone conversation between J. Echardt and J. Cook on
November 26, 1982.
(B) ANPP-22521 dated December 13, 1982 (Interim Report)
(C) ANPP-23025 dated February 16, 1983 (Time Extension)
(D) ANPP-23347 dated March 24, 1983 (Time Extension)
(E) ANPP-23470 dated April 12, 1983 (Time Extension)
(F) ANPP-23756 dated May 16, 1983 (Time Extension)

The NRC was notified of a potentially reportable deficiency in
Reference (A), an Interim Report was transmitted by Reference (B), and
time extensions were requested by References (C), (D), (E), and (F). As
of May 16, 1983 as estimated that a Final Report would be available
by July 29, 1983.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by September 16, 1983,
when a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,



E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects Management
ANPP Project Director

EEVBJr/RQT:rb

cc: See Page 2

8308220153 830729
PDR ADOCK 05000528
S PDR

110
IF-27

cc:

Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
G. C. Andognini
J. A. Roedel
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. R. Bynum
P. P. Klute/D. D. Green
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost
J. Self

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway - Suite 1500
Atlanta, Georgia 30339