

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L G 0 5 0 0 0 3 1 6 7 0 7 1 7 8 3 8 0 8 0 5 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 AT 1630, THE P-250 COMPUTER FAILED WHICH REQUIRES LOGGING AXIAL FLUX DIFFERENCE
0 3 (AFD) ONCE PER HOUR FOR THE FIRST 24 HOURS. P-250 WAS RETURNED TO SERVICE AT 1730,
0 4 WITH THE FIRST PRINTOUT AT 1733, WHICH REQUIRES MONITORING AFD ONCE PER HOUR FOR THE
0 5 FOLLOWING 24 HOURS. SURVEILLANCE REQUIREMENT OF T.S. 4.2.1.1b WAS NOT COMPLETED
0 6 FOR THE FIRST HOUR AS OPERATOR WAS LOGGING THE POWER LEVELS AND NOT AFD. THE HEALTH
0 7 AND SAFETY OF THE PUBLIC WERE NOT AFFECTED. THIS IS THE FIRST OCCURRENCE OF THIS
0 8 TYPE.

0 9 SYSTEM CODE I F 11 CAUSE CODE A 12 CAUSE SUBCODE B 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE Y 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16
17 LER/RO REPORT NUMBER 8 3 21 22 EVENT YEAR 23 24 SEQUENTIAL REPORT NO. 0 6 4 25 26 OCCURRENCE CODE 0 3 27 28 REPORT TYPE L 29 30 REVISION NO. 0 31
18 19 ACTION TAKEN FUTURE ACTION 20 EFFECT ON PLANT 21 SHUTDOWN METHOD 22 HOURS 23 ATTACHMENT SUBMITTED 24 NPRD-4 FORM SUB. 25 PRIME COMP. SUPPLIER 26 COMPONENT MANUFACTURER
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 OPERATOR WAS A NON-LICENSED TRAINEE IN THE CONTROL ROOM. HE MISUNDERSTOOD THE
1 1 READINGS HE WAS SUPPOSED TO LOG AND WAS LOGGING POWER LEVELS INSTEAD OF AFD.
1 2 THE AFD WAS VISUALLY MONITORED BY A LICENSED OPERATOR WITHIN LIMITS DURING THE
1 3 TOTAL LENGTH OF TIME OF THE EVENT. THIS REPORT HAS BEEN CIRCULATED TO ALL OPERATIONS
1 4 DEPARTMENT SUPERVISORS TO INSURE THEY MONITOR CONTROL ROOM TRAINEES WORK CAREFULLY.

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
1 6 RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER D. F. KRAUSE

PHONE (616) 465-5901

NRC USE ONLY