



Public Service Electric and Gas Company P.O. Box 236 Hancocks Bridge, New Jersey 08038

Nuclear Department

August 15, 1983

Dr. Thomas E. Murley, Regional Administrator
Region I - Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Dr. Murley:

IE BULLETIN 83-05
ASME NUCLEAR CODE PUMPS AND SPARE PARTS
MANUFACTURED BY HAYWARD TYLER PUMP COMPANY
NO. 1 AND 2 UNITS
SALEM GENERATING STATION
DOCKET NOS. 50-272 AND 50-311

In response to the referenced Bulletin, PSE&G has reviewed its use of pumps manufactured by Hayward Tyler Pump Company (HTPC) for the Salem Generating Station.

Four HTPC pumps were purchased in 1978 for reducing the required recirculation time on waste holdup tanks. None of these pumps has been installed; they are currently in storage on site. Two of the pumps are to be installed in the liquid radwaste system, one per unit. This application is classified as non-safety related; accordingly, the "Expanded Commissioning Tests and Inspections," issued January 21, 1983 as Attachment 2 to Bulletin 83-05, is not applicable to these pumps.

No HTPC spare parts have been purchased, nor is there any plan to purchase them. In April 1982, HTPC was placed in an "inactive" status in the Salem vendors list. Any future use of HTPC pumps or parts at Salem will be reviewed by QA Nuclear Operations for conformance to the appropriate standards and specifications.

8308230077 830815
PDR ADOCK 05000272
Q PDR

IE 11
1/0


Dr. Thomas E. Murley, Regional Administrator
U.S. Nuclear Regulatory Commission

-2-

8/15/83

Should you have any questions, please do not hesitate to
contact us.

Very truly yours,



E. A. Liden
Manager - Nuclear
Licensing and Regulation

CC: Mr. Donald C. Fisher
Licensing Project Manager

Mr. Leif Norrholm
Senior Resident Inspector

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555