



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704


AREA CODE 713 838-6631

May 12, 1983

RBG-15,026

File Nos. G9.5, G9.25.1.1

Mr. John T. Collins, Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV, Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



Dear Mr. Collins:

River Bend Station Unit 1
Docket No. 50-458
Interim Report/DR-100

On February 22, 1983, Gulf States Utilities Company (GSU) notified Region IV of a condition potentially reportable under 10CFR50.55(e) concerning Category I motor control center MOV feeder breaker settings supplied to River Bend Station by Gould-Brown Boveri. The breaker settings are larger than required (DR-100). GSU has not completed its evaluation. GSU is awaiting additional information from our architect-engineer. An interim or final status report will be submitted by June 20, 1983.

Sincerely,

William J. Leedy
for J. E. Booker
Manager-Engineering,
Nuclear Fuels & Licensing
River Bend Nuclear Group

JEB
JEB/PJD/kt

cc: Director of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

R. L. Brown (SRI)

8305200151 830512
PDR ADOCK 05000458
S PDR

IE-27