NRC FORM 366 (12-81)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011 EXPIRES 4-30-82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | SCVCS1 (2) | 00-00000-00 (3) | 41000 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE L (6) | 050003 95 (7) | 041583 (8) | 051283 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On April 15, 1983, with the Plant in Mode 5, Pressurizer Pressure Transmitter
03 IPT-457 was found to be out of tolerance. There were no adverse consequences
04 from this event since the minimum required channels were operable. This
05 instrument is required to be operable in Modes 1 and 2 by Technical Specification
06 3.3.1, and Modes 1, 2, and 3 by Technical Specification 3.3.2.
07
08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	IA (11)	E (12)	E (13)	INSTRU (14)	T (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	83	—	038	/	03	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER (26)
E (18)	Z (19)	Z (20)	Z (21)	0000	Y (23)	N (24)	L (25)	B080

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The cause of this event is contributed to a zero and span shift of the test
11 instrument used in the calibration of the transmitter. Maintenance personnel
12 are to continue to check post calibration data.
13
14

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	G (28)	000 (29)	N/A	B (31)	Post Test Calibration Check

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	N/A	N/A

	PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION (39)
17	000 (37)	Z (38)	N/A

	PERSONNEL INJURIES NUMBER	DESCRIPTION (41)
18	000 (40)	N/A

	LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION (43)
19	Z (42)	

8305200633 830512
PDR ADOCK 05000395
S PDR

	PUBLICITY ISSUED	DESCRIPTION (45)
20	N (44)	N/A

NRC USE ONLY

NAME OF PREPARER R. J. Bouknight

PHONE: (803) 345-5209