

yellow

CP&L

USNRC REGION II
ATLANTA, GEORGIA

Carolina Power & Light Company

83 AUG 8 09:48

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

August 4, 1983

FILE: B09-13510C
SERIAL: BSEP/83-2122

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 310C
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 & 2
LICENSE NOS. DPR-71 AND DPR-62
DOCKET NOS. 50-325 AND 50-324
SUPPLEMENTAL RESPONSE TO IE BULLETIN 80-17

Dear Mr. O'Reilly:

Our letter of August 28, 1980 (Serial No. BSEP/80-1417), in response to IE Bulletin 80-17, Revision 3 committed to functionally test the CRD instrument volume level alarm, rod block and scram switches after each scram event before returning to power. The bulletin required that this requirement remain in effect until completion of modifications to substantially increase reliability of water level indications in the scram discharge volume(s). Diverse level instrumentation has been installed on both units in accordance with PMs 81-238 and 81-239 as described in our letter dated January 13, 1981 (Serial No. BSEP/81-060). As a result, Brunswick is revising the procedure to return the frequency to that required by the technical specifications. If you have any questions regarding this item, please contact my staff.

Very truly yours,

P. W. Howe

P. W. Howe, Vice President
Brunswick Nuclear Project

RMP/mcg/LETCG1

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8308230273 830804
PDR ADOCK 05000324
G PDR

1/0 IE11