

# Duquesne Light Company

Beaver Valley Power Station  
PO Box 4  
Shippensburg, PA 17077-0004

July 19, 1991

JOHN D. SIEBER  
Vice President - Nuclear Group

412-392-5265

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Exemption From General Design Criterion 57

Ref: Letter from A.W. DeAgazio  
(Nuclear Regulatory Commission) to  
J.D. Sieber (Duquesne Light Company),  
Regarding: Exemption from GDC-57,  
TAC 75772 (June 26, 1991).

The referenced letter forwarded an exemption from the requirements of General Design Criterion (GDC) 57, and requested an implementation schedule for related action items. Each action item is described below with a scheduled or actual completion date.

Item A Include valves RW-615, -621, -627, and -633 in the Technical Specifications as containment isolation valves.

Presently we are considering removal of Table 3.6-1, "Containment Penetrations," from Technical Specifications in accordance with Generic Letter 91-08, "Removal of Component Lists from Technical Specifications." Therefore, a Technical Specification change will be submitted by February 28, 1992 to either

1. Include the valves referenced above in Technical Specification Table 3.6-1, or
2. Include the valves referenced above in Technical Specification Table 3.6-1, and move the Table from Technical Specifications to plant procedures in accordance with Generic Letter 91-08.

Item B Test valves RW-615, -621, -627, and -633 in accordance with the requirements of ASME Section XI.

The valves referenced above have been included in Revision 7 of the Inservice Testing Program (effective June 7, 1991) and will be tested in accordance with ASME Section XI.

9107290082 910719  
PDR ADOCK 05000334  
P PDR


Adol  
1/0

Item C Revise the radiation monitor alarm response procedure.

The affected radiation monitor alarm response procedures were revised by an operating manual change notice which was effective July 13, 1990.

Should you have any questions regarding this schedule, please contact Ken McMullen at (412) 393-5214.

Sincerely,

  
J. D. Sieber  
Vice President  
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. M. L. Bowling (VEPCO)