



Carolina Power & Light Company

P.O. Box 1551 • Raleigh, N.C. 27602

JUL 23 1991

SERIAL: NLS-91-190
10CFR50.90
9115B01

G. E. VAUGHN
Vice President
Nuclear Services Department

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2
DOCKET NOS. 50-325 & 50-324/LICENSE NOS. DPR-71 & DPR-62
SUPPLEMENT TO REQUEST FOR LICENSE AMENDMENT
ONE-TIME EXTENSION OF DIESEL GENERATOR SURVEILLANCE INTERVAL

Gentlemen:


Recently, the Staff requested additional information on CP&L's June 17, 1991 (NLS-91-097), submittal regarding a one-time only extension of the surveillance interval associated with Technical Specification 4.8.1.1.2.d.1 for diesel generators 3 and 4. The purpose of this submittal is to provide the requested supplemental information.

The last performance of Technical Specification 4.8.1.1.2.d.1 surveillance requirements was successfully completed on November 15, 1989 for diesel generator 3 and on November 7, 1989 for diesel generator 4. The total run time from the last completion of Technical Specification 4.8.1.1.2.d.1 through July 21, 1991 is 71.2 hours for diesel generator 3 and 87.6 hours for diesel generator 4.

In addition, the June 17, 1991 submittal stated that Unit 2 was shutdown on March 29, 1990 and Technical Specification requirements 4.8.1.1.2.d.2 through 4.8.1.1.2.d.7 were completed. Unit 2 was actually shutdown on March 29, 1991. This typographical error appeared in Enclosure 1, Basis For Change Request, and in Enclosure 2, 10 CFR 50.92 Evaluation.

Please refer any questions regarding this submittal to Mr. M. R. Oates at (919) 546-6063.

Yours very truly,



G. E. Vaughn

GEV/MAT

cc: Mr. Dayne H. Brown
Mr. S. D. Ebnetter
Mr. N. B. Le
Mr. R. L. Prevatte

9107290114 910723
PDR ADOCK 05000324
P PDR

Acc
1/10

G. E. Vaughn, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, contractors, and agents of Carolina Power & Light Company.

James Lealyn P. Midgley
Notary (Seal)

My commission expires: Aug. 12, 1991