

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

(412) 393-5255

July 22, 1991

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
Unqualified Fire Dampers (TAC No. 66319)


- Ref: 1) NRC Letter to DLC, dated June 29, 1990
2) DLC Letter to NRC, dated December 19, 1989
3) DLC Special Report, dated September 15, 1989

As requested by NRC letter dated June 29, 1990, the below notification is provided regarding the implementation of the fire damper replacement work at BVPS Unit No. 1.

Replacement has been completed for all 17 fire dampers affected by the UL fire test results noted in Reference (3). During the 8th refueling outage at Unit 1, replacement dampers were installed. Upon completion of installation, each of the dampers was operationally tested. Based on satisfactory testing results, the fire dampers were declared operable, and the compensatory measures in the form of fire watch patrols for the affected areas were terminated.

This completes our corrective actions for the Unit 1 fire dampers. Should there be any questions regarding this matter, please contact John Maracek at (412) 393-5232.

Sincerely,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. M. L. Bowling (VEPCO)

9107290138 910722
PDR ADOCK 05000334
F PDR

A006
1/0