

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

PHONE (717) 542-2181 X-3246

Continuation Sheet

Licensee Event Report 83-059/03L-0

Item 10 cont'd:

not immediately recognized that the Action statement associated with the LCO were in effect. Cold shutdown was achieved on April 8, per the outage schedule, which was not in accordance with Action requirements.