NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MAPP S0 (2) | 00-00000-00 (3) | 4 1 1 1 1 (4) | 1 (5)
LICENSEE CODE (9–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 - 0 2 9 3 (7) | 0 4 0 2 8 3 (8) | 0 4 2 7 8 3 (9)
DOCKET NUMBER (61–65) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During a scram recovery, an overload annunciation was received when
03 MOV-220-2 (Main Steam Line Drain Valve) was switched to open. The valve
04 was made inoperable. The redundant in-line valve verified closed and in-
05 vestigation into the cause initiated. This event created no threat to
06 the public health and safety.
07
08

09 SYSTEM CODE CC (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE CKTBRK (14) | COMP. SUBCODE D (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 | — | SEQUENTIAL REPORT NO. 016 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER 0776 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Upon investigation, the breaker was found to be not tripped. The valve was
11 then manually inspected and operated. The operator motor insulation was
12 inspected and the running current checked out. No mechanical binding or
13 electrical damage was found. The most probable cause of this event is a
14 spurious annunciator from the overload mechanism in the Cutler-Hammer motor
control center. The valve was returned to service on 4/3/83.

15 FACILITY STATUS C (25) | % POWER 000 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operational Event

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION N/A

20 PUBLICITY ISSUED Z (44) | DESCRIPTION (45) N/A | NRC USE ONLY

8305230521 830427
PDR ADOCK 05000293
S PDR

NAME OF PREPARER G. G. Whitney PHONE: (617)746-7900