

# Duquesne Light Company

Beaver Valley Power Station  
PO Box 4  
Shippingport, PA 15077-0004

JOHN D. SIEBER  
Vice President, Nuclear Group

401,993,626

July 15, 1991

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Proposed Operating License Change Request 191  
(TAC No. 80559)


Enclosed are the following:

1. An application for amendment to the above license to provide heatup and cooldown curves applicable to 16 effective full power years (EFPY) and change the overpressure protection system (OPPS) setpoint and enable temperature to reflect analysis results applicable to 16 EFPY.
2. Documents designated Attachments A,B,C,D,E and F which set forth, respectively, the changes in the Technical Specifications, the safety analysis (including the no significant hazards evaluation), the typed replacement pages, UFSAR changes, Life Attainment Plan and the Low Temperature Overpressure Protection System Setpoint Analysis (including a Westinghouse letter describing a reduction in the setpoint by 4°F).

This change has been reviewed by the Onsite Safety Committee and the Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The requested target date for approval of this proposed change is February 28, 1992.

Sincerely,

  
J. D. Sieber  
Vice President  
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. T. M. Gerusky, Director BRP/DER  
Mr. R. Janati, BRP/DER  
Mr. M. L. Bowling (VEPCO)

206

9107300092 910715  
PDR ADOCK 05000334  
P PDR

A001  
111