



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649



TELEPHONE
AREA CODE 716 46-2700

APRIL 19, 1983

MR. J. M. ALLAN
ACTING REGIONAL ADMINISTRATOR
U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PA. 19406

SUBJECT: LER 83-013/01T-0, STEAM GENERATOR TUBE DEGRADATION

DEAR MR. ALLAN:

THIS LETTER IS TO CONFIRM OUR CONVERSATION OF TUESDAY, APRIL 19, 1983 REPORTING LICENSEE EVENT REPORT, LER 83-013/01T-0 TO YOUR SENIOR RESIDENT INSPECTOR.

THE RESULTS OF THE MULTIFREQUENCY EDDY CURRENT EXAMINATION OF THE "A" STEAM GENERATOR INLET AND OUTLET REVEALED NO TUBES WITH INDICATIONS ABOVE THE PLUGGING LIMIT.

THE RESULTS OF THE EXAMINATION OF THE "B" STEAM GENERATOR INLET AND OUTLET REVEALED 23 TUBES IN THE INLET (HOT LEG) THAT HAVE TUBESHEET CREVICE INTERGRANULAR ATTACK INDICATIONS ABOVE THE PLUGGING LIMIT.

FURTHER INFORMATION REGARDING CORRECTIVE ACTION FOR THESE 23 TUBES IN THE "B" STEAM GENERATOR INLET WILL BE PRESENTED IN OUR 14 DAY WRITTEN REPORT, LER 83-013/01T-0.

BRUCE A. SNOW
PLANT SUPERINTENDENT

BAS/nh

xc: J. E. MAIER
R. P. ZIMMERMAN
CAR 1447 FILE

8305230526 830419
PDR ADOCK 05000244
S PDR

1/0
1529