

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	A	B	V	S	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9	14						15	25										26	30					57	58	
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE						CAT		

CON'T

0 1
7 8

REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 0 4 0 9 8 3 8 0 5 0 9 8 3 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On 4/9/83, while performing the Safeguards Protection System

0	3	Train A Test, the motor thermal overload relay for the Containment
---	---	--

0	4	Sump to 1A LHSI Pump Suction Valve (MOV-SI-860A) was found tripped,
---	---	---

0 5 | disabling the motor. After resetting the relay, the valve was stroked

06 | satisfactorily. There were no safety implications since the valve

07 | was properly positioned for short term core cooling for both safety trains |

08 | with long term cooling available through the redundant SI train. |

7 8

SYSTEM CODE

9 10

CAUSE CODE

11

CAUSE SUBCODE

12

COMPONENT CODE

13

COMP. SUBCODE

14

VALVE SUBCODE

15

16

(17)	LER REPORT NUMBER	[8 3]	[]	[0 1 1]	[]	[0 3]	[L]	[]	[0]			
		21	22	23	24	26	27	28	29	30	31	32
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP SUPPLIER	COMPONENT MANUFACTURER				
[K]	[18]	[Z]	[]	[0 0 0 0]	[Y]	[N]	[A]	[W 1 2 1]				
33	34	35	36	37	40	41	42	43	44	47		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Electrical maintenance testing of the valve motor operator and
---	---	--

overload heater relay following the incident on 4/9/83 yielded satisfactory

1 2 results as did subsequent stroke tests of the valve. No cause for the relay

1 3 | actuation was determined through these tests. The station will re-evaluate |

1 4 | this incident in the event of similar future problems with this valve. |

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
1	5	E	(28)	1	0	0	(29)	N/A	3	(31)	Surveillance Test

ACTIVITY		CONTENT		RELEASED		OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	
1	6	7	22	7	24	N/A					

PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION
39		

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
8305230527 830509
PDR ADOCK 05000334
8305230527 830509
PDR ADOCK 05000334

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
			0	0	0	40																							
LOSS OF OR DAMAGE TO FACILITY																													

TYPE		DESCRIPTION
1	0	2 (42) N/A

MOBILITY		ISSUED		DESCRIPTION		NRC USE ONLY	
2	9	N	(44)	N/A			

NRC USE ONLY

Attachment to LER 83-011/03L
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.