



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

May 6, 1983

Mr. J.M. Allan
Acting Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-056/03L-0
ER 100450 FILE 841-23
PLA-1653

Docket No. 50-387
License No. NPF-14

Dear Mr. Allan:

Attached please find a copy of Licensee Event Report No. 83-056/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the reactor coolant system cooldown rate limit was exceeded twice within a two hour period. Concurrent with these instances, the Residual Heat Removal shutdown cooling loop required to be in operation automatically isolated. There was another occurrence of loss of shutdown cooling one day later. The unit was in Condition 3 at the time of the occurrences.

LER's 83-030/03L-0 and 83-034/03L-0 are similar in that they deal with the loss of shutdown cooling.


H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/pjg

attachment

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8305230534 830506
PDR ADOCK 05000387
S PDR

IE22