



TU ELECTRIC

Log # TXX-91258
File # 10110
908.3
Ref. # 10CFR50.55(e)

William J. Cahill, Jr.
Executive Vice President

July 24, 1991

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) - UNIT 2
DOCKET NO. 50-446
POTENTIAL FOR ELECTRICAL PENETRATION
ASSEMBLIES OVERPRESSURIZATION
SDAR: CP-91-001 (INTERIM REPORT)

REF: TU Electric Letter logged TXX-91056 from William J. Cahill, Jr. to
U. S. Nuclear Regulatory Commission dated February 1, 1991

Gentlemen:

TU Electric notified the NRC staff, via the referenced letter, of a reportable deficiency involving the potential for electrical penetration assembly overpressurization. The purpose of this report is to update the status of the corrective actions.

The corrective actions as stated in referenced letter were as follows:
"Unit 2 Engineering is closely monitoring the corrective actions of Unit 1. Upon completion of design validation of the (EPA) Electrical Penetration Assemblies Nitrogen Pressurization System and related corrective action by Unit 1, Unit 2 Engineering will review the results and determine the corrective actions required for Unit 2. We anticipate this action to be complete by July 31, 1991."

9107300290 910724
PDR ADOCK 05000446
S PDR

400 North Olive Street L.B. 81 Dallas, Texas 75201

IE27
110

The evaluation for specific corrective actions for Unit 1 is continuing. Therefore, the review and determination of specific corrective actions required for Unit 2 will be submitted by January 31, 1992.

Sincerely,

William J. Cahill, Jr.

By: J. S. Marshall
J. S. Marshall
Generic Licensing Manager

JLR/bm

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (2)
Mr. M. B. Fields, NRR